



# ALINTA ENERGY REEVES PLAINS POWER STATION

DEVELOPMENT APPLICATION



12 OCTOBER 2017

# **APPENDIX F – AIR QUALITY IMPACT ASSESSMENT**



This document has been prepared on behalf of **Arcadis Australia Pacific Pty Ltd** by:

**Northstar Air Quality Pty Ltd,**

**Level 40, 100 Miller Street, North Sydney, NSW 2060**

**[www.northstarairquality.com](http://www.northstarairquality.com) | Tel: +61 (02) 9931 7870**

## **Reeves Plains Power Station Project, Air Quality Impact Assessment**

**Addressee(s):** Arcadis Australia Pacific Pty Ltd

**Report Reference:** 17.1052.FR1V1

**Date:** 13 September 2017

## Disclaimer

This report has been prepared with the due care and attention of a suitably qualified consultant. Information is obtained from sources believed to be reliable, but is in no way guaranteed. No guarantee of any kind is implied or possible where predictions of future conditions are attempted. This report (including any enclosures and attachments) has been prepared for the exclusive use and benefit of the addressee(s) and solely for the purpose for which it is provided. Unless we provide express prior written consent, no part of this report should be reproduced, distributed or communicated to any third party. We do not accept any liability if this report is used for an alternative purpose from which it is intended, nor to any third party in respect of this report.

## Quality Control

Study	Status	Prepared by	Checked by	Authorised by
INTRODUCTION	Final	Northstar Air Quality	MD, EH, SW	GCG, MD
THE PROJECT	Final	Northstar Air Quality	MD, EH, SW	GCG, MD
EXISTING CONDITIONS	Final	Northstar Air Quality	MD, EH, SW	GCG, MD
METHODOLOGY	Final	Northstar Air Quality	MD, EH, SW	GCG, MD
CONSTRUCTION PHASE RISK ASSESSMENT	Final	Northstar Air Quality	MD, EH, SW	GCG, MD
OPERATIONAL PHASE IMPACT ASSESSMENT	Final	Northstar Air Quality	MD, EH, SW	GCG, MD
DISCUSSION	Final	Northstar Air Quality	MD, EH, SW	GCG, MD

## Report Status

Northstar References		Report Status	Report Reference	Version
Year	Job Number	(Draft: Final)	(R.x)	(V.x)
17	1052	F	R1	V1
Based upon the above, the specific reference for this version of the report is:				17.1052.FR1V1

## Final Authority

This report must be regarded as draft until the above study components have been each marked as final, and the document has been signed and dated below.



**G. Graham**

**13 September 2017**

---

## Non-Technical Summary

Arcadis Australia Pacific Pty Ltd, on behalf of Alinta Energy (Reeves Plains) Pty Ltd, has engaged Northstar Air Quality Pty Ltd to perform an impact assessment study of the potential impacts upon air quality of the construction and operation of the Reeves Plains Power Station Project (the Project).

The power station will be located at 1629 Redbanks Road on a 41 hectare greenfield site located in Reeves Plains, approximately 12 kilometres south-east of Mallala and 50 kilometre north of Adelaide (the Project site).

The purpose of this Air Quality Impact Assessment is to assess the impact of the construction and operation of the Project upon air quality, determine compliance (or otherwise) with the South Australia *Environmental Protection (Air Quality) Policy* (2016) and make recommendations for changes to operations where the studies show that there is an unacceptable risk to the environment.

The Project involves the construction and operation of a series of six (6) 50-megawatt dual-fuel gas turbines to generate peak-demand electricity for export to the electricity grid and each turbine will discharge exhaust gases to atmosphere via a dedicated 3.5 metre diameter emission stack at a discharge height of 15.5 metres above ground level. The proposed power station can be operated at various reduced load profiles, and emissions of air pollutants have been shown to vary according to the operating load. The Project is capable of operating on either natural gas or mineral diesel as fuel. The Project is to operate the power station on natural gas with an option to operate on mineral diesel in case of interruption of the gas supply and this AQIA considers the potential impacts of the operation of the power station operating on both fuels.

The Air Quality Impact Assessment presents an assessment of potential impacts during the construction and operation of the Project. The construction phase assessment uses a risk-based methodology adapted from the Institute of Air Quality Management (2014) *IAQM Guidance on the Assessment of Dust from Demolition and Construction*. Using this methodology, it is concluded that construction dust emissions may be adequately controlled through the application of a range of suitable construction management practices, and that these should be documented within a Construction Environmental Management Plan (CEMP).

The potential impacts from the operation of the Project have been assessed using a referenced dispersion modelling study, using meteorological data as specified by the Environmental Protection Authority, representative background monitoring data and using emission rates derived directly from Alinta Energy (Reeves Plains) Pty Ltd. Based upon the assumptions presented in the Air Quality Impact Assessment it is predicted that the operation of the power station on either gas or mineral diesel will not result in a breach of the standards prescribed in the South Australia *Environmental Protection (Air Quality) Policy* (2016).

---

It is recommended that a suitable campaign of compliance monitoring should be implemented to the satisfaction of the Environmental Protection Authority. It is considered that the demonstration that the engines are capable of being operated as set out in this Air Quality Impact Assessment is of critical importance, and that a program of emissions testing with the engines operating on gas and diesel and at various loads should be implemented as a condition of approval.

Whilst the Air Quality Impact Assessment predicts that the air quality risks associated with operation at full capacity (300 megawatts) are within acceptable limits, it is considered that the environmental risks are further managed by the proposed staged development. Implementing the recommended program of compliance emissions monitoring during the initial stage (150 megawatts installed capacity) would provide the Environmental Protection Authority with increased assurance that the proposed plant is able to achieve its performance objectives prior to operating the second stage (300 megawatt installed capacity).

In light of the above, and in consideration of the proposed verification studies, it is considered to be reasonable to conclude that the proposed construction and operation of the Project should not be refused on grounds of air quality.

## Contents

1.	INTRODUCTION .....	11
1.1.	Approach .....	11
1.2.	Objective of the Study .....	11
1.3.	Ambient Air Quality Standards .....	12
2.	THE PROJECT .....	13
2.1.	Environmental Setting .....	13
2.2.	Overview .....	14
2.3.	Potential for Emissions to Air .....	15
2.3.1.	Construction .....	15
2.3.2.	Operation .....	15
3.	EXISTING CONDITIONS .....	17
3.1.	Topography .....	17
3.2.	Surrounding Land Sensitivity .....	18
3.2.1.	Discrete Receptor Locations .....	18
3.2.2.	Uniform Receptor Locations .....	22
3.3.	Air Quality .....	22
3.3.1.	Source of Data for Background Gaseous Pollutants .....	23
3.3.2.	Source of Data for Background Particulates .....	24
3.3.3.	Application of Background Data .....	24
3.4.	Meteorology .....	25
4.	METHODOLOGY .....	29
4.1.	Construction Phase Risk Assessment .....	29
4.2.	Operational Phase Impact Assessment .....	31
4.2.1.	Emissions Estimation (Gas) .....	32
4.2.2.	Emissions Estimation (Diesel) .....	33
4.2.3.	Start-Up Emissions .....	34
4.2.4.	Dispersion Modelling .....	36
4.2.5.	Meteorological Processing .....	37

4.2.6.	Short-Term Impacts.....	39
4.2.7.	Particle Size Fractions .....	39
4.2.8.	NO <sub>x</sub> to NO <sub>2</sub> Reactions .....	39
5.	CONSTRUCTION PHASE RISK ASSESSMENT .....	41
5.1.	Impact Magnitude.....	43
5.2.	Sensitivity of an Area.....	44
5.2.1.	Land Use Value .....	44
5.2.2.	Sensitivity of an Area.....	44
5.3.	Risk (Pre-Mitigation) .....	44
5.4.	Identified Mitigation .....	45
5.5.	Risk (Post-Mitigation) .....	49
6.	OPERATIONAL PHASE IMPACT ASSESSMENT .....	51
6.1.	Predicted Incremental Operational Impacts .....	51
6.1.1.	Operating on Gas.....	51
6.1.2.	Operating on Diesel .....	52
6.2.	Predicted Cumulative Operational Impacts .....	53
6.2.1.	Operating on Gas.....	53
6.2.2.	Operating on Diesel .....	54
6.3.	Predicted Start-Up Impacts.....	55
7.	DISCUSSION .....	57
7.1.	Construction Phase Air Quality Impacts.....	57
7.2.	Operational Phase Air Quality Impacts.....	58
7.2.1.	Operating on Gas.....	59
7.2.2.	Operating on Diesel .....	60
7.2.3.	Start Up Emissions .....	61
7.3.	Conclusions.....	61
8.	REFERENCES.....	63



## Appendices

Appendix A	Meteorology
Appendix B	Background Air Quality
Appendix C	Emissions Estimation
Appendix D	Construction Dust Assessment Methodology
Appendix E	Dispersion Modelling Results
Appendix F	Technical Specifications
Appendix G	Practitioner Capability Statement

## Tables

Table 1	Air EPP ambient air standards	12
Table 2	Discrete sensitive receptor locations used in the study	19
Table 3	Summary of assumed background concentrations	25
Table 4	Details of meteorological monitoring surrounding the power station	25
Table 5	Turbine locations	31
Table 6	Emissions per engine operating on gas	32
Table 7	Emissions per engine operating on diesel	33
Table 8	Factor weighted emissions profiles for start-up and shut-down (U1 and U2)	36
Table 9	Meteorological Parameters used for this Study	37
Table 10	Construction phase impact screening criteria distances	41
Table 11	Application of step 1 screening	43
Table 12	Construction phase impact categorisation of dust emission magnitude	43
Table 13	Risk of air quality impacts from construction activities	44
Table 14	Site-specific management measures	45
Table 15	Predicted maximum incremental GLC (all receptors) – gas	51
Table 16	Predicted maximum incremental GLC (all receptors) – diesel	52
Table 17	Predicted maximum cumulative impacts – gas	53
Table 18	Predicted maximum incremental impacts – diesel	54
Table 19	Predicted maximum start-up impacts (all receptors) – gas and diesel	55
Table 20	Summary of impacts (gas) and comparison against Air EPP	59
Table 21	Summary of impacts (diesel) and comparison against Air EPP	60

## Figures

Figure 1	Project location and surrounds	13
Figure 2	Topography surrounding the project site (3-D projection)	17
Figure 3	Topography surrounding the project site (2-D projection)	18
Figure 4	Discrete receptor locations used in the AQIA (close view)	21
Figure 5	Discrete receptor locations used in the AQIA (wide view)	21
Figure 6	Sources of air quality and meteorological data used in the study	23
Figure 7	Annual wind roses 2012 to 2016, Edinburgh RAAF AWS	26
Figure 8	Long-term wind rose (2012 to 2016), Edinburgh RAAF AWS	27
Figure 9	Construction phase risk assessment methodology	30
Figure 10	LM6000 Sprint® start up cycle	34
Figure 11	1-minute average emissions measured during start-up at Bairnsdale Power Station (engine U1 top) (engine U2 bottom)	35
Figure 12	Predicted wind speed and direction – Project site 2009	38

## Units Used in the Report

All units presented in the report follow the International System of Units (SI) conventions, unless derived from references using non-SI units. In this report, units formed by the division of SI and non-SI units are expressed as a negative exponent, and do not use the solidus (/) symbol. For example:

- 3 milligrams per cubic metre would be presented as 3 mg·m<sup>-3</sup> and not 3 mg/m<sup>3</sup>.
- 20 metres per second would be presented as 20 m·s<sup>-1</sup> and not 20 m/s.

The following prefixes are added to unit names to produce multiples and sub-multiples of SI units:

Prefix	Symbol	Factor	Prefix	Symbol	Factor
T	tera-	10 <sup>12</sup>	p	pico-	10 <sup>-12</sup>
G	giga-	10 <sup>9</sup>	n	nano-	10 <sup>-9</sup>
M	mega-	10 <sup>6</sup>	μ	micro-	10 <sup>-6</sup>
k	kilo-	10 <sup>3</sup>	m	milli-	10 <sup>-3</sup>
h	hector-	10 <sup>2</sup>	c	centi-	10 <sup>-2</sup>
da	deca	10 <sup>1</sup>	d	deci-	10 <sup>-1</sup>

## Common Abbreviations

Abbreviation	Term
AGL	above ground level
AHD	Australian height datum
AQIA	air quality impact assessment
AQMS	air quality monitoring station
AWS	automatic weather station
BoM	Bureau of Meteorology
CH <sub>2</sub> O	formaldehyde
CO	carbon monoxide
CSIRO	Commonwealth Scientific and Industrial Research Organisation
EPA	Environmental Protection Authority
g·s <sup>-1</sup>	gram per second
ha	hectare
HAP	hazardous air pollutant
K	degrees Kelvin
m	metre
m·s <sup>-1</sup>	metres per second
mg·m <sup>-3</sup>	milligram per cubic metre of air
µg·m <sup>-3</sup>	micrograms per cubic metre of air
mg·Nm <sup>-3</sup>	milligram per normalised cubic metre of air
MW	megawatt
NEPM	National Environment Protection Measure
NO	nitric oxide
NO <sub>x</sub>	total oxides of nitrogen
NO <sub>2</sub>	nitrogen dioxide
ppb	parts per billion (1x10 <sup>-9</sup> )
ppm	parts per million (1x10 <sup>-6</sup> )
SO <sub>2</sub>	sulphur dioxide
TAPM	The Air Pollution Model
TSP	total suspended particulates
US EPA	United States Environmental Protection Agency
UTM	Universal Transverse Mercator

## 1. INTRODUCTION

Arcadis Australia Pacific Pty Ltd (Arcadis), on behalf of Alinta Energy (Reeves Plains) Pty Ltd (Alinta Energy), has engaged Northstar Air Quality Pty Ltd (Northstar) to perform an impact assessment study of the potential impacts upon air quality of the construction and operation of the Reeves Plains Power Station Project (the Project).

The Project involves the construction and operation of a series of six (6) 50-megawatt (MW) dual-fuel gas turbines to generate peak-demand electricity for export to the electricity grid.

The power station will be located at 1629 Redbanks Road on a 41 hectare (ha) greenfield site located in Reeves Plains, approximately 12 kilometres (km) south-east of Mallala and 50 km north of Adelaide (the Project site). The proposed site is located at 280,680 mE 6,179,275 mS (UTM).

The purpose of this Air Quality Impact Assessment is to assess the impact of the construction and operation of the Project upon air quality and determine compliance with the South Australia *Environmental Protection (Air Quality) Policy* (2016) (Air EPP).

### 1.1. Approach

During the preparation of this AQIA reference has been made to the South Australian Environment Protection Authority (EPA) specifications and requirements presented in Environment Protection Authority (2016) Ambient Air Quality Assessment<sup>1</sup> (EPA, 2016). That guidance publication sets out the EPA's requirements and expectations for an AQIA to adequately assess impacts upon air quality under the *Environment Protection Act* (1993) and the *Development Act* (1993).

**Appendix G** presents a Capability Statement, as specified in Appendix 1 of EPA 2016. **Appendix G** additionally presents the key requirements specified in EPA 2016 as relates to a dispersion modelling assessment.

### 1.2. Objective of the Study

The objective of this Air Quality Impact Assessment is to determine whether the proposed power station may be constructed and operated at the Project site without breaching the environmental objectives, evaluated as a risk in terms of construction dust, and compliance with the standards prescribed under the *Environment Protection (Air Quality) Policy* 2016 (Air EPP) during operation.

---

<sup>1</sup> [http://www.epa.sa.gov.au/environmental\\_info/air\\_quality/assistance\\_and\\_advice](http://www.epa.sa.gov.au/environmental_info/air_quality/assistance_and_advice)

Where the AQIA identifies that those environmental objectives are not achievable, the objective is to identify further mitigation that may be applied to achieve those objectives, which may include changes to operational conditions, air pollution control or restricted operations, as appropriate.

### 1.3. Ambient Air Quality Standards

State air quality guidelines adopted by the South Australia EPA are published in the *Environment Protection (Air Quality) Policy 2016* (Air EPP) under section 28 of the *Environment Protection Act* (1993). Where relevant to the expected potential scope of emissions to air from the operation of the power station (see **Section 2.3.2**), the ground level concentration standards are reproduced from Schedule 2 of the Air EPP in **Table 1** below:

**Table 1 Air EPP ambient air standards**

Pollutant	Classification	Averaging time	Maximum concentration (mg·m <sup>-3</sup> )	Maximum concentration (ppm)
Carbon monoxide (CO)	Toxicity	1 hour	31.24	25
		8 hours	11.12	9.0
Nitrogen dioxide (NO <sub>2</sub> )	Toxicity	1 hour	0.25	0.12
		12 months	0.06	0.03
Particles (as PM <sub>10</sub> )	Toxicity; Group 1 carcinogen	24 hours	0.05	-
Particles (as PM <sub>2.5</sub> )	Toxicity; Group 1 carcinogen	24 hours	0.025	-
		12 months	0.008	-
Sulphur dioxide (SO <sub>2</sub> )	Toxicity	1 hour	0.57	0.2
		24 hours	0.23	0.08
		12 months	0.06	0.02
Formaldehyde (CH <sub>2</sub> O)	Toxicity; Group 1 carcinogen	3 minutes	0.044	0.033

The air quality standards presented in **Table 1** represent the standards to be achieved for the Project in this AQIA.

## 2. THE PROJECT

The following provides a description of the Project, the environmental setting and the identified potential emissions of air pollutants which may result from the construction and operation of the power station.


### 2.1. Environmental Setting

The Project site is located at Reeves Plains, approximately 12 km to the south-east of Mallala and approximately 14 km to the north-west of Gawler, as shown in **Figure 1**.

The 41 ha site is located to the south of the junction of Gawler Road and Days Road at Reeves Plains.

The Project site is located in a rural area, with mixed residential and agricultural land uses. The land at the Project site is flat and at a height of approximately 50-52 metres (m) Australian Height Datum (AHD).

**Figure 1** Project location and surrounds



Source: Northstar Air Quality

## 2.2. Overview

The power station will operate as a 'peaker', providing electricity during periods of high demand, and is designed to generate up to 300 megawatts (MW) of power and will be delivered in two stages with up to 150 MW installed initially with further build out as required by prevailing market conditions. The Project includes the following infrastructure:

- A gas receival station;
- Up to six (6) dual fuel (gas and diesel) turbines each capable of generating 50 MW of power;
- Three (3) transformers designed to convert low voltage electricity into high voltage electricity
- Connection to the electricity network including a new substation, transmission tower and communications tower;
- Water supply and storage including:
  - Water treatment plant;
  - Water storage tanks;
  - Firefighting system;
- Evaporation pond; and
- Diesel storage.

Also included within the Project are the following:

- Control rooms, workshop and maintenance facilities and administration building;
- Security fencing and lighting;
- Onsite drainage works;
- Upgrade to the Redbanks Road and Day Road intersection and sealing of Day Road from Redbanks Road to the Project entrance;
- Carparking for employees and contractors;
- Demolition of existing buildings onsite; and
- Landscaping.

The Project is required to obtain development consent from the State Commission Assessment Panel before proceeding. Construction of the Project is scheduled to commence in 2018 with operation of the power station occurring in Q1 2020 at the earliest.

The power station will operate six (6) dual-fuel gas turbines and each turbine will discharge exhaust gases to atmosphere via a dedicated 3.5 metre (m) diameter emission stack at a discharge height of 15.5 m above ground level (AGL).

The proposed power station can be operated at various reduced load profiles, and emissions of air pollutants have been shown to vary according to the operating load (refer **Section 4.2**).



Further, the proposed power station is capable of operating on either natural gas or diesel as fuel. The Project is to operate the power station on natural gas with an option to operate on mineral diesel (hereafter referred to as 'diesel') in case of interruption of the gas supply and this AQIA considers the potential impacts of the operation of the power station operating on both fuels.

## 2.3. Potential for Emissions to Air

### 2.3.1. Construction

The potential emissions to air during the construction phase will be associated with the emission of particulates associated with the various construction activities, including: demolition; earthworks and enabling works; construction; track-out and construction traffic.

Additionally, the operation of construction vehicles and plant may give rise to short-term engine exhaust emissions, however given the low number of construction vehicles expected for such a development, these emissions have not been quantitatively assessed.

### 2.3.2. Operation

Potential emissions to air during operation of the power station are associated with products of combustion of the fuel. The power station will be equipped to operate principally on gas, but with a capability to operate on diesel should the gas supply not be available, and depending on the fuel consumed the rate of emissions may vary and consequently, the principal emissions during operation involve emissions of the following air pollutants:

- **Oxides of nitrogen.** Oxides of nitrogen ( $\text{NO}_x$ ) are principally emitted as nitric oxide (NO), nitrogen dioxide ( $\text{NO}_2$ ) and a small component of nitrous oxide ( $\text{N}_2\text{O}$ ) and combined these gases are termed as total oxides of nitrogen ( $\text{NO}_x$ ). These pollutants are formed in the combustion zone where the high operating temperatures generate thermal  $\text{NO}_x$  from the nitrogen in the air, and are typically emitted as 90-95% NO and 5-10%  $\text{NO}_2$ . Upon emission to the atmosphere, secondary reactions occur that oxidise NO to  $\text{NO}_2$ .
- **Carbon monoxide.** Carbon monoxide (CO) is a colourless and odourless gas, formed due to the incomplete combustion of fuel.
- **Sulphur dioxide.** Sulphur dioxide ( $\text{SO}_2$ ) emissions are generated from the oxidation of sulphur in the fuel during combustion. Australian Standard (AS/NZS 4564) provides a limit of sulphur in natural gas of 50 milligrams per cubic metre of air ( $\text{mg}\cdot\text{m}^{-3}_{101.3\text{kPa}, 288\text{K}}$ ). The sulphur content of diesel is specified by the *Fuel Quality Standards Act (2000)* which limits the sulphur content to 10 parts per million (ppm).
- **Particulate matter.** Particulate matter (PM) may be generated through the combustion of fuels, and may be described in terms of the particle size fraction, including:

- TSP: Particulate matter with an aerodynamic diameter of (approximately) 30 micrometres ( $\mu\text{m}$ ) to 10  $\mu\text{m}$ ;
- $\text{PM}_{10}$ : Particulate matter with an aerodynamic diameter of 10  $\mu\text{m}$  or less; and
- $\text{PM}_{2.5}$ : Particulate matter with an aerodynamic diameter of 2.5  $\mu\text{m}$  or less.

The combustion of gas creates extremely low rates of particle emissions due to the nature of the fuel. The US Environmental Protection Agency (US EPA) identifies that particulate emissions from gas turbines is principally composed of larger molecular weight hydrocarbons that have been incompletely combusted, and virtually 100% are less than 1  $\mu\text{m}$  in diameter. For this project, given that virtually all particles emitted from the combustion of gas in a gas turbine are <1  $\mu\text{m}$ , particulates from gas are assessed as  $\text{PM}_{2.5}$ , which is a subset of  $\text{PM}_{10}$ .

In regard to particulates from diesel, again virtually 100% of diesel particles are less than 1  $\mu\text{m}$  in diameter, and given that virtually all particles emitted from the combustion of diesel are <1  $\mu\text{m}$ , particulates from diesel are assessed as  $\text{PM}_{2.5}$ .

- **Hazardous air pollutants.** Hazardous air pollutants (HAP) is a term applied to a range of pollutants. The US EPA AP-42 states: "*available data indicate that emission levels of HAP are lower for gas turbines than for other combustion sources. This is due to the high combustion temperatures reached during normal operation. The emission data also indicate that formaldehyde is the most significant HAP emitted from combustion turbines. For natural gas fired turbines, formaldehyde accounts for about two-thirds of the total HAP emissions...*"

The rate at which pollutants are emitted to atmosphere will further vary by the load requirements on the power station. For the purposes of this assessment, the emission rates have been estimated for each fuel type (gas and diesel) at four load points: 100% load (maximum); 75% load; 50% load; and 25% load.


Further details regarding the estimation of emissions are provided in **Section 4.2**.

### 3. EXISTING CONDITIONS

#### 3.1. Topography


The elevation of the proposed site of the power station is approximately 51 m AHD. The topography of the surrounding area gradually increases with distance from the coast, but is generally flat, as shown in **Figure 2** and **Figure 3**.

Figure 2 Topography surrounding the project site (3-D projection)



Source: Northstar Air Quality

Figure 3 Topography surrounding the project site (2-D projection)



Source: Northstar Air Quality

## 3.2. Surrounding Land Sensitivity

### 3.2.1. Discrete Receptor Locations

Air quality assessments typically use a desk-top mapping study to identify 'discrete receptor locations', which are intended to represent a selection of locations that may be susceptible to changes in air quality. In broad terms, the identification of sensitive receptors refers to places at which humans may be present for a period representative of the averaging period for the pollutant being assessed. Typically, these locations are identified as residential properties although other sensitive land uses may include schools, medical centres, places of employment, recreational areas or ecologically sensitive locations.

**Table 2** represents the discrete receptor locations that have been identified as part of this study (see also **Figure 4** and **Figure 5**).

The table and figures are not intended to represent a definitive list of sensitive land uses, but a cross section of available locations that are used to characterise larger areas, or selected as they represent more sensitive locations which may represent people who are more susceptible to changes in air pollution than the general population.

**Table 2 Discrete sensitive receptor locations used in the study**

Receptor	Land Use	Location (m, UTM)	
		m E	m S
R1	81 Woolsheds Rd	280,802	6,180,445
R2	30 Worden Rd	280,887	6,180,723
R3	228 Worden Rd	281,208	6,182,691
R4	1152 Wasleys Rd	281,000	6,183,054
R5	1149 Wasleys Rd	280,988	6,183,329
R6	1227 Wasleys Rd	281,824	6,183,173
R7	347 Wasleys Rd	282,267	6,182,599
R8	262 Woolsheds Rd	282,132	6,181,850
R9	64 Woolsheds Rd	281,055	6,180,364
R10	43 Dogleg Rd	281,546	6,179,695
R11	67 Dogleg Rd	281,717	6,179,745
R12	77 Dogleg Rd	281,895	6,179,716
R13	264 Boundary Rd	282,355	6,179,801
R14	236 Boundary Rd	282,316	6,179,937
R15	21-43 Bache Rd	282,118	6,180,067
R16	43 Bache Rd	281,974	6,180,028
R17	57 Bache Rd	281,893	6,180,127
R18	75 Bache Rd	281,589	6,180,133
R19	206 Boundary Rd	282,292	6,180,331
R20	164 Boundary Rd	282,296	6,180,531
R21	351 Boundary Rd	282,439	6,178,681
R22	312 Buckby Rd	284,644	6,179,971
R23	332 Selleck Rd	285,286	6,180,921
R24	448 Oliver Rd	285,218	6,186,065
R25	1 Wasleys Rd	286,333	6,182,891
R26	23 Henry Turton Circuit	286,806	6,182,682
R27	18 Pratt Rd	287,518	6,182,285
R28	11 Mitchell Rd	287,817	6,180,228
R29	Roseworthy College Hall	287,781	6,176,833
R30	1357 Redbanks Rd	282,991	6,177,713
R31	1005 Redbanks Rd	286,078	6,175,841
R32	248 Fairlie Rd	286,767	6,173,164
R33	364 Mortimer Rd	283,767	6,173,540
R34	Aunger Rd N	280,940	6,178,220
R35	236 Day Rd	279,363	6,177,606
R36	334 Day Rd	279,072	6,176,764
R37	206 Gregor Rd	281,817	6,175,884
R38	513 Day Rd	277,563	6,175,602
R39	560 Jenkin Rd	275,398	6,174,285

Receptor	Land Use	Location (m, UTM)	
		m E	m S
R40	1061 Germantown Rd	275,495	6,177,173
R41	1321 Germantown Rd	275,457	6,178,960
R42	86 Hall Rd	276,178	6,181,208
R43	70 Hall Rd	276,162	6,181,408
R44	40 Hall Rd	276,155	6,181,733
R45	26 Hall Rd	276,123	6,181,970
R46	325 Hall Rd	276,443	6,179,020
R47	715 Verner Rd	278,479	6,178,454
R48	188 Cheek Rd	277,319	6,183,792
R49	1800 Redbanks Rd	279,581	6,180,379
R50	1561 Redbanks Rd	281,638	6,179,015
R51	1806 Redbanks Rd	279,209	6,179,731

The receptors used in the study have been selected to include a range of receptor locations in all directions from the site, to account for the potential changes due to the prevailing meteorology.

The receptor closest to the boundary of the Project site is Receptor 10 [R10], located at 43 Dogleg Road which is approximately 500 m from the site.

Due to the geographical spread of the receptors used in this study, the maps showing the receptor locations have been replicated to show a closer view (larger scale) showing those receptor locations closer to the site boundary, and a wide view (smaller scale) showing those less proximate. The closer view is presented in **Figure 4** and the wide view is presented in **Figure 5**. Some receptors are identified on both Figures.

Figure 4 Discrete receptor locations used in the AQIA (close view)





Figure 5 Discrete receptor locations used in the AQIA (wide view)



Source: Northstar Air Quality

### 3.2.2. Uniform Receptor Locations

Additional to the sensitive receptors identified in **Section 3.2.1**, a grid of receptor locations has been used in the AQIA to allow presentation of contour plots of predicted impacts.

The grid of uniform receptors covers a longitudinal and latitudinal distance of 20,000 m, covering an area of 400 square kilometres, from UTM 271,530 mE, 6,169,050 mS.

The grid resolution has been set at 25 m (approx.  $1.5 \times$  stack height) and this represents over 640,000 receptor locations.

### 3.3. Air Quality

The air quality experienced at any location will be a result of emissions generated by natural and anthropogenic sources on a variety of scales (local, regional and global). The relative contributions of sources at each of these scales to the air quality at a location will vary based on a wide number of factors including the type, location, proximity and strength of the emission source(s), prevailing meteorology, land uses and other factors affecting the emission, dispersion and fate of those pollutants.

When assessing the impact of any particular source of emissions on the potential air quality at a location, the impact of all other local and regional sources of an individual pollutant must also be assessed. This 'background' air quality will vary depending on the pollutants to be assessed, and can often be characterised by using representative air quality monitoring data.

The EPA maintain and operate a number of ambient air quality monitoring stations (AQMS) across South Australia. The on-line data resource maintained by the EPA has been accessed from the South Australia Government Data Directory<sup>2</sup> and the data recorded at the various AQMS have been reviewed for the purposes of establishing a suitable and representative baseline assumption for use in this AQIA. The air quality (and meteorological) sources of data used in this AQIA are illustrated in **Figure 6**.


Further details, including summary statistics, distribution and graphs of measured background air pollutants are presented in **Appendix B**.

---

<sup>2</sup> <https://data.sa.gov.au/data/dataset?tags=air+quality&organization=environment-protection-authority-epa>



Figure 6 Sources of air quality and meteorological data used in the study



Source: Northstar Air Quality

### 3.3.1. Source of Data for Background Gaseous Pollutants

The most proximate AQMS to the Project site is the Elizabeth Downs monitoring station, located in the grounds of Elizabeth Downs Primary School at 12 Heard Street, Elizabeth Downs, approximately 22.5 km to the south south-east of the Project site. The AQMS is located in the middle of a highly urbanised location, and as such the data measured at the site will be significantly influenced by urban emission sources, including road traffic. It is therefore considered that the use of this site as proxy data to represent the Project site would be conservative.

Elizabeth Downs AQMS does not measure SO<sub>2</sub> and so surrogate measurements taken at Adelaide Northfield have been used to characterise the background conditions.

### 3.3.2. Source of Data for Background Particulates

At the request of the EPA, Netley AQMS was referenced as the monitoring location to determine background particulate concentrations. Netley AQMS is located on a commercial lot near to the junction of Richmond Road and Transport Avenue in Netley, Western Adelaide. It is located approximately 50 km to the south south-west of the Project site in an urbanised location, and approximately 250 m from the boundary of Adelaide Airport and as such, it is considered that the use of this data to represent the Project site is highly conservative.

### 3.3.3. Application of Background Data

The application of recent background data to predicted dispersion modelling results for 2009 (the EPA's preferred 'reference' year [see **Section 3.4**]) needs to be undertaken with care. Clearly, applying a contemporaneous approach (as is used in other jurisdictional areas in Australia) is not appropriate as the conditions of meteorology during 2009 and background variations during 2015 are not concurrent and clearly not appropriate.

Alternative to this is to use a constant single value to represent the conditions at the Project site over the assessment year (2009). The application of the measured annual average background concentration to predictions of incremental annual average is clearly applicable, as this does not need to account for conditions that give rise to short-term elevations in emissions. However, that approach would also under-predict short term cumulative predictions although that approach has been used historically in South Australia, for example SA Water *Proposed Adelaide Desalination Plant Environmental Impact Statement, Chapter 9: Noise, Dust, Odour and Waste Management*. That assessment, performed by Connell Wagner, used the annual average PM<sub>10</sub> concentration as background to evaluate the 24-hour PM<sub>10</sub> impacts, and was approved on that basis.

Other recent studies, for example the AQIA for the Duplication of the Southern Expressway<sup>3</sup> has used the 90<sup>th</sup> percentile of short-term measurements, and this is considered to be conservative and appropriate for this study.

Summary details of air quality measurements at the Elizabeth Downs, Netley and Northfield AQMS are presented in **Appendix B**. The baseline data derived from the monitoring data is summarised in **Table 3**.

---

<sup>3</sup> [https://dpti.sa.gov.au/\\_data/assets/pdf\\_file/0020/59402/Part\\_B\\_Chapter\\_16\\_Air\\_quality.pdf](https://dpti.sa.gov.au/_data/assets/pdf_file/0020/59402/Part_B_Chapter_16_Air_quality.pdf)

**Table 3 Summary of assumed background concentrations**

Pollutant	Averaging Period	Concentration Value Assumed	Notes
Carbon monoxide (CO)	1-hour	0.04 mg·m <sup>-3</sup>	90%ile of 1-hour CO, Elizabeth Downs, 2015
	8-hour	0.05 mg·m <sup>-3</sup>	90%ile of 8-hour CO, Elizabeth Downs, 2015
Nitrogen dioxide (NO <sub>2</sub> )	1 hour	20.5 µg·m <sup>-3</sup>	90%ile of 1-hour NO <sub>2</sub> , Elizabeth Downs, 2015
	annual average	8.2 µg·m <sup>-3</sup>	Annual average NO <sub>2</sub> , Elizabeth Downs, 2016
Particulates (as PM <sub>10</sub> )	24-hour	15.7 µg·m <sup>-3</sup>	90%ile of 24-hour PM <sub>10</sub> , Netley, 2015
Particulates (as PM <sub>2.5</sub> )	24-hour	10.4 µg·m <sup>-3</sup>	90%ile of 24-hour PM <sub>2.5</sub> , Netley, 2015
	annual average	7.3 µg·m <sup>-3</sup>	Annual average PM <sub>2.5</sub> , Netley, 2015
Sulphur dioxide (SO <sub>2</sub> )	1-hour	28.6 µg·m <sup>-3</sup>	Maximum 1-hour SO <sub>2</sub> , Northfield 2015
	24-hour	5.8 µg·m <sup>-3</sup>	Maximum 24-hour SO <sub>2</sub> , Northfield 2015
	annual average	0.2 µg·m <sup>-3</sup>	Annual average SO <sub>2</sub> , Northfield 2015
Formaldehyde (CH <sub>2</sub> O)	1-hour	0 µg·m <sup>-3</sup>	Assumed to be negligible (zero) for the purposes of the AQIA

Reference should be made to **Appendix B** for details of the background air quality conditions.

### 3.4. Meteorology

This section briefly discusses the existing meteorology in the area, using measurements taken from neighbouring Automatic Weather Stations (AWS) operated by the Australian Government Bureau of Meteorology (BoM). The meteorology used in the dispersion modelling assessment is discussed in **Section 4.2.5**.


The meteorology experienced within an area can govern the dispersion, transport and eventual fate of pollutants in the atmosphere. The meteorological conditions surrounding the power station site have been characterised using data collected by the BoM, and a summary of the relevant AWS monitoring site locations is provided in **Table 4**.

**Table 4 Details of meteorological monitoring surrounding the power station**

Site Name	Approximate Location (Latitude, Longitude)	
	°S	°E
Edinburgh RAAF – Station # 023083	34.71	138.62
Outer Harbour – Station # 023052	34.73	138.47
Parafield Airport – Station # 023013	34.80	138.63

Details of the prevailing meteorology are presented in **Appendix A**, however for clarity the wind roses for Edinburgh RAAF AWS are also presented in **Figure 7**.

Figure 7 Annual wind roses 2012 to 2016, Edinburgh RAAF AWS




Source: Northstar Air Quality

The wind roses indicate that from 2012 to 2016, winds at Edinburgh RAAF AWS show a predominant southwesterly wind direction with a north-easterly and south-easterly components also evident, and there is little in the way of annual variation. The majority of wind speeds experienced at the Edinburgh RAAF AWS between 2012 and 2016 are generally in the range 1.5 metres per second (m·s<sup>-1</sup>) to 5.5 m·s<sup>-1</sup> with the highest wind speeds (greater than 8 m·s<sup>-1</sup>) occurring from a south easterly direction. Winds of this speed are rare and occur during 1.1% of the observed hours during the years. Calm winds (<0.5 m·s<sup>-1</sup>) occur for less than 3.7% of hours across the years.

Presented in **Figure 8** is the long-term wind rose for the 2012 to 2016 period and the annual wind speed distribution for Edinburgh RAAF AWS.

Figure 8 Long-term wind rose (2012 to 2016), Edinburgh RAAF AWS



Source: Northstar Air Quality

Page left intentionally blank

---

## 4. METHODOLOGY

### 4.1. Construction Phase Risk Assessment

Construction phase activities have the potential to generate short-term emissions of particulates. Generally, these are associated with uncontrolled (or 'fugitive') emissions and are typically experienced by neighbours as amenity impacts, such as dust deposition and visible dust plumes, rather than associated with health-related impacts. Localised engine exhaust emissions from construction machinery and vehicles may also be experienced, but given the scale of the proposed works, fugitive dust emissions would have the greatest potential to give rise to downwind air quality impacts.

Modelling of dust from construction sites is generally not considered appropriate, as there is a lack of reliable emission factors from construction activities upon which to make predictive assessments, and the rates would vary significantly depending upon local conditions, construction practices and implemented dust mitigation measures. In lieu of a modelling assessment, the construction phase impacts associated with the Project have been assessed using a risk-based assessment procedure. The advantage of this approach is that it determines the activities that pose the greatest risk, which allows the Construction Environmental Management Plan (CEMP) to focus controls to manage that risk appropriately, and reduce the impact through proactive management.


For this risk assessment, Northstar has adapted a methodology presented in the Institute of Air Quality Management (2014) *IAQM Guidance on the Assessment of Dust from Demolition and Construction* (IAQM 2014) developed in the United Kingdom<sup>4</sup>. Reference should be made to **Appendix D** for the methodology.

Briefly, the adapted method uses a six-step process for assessing dust impact risks from construction activities, and to identify key activities for control, as illustrated in **Figure 9**.

---

<sup>4</sup> [www.iaqm.co.uk/text/guidance/construction-dust-2014.pdf](http://www.iaqm.co.uk/text/guidance/construction-dust-2014.pdf)

Figure 9 Construction phase risk assessment methodology



Source: Northstar Air Quality, adapted from IAQM 2014)

The assessment approach is detailed in **Appendix D**.



## 4.2. Operational Phase Impact Assessment

The following provides a brief description of the methodology used to assess the potential air quality impacts resulting from the operation of the proposed power station at the varying load profiles. The Project is to construct and operate six open-cycle gas turbines operating on gas, with a capacity to operate on diesel as a support fuel in case of interruption of the gas supply.

Reference has been made to the specifications and requirements presented in Environment Protection Authority (2016) Ambient Air Quality Assessment<sup>5</sup> and a practitioner capability statement has been presented in **Appendix G**.

The location to the six turbines will be as indicated in **Table 5**.

**Table 5 Turbine locations**

Unit No	Type	Co-ordinates (MGAZ54)	
		mE	mS
1	Point source	280,541	6,179,051
2	Point source	280,538	6,179,091
3	Point source	280,535	6,179,127
4	Point source	280,532	6,179,167
5	Point source	280,530	6,179,205
6	Point source	280,527	6,179,242

<sup>5</sup> [http://www.epa.sa.gov.au/environmental\\_info/air\\_quality/assistance\\_and\\_advice](http://www.epa.sa.gov.au/environmental_info/air_quality/assistance_and_advice)

#### 4.2.1. Emissions Estimation (Gas)

The estimation of emissions from the power station operating on gas has been informed from emission estimates provided by Alinta Energy, and assumed to be representative of the emissions from the Project.

**Table 6** below presents a summary of the emissions data estimates used in this assessment for gas operating at 100% load; 75% load; 50% load and 25% load. Full details are presented in **Appendix C**.

**Table 6 Emissions per engine operating on gas**

Pollutant	Units	Reference Conditions	Engine Load (% of Capacity)			
			100	75	50	25
Gas Volumetric Discharge						
Discharge rate	Nm <sup>3</sup> ·hr <sup>-1</sup>	STP, dry, 15% O <sub>2</sub>	241,796.9	197,070.3	153,710.9	128,906.3
Temperature	°C		395	390	434	421
Velocity	m·s <sup>-1</sup>	Stack temperature	17.08	13.82	11.49	9.45
Emission Rate						
NO <sub>x</sub> (as NO <sub>2</sub> )	g·s <sup>-1</sup>		3.4389	2.8028	2.1861	1.8333
CO	g·s <sup>-1</sup>		2.0956	1.7079	1.3322	1.1172
SO <sub>2</sub>	g·s <sup>-1</sup>		0.5496	0.4488	0.3524	0.2935
PM <sub>2.5</sub>	g·s <sup>-1</sup>		0.3780	0.3780	0.3780	0.3780
Formaldehyde	g·s <sup>-1</sup>		0.0341	0.1192	0.0924	0.0684

Sulphur dioxide emissions operating on gas have been estimated from an assumed fuel sulphur content in natural gas of 50 mg·m<sup>-3</sup> (101.3kPa, 288 K) as specified in Australian Standard (AS/NZS 4564), and the emission rates provided by Alinta Energy (assuming a nominal 0.1% sulphur) have been scaled accordingly to represent anticipated sulphur content.

Formaldehyde emissions operating on gas have been estimated from the emission rates published in US EPA (1995) *Compilation of Air Pollutant Emission Factors AP-42, Volume 1, Chapter 3: Stationary Internal Combustion Sources (fifth edition)* (USEPA 1995), Section 3.1, Table 3.1-3:

Formaldehyde 7.09x10<sup>-4</sup> lb·MMBtu<sup>-1</sup> (7.23x10<sup>-1</sup> lb·MMscf) (loads >80%, i.e. 100% load) (*emission factor rating A*)

3.12x10<sup>-3</sup> lb·MMBtu<sup>-1</sup> (3.18x10<sup>0</sup> lb·MMscf) (all loads, i.e. 75%, 50% and 25% loads)

The above published formaldehyde emission factors were used in conjunction with provided gas consumption rates for all loads (see **Appendix F**), assuming an AP-42 derived natural gas reference temperature of 60°F (15.6°C), and a gas density of approximately 0.8 kg·m<sup>-3</sup>.

#### 4.2.2. Emissions Estimation (Diesel)

The estimation of emissions from the power station operating on diesel has been informed from emission estimates provided by Alinta Energy, and assumed to be representative of the emissions from the Project.

**Table 7** below presents a summary of the emissions data estimates used in this assessment for gas operating at 100% load; 75% load; 50% load and 25% load. Full details are presented in **Appendix C**.

**Table 7 Emissions per engine operating on diesel**

Pollutant	Units	Reference Conditions	Engine Load (% of Capacity)			
			100	75	50	25
Gas Volumetric Discharge						
Discharge rate	Nm <sup>3</sup> ·hr <sup>-1</sup>	STP, dry, 15% O <sub>2</sub>	216,179.0	178,415.6	163,453.8	122,732.5
Temperature	°C	-	399	413	437	423
Velocity	m·s <sup>-1</sup>	Stack temperature	15.36	12.95	12.27	9.03
Emission Rate						
NO <sub>x</sub> (as NO <sub>2</sub> )	g·s <sup>-1</sup>	-	10.4667	8.6333	7.9139	5.9389
CO	g·s <sup>-1</sup>	-	1.8736	1.5463	1.4166	1.0637
SO <sub>2</sub>	g·s <sup>-1</sup>	-	0.0468	0.0386	0.0361	0.0271
PM <sub>2.5</sub>	g·s <sup>-1</sup>	-	0.3780	0.3780	0.3780	0.3780
Formaldehyde	g·s <sup>-1</sup>	-	0.0063	0.0055	0.0058	0.0051

Sulphur dioxide emissions operating on diesel have been estimated from an assumed fuel sulphur content of 10 ppm (0.0001% v/v) as specified by the *Fuel Quality Standards Act (2000)* and the emission rates provided by Alinta Energy (assuming a nominal 0.1% sulphur) have been scaled accordingly to represent actual sulphur content.

Formaldehyde emissions operating on diesel have been estimated from the emission rates published in US EPA *AP-42, Volume 1, Chapter 3: Stationary Internal Combustion Sources*, Section 3.1, Table 3.1-4:

Formaldehyde  $2.82 \times 10^{-4}$  lb·MMBtu<sup>-1</sup> ( $3.92 \times 10^{-2}$  lb·1000gal) (loads >80% i.e. 100% load) (*emission factor rating B*)

$2.45 \times 10^{-4}$  lb·MMBtu<sup>-1</sup> ( $3.41 \times 10^{-2}$  lb·1000gal) (all loads i.e. 75%, 50% and 25% loads)

The above published formaldehyde emission factors were used in conjunction with provided diesel consumption rates for all loads (see **Appendix F**), and assuming a diesel fuel density of approximately 0.832 kg·L<sup>-1</sup>.


Further details are provided in **Appendix C**.

### 4.2.3. Start-Up Emissions

The figure below is reproduced from Figure 5-11 'LM6000 10 minutes start cycle' as presented in GE Energy (2008) LM6000-50/60 Hz Gas Turbine Generator Set Product Specification (GE Energy 2008), as reproduced in **Appendix H**. The product specification presented in **Appendix H** shows that the proposed LM6000 Sprint® turbines are capable of completing the start-up and ramp-up to full-load within a 10-minute start-up cycle.

*“It can also start and stop easily for “peaking” or “dispatched” applications. Additionally, quick dispatchability is available in simple-cycle applications with the 10-minute fast start feature.”*

Figure 10 LM6000 Sprint® start up cycle





Source: GE Energy 2008

The start-up cycle is important, as the products of combustion during non-ideal conditions are different than those generated when the turbine is operating normally under load, and this is a significant consideration for a peaking plant.

The emission estimates presented in **Section 4.2.1** and **Section 4.2.2** for gas and diesel respectively, and presented in more detail in **Appendix C**, are derived from emissions data supplied directly by Alinta Energy.

To address the issue of start-up emissions, Alinta has provided emissions data from the Bairnsdale Power Station (using similar technology to that proposed at Reeves Plains), and those data are presented in **Figure 11** below for two turbine sets (names U1 and U2):

Figure 11 1-minute average emissions measured during start-up at Bairnsdale Power Station (engine U1 top) (engine U2 bottom)



Source: Northstar Air Quality

Based upon the data summarised above, the maximum 1-min peak CO and NO<sub>x</sub> measured data during the start-up cycle has been compared to the average steady-state emissions during normal operations. For the purposes of this AQIA, this cut-off time between start-up and normal operations has been assumed to be at 32 minutes (see **Figure 11**). It is the numerical relationship between the maximum value before 32 minutes and the average value after 32 minutes that is important, not the actual values.

**Table 8 Factor weighted emissions profiles for start-up and shut-down (U1 and U2)**

Pollutant ( $p$ )	Operational Emission Rate	Start-Up Emission Rate	Start-Up Weighting $F_p$
CO	7.4	186.8	25.12
NO <sub>x</sub> (as NO <sub>2</sub> )	19.4	40.2	2.07

Considering the 10-minute start up cycle of the proposed generators (see **Appendix H**), the resultant hourly emission rates may be estimated assuming a time weighted averaging approach. Using the above, the results of the operational phase AQIA may be sequentially factored for start-up emissions to the determination short-term (1-hour) impacts during start-up. These factors have been used to conservatively estimate the predicted ground-level concentrations of CO and NO<sub>x</sub> (as NO<sub>2</sub>) during the start-up cycle, and are used in **Section 6.2**.

The measured data shows that the engines may emit short-term spikes of CO during start-up and a smaller differential of NO<sub>x</sub> emissions (as represented in the start-up weighting factors presented in **Table 8**). The data presented in **Figure 11** also shows that the emission rate of CO and NO<sub>x</sub> does not vary significantly with load, supporting the assumptions presented in **Sections 4.2.1 - 4.2.2**.

#### 4.2.4. Dispersion Modelling

Emissions from the power station have been modelled using the US EPA's AERMOD modelling system. The SA EPA makes the following observations regarding AERMOD (EPA 2016):

##### **AERMOD**

*AERMOD is a new generation Gaussian plume dispersion model developed by the US EPA. The model is an improvement on Ausplume in that it incorporates recent boundary layer theory and advanced methods for handling:*

- *terrain*
- *dispersion under stable and unstable conditions*
- *plume rise and buoyancy*
- *plume penetration into elevated inversions*
- *treatment of elevated near-surface and surface-level sources*
- *computation of vertical profiles of wind*
- *turbulence*
- *temperature*
- *terrain effects on plume behaviour.*

*AERMOD also includes algorithms to take into account the effects of any buildings near the emission source/s. EPA Victoria has recently changed its preferred regulatory model from Ausplume to AERMOD.*

Given the relatively flat and simple terrain of the study area surrounding the Project site, it is considered that AERMOD is an appropriate dispersion model for use in this study.

#### 4.2.5. Meteorological Processing

Dispersion models require meteorological data as input to affect the dispersion and transport of pollutants emitted from a source.

A detailed summary of the application of local meteorology over the period from 2012 to 2016 is discussed in the Existing Conditions chapter in **Section 3.4** and discussed in further detail in **Appendix A**.

As required by the EPA, the dispersion modelling assessment that underpins the AQIA has used a reference calendar year of 2009. The EPA has requested that this year is used to provide a level of consistency between various studies, and to avoid the unintentional use of meteorological data not representative of long-term trends.

For clarity, this AQIA has used 2009 as the reference year, compliant with the requirements of the EPA.

Meteorological modelling using The Air Pollution Model (TAPM, v 4.0.5) has been performed to predict the meteorological parameters for 2009 that are required for AERMOD. TAPM, developed by the Commonwealth Scientific and Industrial Research Organisation (CSIRO) is a prognostic model which may be used to predict three-dimensional meteorological data and air pollution concentrations.

TAPM predicts wind speed and direction, temperature, pressure, water vapour, cloud, rain water and turbulence. The program allows the user to generate synthetic observations by referencing databases (covering terrain, vegetation and soil type, sea surface temperature and synoptic scale meteorological analyses) which are subsequently used in the model input to generate site-specific hourly meteorological observations at user-defined levels within the atmosphere.

The parameters used in TAPM modelling are presented in **Table 9** and presented in further detail in **Appendix A**.

**Table 9 Meteorological Parameters used for this Study**

TAPM v 4.0.5	
Modelling period	1 January 2009 to 31 December 2009
Centre of analysis	280,713 mE, 6179,316 mN (UTM Coordinates)
Number of grid points	70 × 70 × 25
Number of grids (spacing)	4 (20 km, 10 km, 3 km, 1 km)
Terrain	AUSLIG 9 second DEM
Data assimilation	None

A comparison of the TAPM generated meteorological data, and BoM observations is presented in **Appendix A**. For completeness, the TAPM model predictions have been extracted and compared to BoM observations at the following locations:

- Edinburgh RAAF AWS
- Outer Harbour AWS


It is observed that these data generally compare well, and this provides confidence that the meteorological conditions modelled as part of this assessment are appropriate.

**Appendix A** provides graphical summaries of the TAPM predicted meteorological conditions at the Project site, including:

- Hourly mixing heights at the Project site for 2009;
- Hourly ambient temperatures at the Project site for 2009;
- Hourly wind speed and direction at the Project site for 2009.

The predicted wind-rose distribution of wind speed and direction data is presented in **Figure 12** below:

**Figure 12 Predicted wind speed and direction – Project site 2009**



**Frequency of counts by wind direction (%)**

**Source:** Northstar Air Quality

For clarity, this data has been used by AERMET / AERMOD in the dispersion modelling.



#### 4.2.6. Short-Term Impacts

The time resolution of dispersion modelling is defined by the hourly limitation of the meteorology, which uses hourly averaged data.

With regard to predicting the potential impacts of HAP (as formaldehyde) (see **Section 2.3.2**) the predicted impact is required to be compared against the 3-minute average criterion (see **Section 1.3**). To derive this prediction from the maximum 1-hour average prediction, the following Power Law adjustment has been applied<sup>6</sup>:

$$C_{p,t} = C_{p,60} \left[ \frac{60}{t} \right]^{0.2}$$

Where:

- $C_{p,t}$  = concentration of pollutant (p) at averaging time (mins) (t)
- $C_{p,60}$  = concentration of pollutant (p) at modelled averaging time (60 mins)
- $t$  = time (mins)

#### 4.2.7. Particle Size Fractions

The technical specification documents indicate that the proposed turbines are capable of operating on dual fuel with a maximum particle emission rate of 3 pounds (lbs) per hour.

As outlined in **Section 2.3.2**, the USEPA has published that virtually 100% of particulates emitted from gas and diesel combustion in turbines is <1µm in diameter and correspondingly it is considered reasonable to assess the potential particulate emissions as PM<sub>2.5</sub>.

As PM<sub>2.5</sub> is a 'subset', or a component of PM<sub>10</sub>, the AQIA also presents the predicted PM<sub>10</sub> impacts albeit it that the predicted results are identical.

#### 4.2.8. NO<sub>x</sub> to NO<sub>2</sub> Reactions

The emission rates of oxides of nitrogen (NO<sub>x</sub>) have been modelled as nitrogen dioxide (NO<sub>2</sub>). As discussed in **Section 2.3.2**, approximately 90% - 95% of NO<sub>x</sub> from a combustion process will be emitted as NO, with the remaining 5% - 10% emitted directly as NO<sub>2</sub>. Over time and after the point of discharge, NO in ambient air will be transformed by secondary atmospheric reactions to form NO<sub>2</sub>, and this reaction often occurs at a considerable distance downwind from the point of emission, and by which time the plume will have dispersed and diluted significantly from the concentration at point of discharge.

<sup>6</sup> <http://www.epa.vic.gov.au/~media/Publications/1551.pdf>

---

Air quality impact assessments need to account for the conversion of NO to NO<sub>2</sub> to enable a comparison against the air quality criterion for NO<sub>2</sub>. To perform this, various techniques are common, which are briefly outlined below:

- **100% conversion:** the most conservative assumption is to assume that 100% of the total NO<sub>x</sub> emitted is discharged as NO<sub>2</sub>, and that further reactions do not occur.
- **Jansen method:** where the location is represented by good monitoring data for NO and NO<sub>x</sub>, the empirical relationship between NO and NO<sub>2</sub> may be used to derive 'steady state' relationships.
- **Ozone limiting method:** this method uses contemporaneous ozone data to estimate that rate at which NO is oxidised to NO<sub>2</sub> hour-on-hour using an established relationship.

This AQIA assumes that 100% of the emitted NO<sub>x</sub> is in the form of NO<sub>2</sub>, which presents the most conservative approach.

## 5. CONSTRUCTION PHASE RISK ASSESSMENT

The area of the site as a whole is approximately 41 hectares (ha) although the footprint of the site which is to be affected by works and installed infrastructure is estimated as approximately 12 ha in area (120,000 m<sup>2</sup>).

The Project would involve the preparation of the ground with some minor grading, and the construction of a piled concrete pad upon which the turbines and associated infrastructure will be located. The Project will not involve any demolition as the land is currently undeveloped.

The assumed supply route around the Project site during construction works may be up to 275 m one-way. It may be anticipated that >50 heavy vehicle movements would be required each day to service the Project site. For the purposes of the assessment, the route for construction traffic to/from the site is assumed to be along Wilton Road, in either direction of the site.

The screening criteria applied to the identified sensitive receptors are whether they are located in excess of:

- 350 m from the boundary of the site.
- 500 m from the site entrance.
- 50 m from the route used by construction vehicles on public roads.
- Track-out is assumed to affect roads up to 100 m from the site entrance.

**Table 10** presents the identified discrete sensitive receptors, with the corresponding estimated screening distances as compared to the screening criteria.

**Table 10 Construction phase impact screening criteria distances**

Rec	Location	Land Use	Screening Distance (m)		
			Boundary (350m)	Site Entrance (500m)	Construction route (50m)
R1	81 Woolsheds Rd	Residential	757	1,041	>50
R2	30 Worden Rd	Residential	1,048	1,300	>50
R3	228 Worden Rd	Residential	3,036	3,262	>50
R4	1,152 Wasleys Rd	Residential	3,361	3,622	>50
R5	1,149 Wasleys Rd	Residential	3,633	3,897	>50
R6	1,227 Wasleys Rd	Residential	3,669	3,820	>50
R7	347 Wasleys Rd	Residential	3,334	3,393	>50
R8	262 Woolsheds Rd	Residential	2,631	2,649	>50
R9	64 Woolsheds Rd	Residential	796	931	>50
R10	43 Dogleg Rd	Residential	516	564	>50
R11	67 Dogleg Rd	Residential	685	739	>50
R12	77 Dogleg Rd	Residential	831	894	>50
R13	264 Boundary Rd	Residential	1,290	1,358	>50

Rec	Location	Land Use	Screening Distance (m)		
			Boundary (350m)	Site Entrance (500m)	Construction route (50m)
R14	236 Boundary Rd	Residential	1,305	1,366	>50
R15	21-43 Bache Rd	Residential	1,198	1,245	>50
R16	43 Bache Rd	Residential	1,058	1,102	>50
R17	57 Bache Rd	Residential	1,062	1,095	>50
R18	75 Bache Rd	Residential	875	885	>50
R19	206 Boundary Rd	Residential	1,495	1,535	>50
R20	164 Boundary Rd	Residential	1,632	1,663	>50
R21	351 Boundary Rd	Residential	1,409	1,582	>50
R22	312 Buckby Rd	Residential	3,559	3,637	>50
R23	332 Selleck Rd	Residential	4,428	4,493	>50
R24	448 Oliver Rd	Residential	7,829	7,835	>50
R25	1 Wasleys Rd	Residential	6,271	6,316	>50
R26	23 Henry Turton Circuit	Residential	6,561	6,612	>50
R27	18 Pratt Rd	Residential	7,012	7,071	>50
R28	11 Mitchell Rd	Residential	6,737	6,816	>50
R29	Roseworthy College Hall	Educational	7,057	7,218	>50
R30	1,357 Redbanks Rd	Residential	2,322	2,595	>50
R31	1,005 Redbanks Rd	Residential	5,931	6,182	36
R32	248 Fairlie Rd	Residential	8,169	8,486	>50
R33	364 Mortimer Rd	Residential	6,107	6,490	>50
R34	Aunger Rd N	Residential	811	1,218	>50
R35	236 Day Rd	Residential	1,623	2,485	>50
R36	334 Day Rd	Residential	2,499	3,321	>50
R37	206 Gregor Rd	Residential	3,223	3,631	>50
R38	513 Day Rd	Residential	4,304	5,178	>50
R39	560 Jenkin Rd	Residential	6,738	7,642	>50
R40	1,061 Germantown Rd	Residential	5,073	5,995	>50
R41	1,321 Germantown Rd	Residential	4,780	5,610	>50
R42	86 Hall Rd	Residential	4,634	5,183	>50
R43	70 Hall Rd	Residential	4,740	5,269	>50
R44	40 Hall Rd	Residential	4,871	5,406	>50
R45	26 Hall Rd	Residential	5,002	5,539	>50
R46	325 Hall Rd	Residential	3,794	4,622	>50
R47	715 Verner Rd	Residential	1,834	2,749	>50
R48	188 Cheek Rd	Residential	5,224	5,736	>50
R49	1,800 Redbanks Rd	Residential	1,206	1,744	>50
R50	1,561 Redbanks Rd	Residential	567	724	>50
R51	1806 Redbanks Rd	Residential	1,610	2,060	>50

With reference to **Table 10**, no sensitive receptors are identified as being within the screening distance associated with either the site boundary or site entrance criteria and therefore no further assessment of construction phase impacts is required.

In relation to the construction route (assumed to be from the Project site to Gawler along Gawler Road), one receptor (R31) is within the 50 m screening distance, although once the construction route enters Gawler itself, multiple properties would be within the 50 m screening distance. Further assessment is therefore required for impacts associated with construction traffic as summarised in **Table 11**.

Although impacts associated with earthworks, construction and track-out have been screened from further assessment, dust control measures will still be implemented at the Project site to ensure that offsite impacts are minimised and best practice is implemented. It is noted that the two small structures located to the north-east of the site would be demolished as part of the proposed scope of construction works.

**Table 11 Application of step 1 screening**

Construction Impact	Screening Criteria	Step 1 Screening	Comments
Earthworks	350 m from boundary 500 m from site entrance	Screened	Receptors not identified within the screening distance
Construction	350 m from boundary 500 m from site entrance	Screened	
Track-out	100 m from site entrance	Screened	
Demolition	350 m from boundary 500 m from site entrance	Screened	
Construction Traffic	50 m from roadside	Not screened	Receptors identified within the screening distance

## 5.1. Impact Magnitude

It may be anticipated that >50 heavy vehicle movements would be required each day to service the Project site during peak construction periods.

Based upon the above assumptions and the assessment criteria presented in **Appendix D**, the dust emission magnitudes are as presented in **Table 12**.

**Table 12 Construction phase impact categorisation of dust emission magnitude**

Activity	Dust Emission Magnitude
Construction traffic routes	small

**Note:** Earthworks, construction and track-out have been screened from further assessment (refer **Table 11**)

## 5.2. Sensitivity of an Area

### 5.2.1. Land Use Value

Based on the criteria listed in **Appendix D**, the land use value of the area surrounding the Project site is concluded to be high for health impacts and for dust soiling, based upon the following assumption:

- The receptor locations include residential properties where people may reasonably be expected to be present for eight to 24-hours.

Given that the highest sensitivity land uses would tend to define the level of control required to minimise impacts, it is considered that these sensitivity land uses are appropriately considered for both health and dust soiling effects. This value is used to derive *the sensitivity of the area*.

### 5.2.2. Sensitivity of an Area

Using the classifications shown in **Appendix D**, the sensitivity of the surrounding area to health effects and dust soiling may be identified.

The sensitivity of the area to dust soiling effects is assessed as being *low*.

The assumed existing background annual average PM<sub>10</sub> concentrations (as measured at Elizabeth Downs in 2015) are reported in **Section 3.3**. The annual average PM<sub>10</sub> concentration as measured at Elizabeth Downs in 2015 was 14.94 µg m<sup>-3</sup>, which provides the sensitivity of the area as *low* for dust health impacts.

## 5.3. Risk (Pre-Mitigation)

Given the sensitivity of the identified receptors is classified as 'low' for dust soiling, and 'low' for health effects, and the dust emission magnitudes for the various construction phase activities as shown in **Table 12**, the resulting risk of air quality impacts (without mitigation) is as presented in **Table 13**.

**Table 13 Risk of air quality impacts from construction activities**

Impact	Sensitivity of Area	Dust Emission Magnitude	Preliminary Risk
		Construction Traffic	Construction Traffic
Dust Soiling	low	small	negl
Human Health	low	small	negl

**Note:** Earthworks, construction and track-out have been screened from further assessment (refer **Table 11**)

The risks summarised in **Table 13** that there is a *negligible* risk of adverse dust soiling and human health impacts at all properties if no mitigation measures were to be applied to control emissions associated with construction traffic activities.

## 5.4. Identified Mitigation

**Table 14** lists the relevant mitigation measures identified, and have been presented as follows:

- **Not required** = not required (although they may be implemented voluntarily).
- **Desirable** = desirable (to be considered as part of the CEMP, but may be discounted if justification is provided).
- **Highly recommended** = highly recommended (to be implemented as part of the CEMP, and should only be discounted if site-specific conditions render the requirement invalid or otherwise undesirable).

The following is presented as *highly recommended* (H) or *desirable* (D) by the IAQM methodology for a *low* risk site for demolition, earthworks, construction and construction traffic. A detailed review of the recommendations would be performed once details of the construction phase are available.

Once again, it is noted that the impacts associated with earthworks, construction and track-out have been screened from the assessment based on the distances to each receptor (**Table 10**). However, dust mitigation measures for those activities associated with a *low* risk site are presented in **Table 14** as those measures would be the minimum which should be applied to ensure best practice dust control for the Project.

**Table 14 Site-specific management measures**

Identified Mitigation		Unmitigated Risk
		Low
1 Communications		
1.1	Develop and implement a stakeholder communications plan that includes community engagement before work commences on site.	Highly recommended
1.1	Display the name and contact details of person(s) accountable for air quality and dust issues on the site boundary. This may be the environment manager/engineer or the site manager.	Highly recommended
1.2	Display the head or regional office contact information.	Highly recommended
1.3	Develop and implement a Dust Management Plan (DMP), which may include measures to control other emissions, approved by the relevant regulatory bodies.	Desirable
2 Site Management		
2.1	Record all dust and air quality complaints, identify cause(s), take appropriate measures to reduce emissions in a timely manner, and record the measures taken.	Highly recommended
2.2	Make the complaints log available to the local authority when asked.	Highly recommended

Identified Mitigation		Unmitigated Risk
		Low
2.3	Record any exceptional incidents that cause dust and/or air emissions, either on- or offsite, and the action taken to resolve the situation in the log book.	Highly recommended
2.4	Hold regular liaison meetings with other high risk construction sites within 500 m of the site boundary, to ensure plans are coordinated and dust and particulate matter emissions are minimised. It is important to understand the interactions of the off-site transport/ deliveries which might be using the same strategic road network routes.	Not recommended
<b>3 Monitoring</b>		
3.1	Undertake daily on-site and off-site inspections where receptors (including roads) are nearby, to monitor dust, record inspection results, and make the log available to the local authority when asked. This should include regular dust soiling checks of surfaces such as street furniture, cars and window sills within 100m of site boundary.	Desirable
3.2	Carry out regular site inspections to monitor compliance with the DMP, record inspection results, and make an inspection log available to the local authority when asked.	Highly recommended
3.3	Increase the frequency of site inspections by the person accountable for air quality and dust issues on site when activities with a high potential to produce dust are being carried out and during prolonged dry or windy conditions.	Highly recommended
3.4	Agree dust deposition, dust flux, or real-time continuous monitoring locations with the relevant regulatory bodies. Where possible commence baseline monitoring at least three months before work commences on site or, if it a large site, before work on a phase commences.	Not recommended
<b>4 Preparing and Maintaining the Site</b>		
4.1	Plan site layout so that machinery and dust causing activities are located away from receptors, as far as is possible.	Highly recommended
4.2	Erect solid screens or barriers around dusty activities or the site boundary that they are at least as high as any stockpiles on site.	Highly recommended
4.3	Fully enclose site or specific operations where there is a high potential for dust production and the site is active for an extensive period.	Desirable
4.4	Avoid site runoff of water or mud.	Highly recommended
4.5	Keep site fencing, barriers and scaffolding clean using wet methods.	Desirable
4.6	Remove materials that have a potential to produce dust from site as soon as possible, unless being re-used on site. If they are being re-used on-site cover as described below	Desirable
4.7	Cover, seed or fence stockpiles to prevent wind erosion	Desirable



Identified Mitigation		Unmitigated Risk
		Low
5 Operating Vehicle/Machinery and Sustainable Travel		
5.1	Ensure all on-road vehicles comply with relevant vehicle emission standards, where applicable	Highly recommended
5.2	Ensure all vehicles switch off engines when stationary - no idling vehicles	Highly recommended
5.3	Avoid the use of diesel or petrol powered generators and use mains electricity or battery powered equipment where practicable	Highly recommended
5.4	Impose and signpost a maximum-speed-limit of 25 kmh on surfaced and 15 kmh on unsurfaced haul roads and work areas (if long haul routes are required these speeds may be increased with suitable additional control measures provided, subject to the approval of the nominated undertaker and with the agreement of the local authority, where appropriate	Desirable
5.5	Produce a Construction Logistics Plan to manage the sustainable delivery of goods and materials.	Not recommended
5.6	Implement a Travel Plan that supports and encourages sustainable travel (public transport, cycling, walking, and car-sharing)	Not recommended
6 Operations		
6.1	Only use cutting, grinding or sawing equipment fitted or in conjunction with suitable dust suppression techniques such as water sprays or local extraction, e.g. suitable local exhaust ventilation systems	Highly recommended
6.2	Ensure an adequate water supply on the site for effective dust/particulate matter suppression/ mitigation, using non-potable water where possible and appropriate	Highly recommended
6.3	Use enclosed chutes and conveyors and covered skips (where relevant).	Highly recommended
6.4	Minimise drop heights from conveyors, loading shovels, hoppers and other loading or handling equipment and use fine water sprays on such equipment wherever appropriate (where relevant).	Highly recommended
6.5	Ensure equipment is readily available on site to clean any dry spillages, and clean up spillages as soon as reasonably practicable after the event using wet cleaning methods.	Desirable
7 Waste Management		
7.1	Avoid bonfires and burning of waste materials.	Highly recommended
8 Measures Specific to Construction		
8.1	Avoid scabbling (roughening of concrete surfaces) if possible	Desirable
8.2	Ensure sand and other aggregates are stored in bunded areas and are not allowed to dry out, unless this is required for a particular process, in which case ensure that appropriate additional control measures are in place	Desirable

Identified Mitigation		Unmitigated Risk
		Low
8.3	Ensure bulk cement and other fine powder materials are delivered in enclosed tankers and stored in silos with suitable emission control systems to prevent escape of material and overfilling during delivery.	Not recommended
8.4	For smaller supplies of fine power materials ensure bags are sealed after use and stored appropriately to prevent dust	Not recommended
9 Measures Specific to Track-Out		
9.1	Use water-assisted dust sweeper(s) on the access and local roads to remove, as necessary, any material tracked out of the site.	Desirable
9.2	Avoid dry sweeping of large areas.	Desirable
9.3	Ensure vehicles entering and leaving sites are covered to prevent escape of materials during transport.	Desirable
9.4	Inspect on-site haul routes for integrity and instigate necessary repairs to the surface as soon as reasonably practicable.	Highly recommended
9.5	Record all inspections of haul routes and any subsequent action in a site log book.	Desirable
9.6	Install hard surfaced haul routes, which are regularly damped down with fixed or mobile sprinkler systems, or mobile water bowsers and regularly cleaned.	Not recommended
9.7	Implement a wheel washing system (with rumble grids to dislodge accumulated dust and mud prior to leaving the site where reasonably practicable).	Desirable
9.8	Ensure there is an adequate area of hard surfaced road between the wheel wash facility and the site exit, wherever site size and layout permits.	Not recommended
9.9	Access gates to be located at least 10 m from receptors where possible.	Not recommended
10 Measures Specific to Construction Traffic (Adapted)		
10.1	Ensure all on-road vehicles comply with relevant vehicle emission standards, where applicable	Highly recommended
10.2	Ensure vehicles entering and leaving sites are covered to prevent escape of materials during transport.	Desirable
10.3	Inspect on-site haul routes for integrity and instigate necessary repairs to the surface as soon as reasonably practicable.	Highly recommended
10.4	Record all inspections of haul routes and any subsequent action in a site log book.	Desirable

**Notes** D = desirable (to be considered), H = highly recommended (to be implemented), N = not required (although can be voluntarily implemented)

## 5.5. Risk (Post-Mitigation)

For almost all construction activity, the adapted methodology notes that the aim should be to prevent significant effects on receptors through the use of effective mitigation and experience shows that this is normally possible.

Given the limited size of the Project site, residual impacts associated with fugitive dust emissions from the Project would be anticipated to remain to be '*not significant*'.

Page left intentionally blank

## 6. OPERATIONAL PHASE IMPACT ASSESSMENT

The methodology used to assess impacts resulting from the power station operation at the various operational loads is discussed in **Section 4.2**. This section presents the results of the dispersion modelling assessment and uses the following terminology:

- Incremental impact – relates to the concentrations predicted as a result of the operation of the power station in isolation.
- Cumulative impact – relates to the concentrations predicted as a result of the operation of the power station plus the background air quality concentrations discussed in **Section 3.3**.

The results are presented in this manner to allow examination of the likely impact of the power station in isolation and the contribution to air quality impacts in a broader sense. Detailed results schedules and isopleth plots of predicted incremental impacts are presented in **Appendix E**.

### 6.1. Predicted Incremental Operational Impacts

#### 6.1.1. Operating on Gas

**Table 15** presents a summary of the predicted incremental ground level concentrations (GLC) of the operation of the turbines operating on gas at various loads. For clarity, **Table 15** presents the maximum predicted incremental impact at any of the identified receptors.

**Table 15** Predicted maximum incremental GLC (all receptors) – gas

Pollutant	Averaging Period	100% load, gas	75% load, gas	50% load, gas	25% load, gas
CO	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	37.47	32.18	25.81	24.76
	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	13.19	14.80	14.12	14.65
NO <sub>x</sub> as NO <sub>2</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	61.49	52.81	42.35	40.64
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	0.53	0.50	0.43	0.41
PM <sub>10</sub> / PM <sub>2.5</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	0.81	1.12	1.37	1.98
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	0.06	0.07	0.07	0.08
SO <sub>2</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	9.83	8.46	6.83	6.51
	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	1.18	1.13	1.28	1.53
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	0.08	0.08	0.07	0.07
Formaldehyde	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	0.61	2.25	1.79	1.52
	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	1.11	4.09	3.26	2.76

The incremental impacts presented in **Table 15** do not include a contribution from background sources (as presented in **Section 3.3.3** and **Table 3**), however, it is noted that there are no incremental exceedances of the Air EPP standards, as presented in **Table 1**.

## 6.1.2. Operating on Diesel

**Table 16** presents a summary of the predicted incremental ground level concentrations (GLC) of the operation of the turbines operating on various diesel loads. For clarity, **Table 15** presents the maximum predicted incremental impact at any of the identified receptors.

**Table 16** Predicted maximum incremental GLC (all receptors) – diesel

Pollutant	Averaging Period	100% load, diesel	75% load, diesel	50% load, diesel	25% load, diesel
CO	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	34.27	29.37	27.04	23.74
	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	13.76	14.27	13.73	14.46
NO <sub>x</sub> as NO <sub>2</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	191.47	163.97	151.07	132.57
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	1.74	1.59	1.49	1.37
PM <sub>10</sub> / PM <sub>2.5</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	0.95	1.19	1.25	2.17
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	0.06	0.07	0.07	0.09
SO <sub>2</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	0.86	0.73	0.69	0.60
	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	0.12	0.12	0.12	0.16
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	0.01	0.01	0.01	0.01
Formaldehyde	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	0.12	0.1	0.11	0.11
	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	0.21	0.19	0.2	0.21

The incremental impacts presented in **Table 16** do not include a contribution from background sources (as presented in **Section 3.3.3** and **Table 3**), however, it is noted that there are no incremental exceedances of the Air EPP standards, as presented in **Table 1**.

## 6.2. Predicted Cumulative Operational Impacts

The following represents the worst-case assessment of cumulative impacts, determined as:

$$\text{cumulative impact} = \text{incremental impact} + \text{background (BG)}$$

### 6.2.1. Operating on Gas

**Table 15** presents a summary of the predicted cumulative ground level concentrations (GLC) of the turbines operating on gas at various loads.

Detailed results schedules (of incremental impacts) are presented in **Appendix E** and summarised in **Table 15**, and background data is presented in **Section 3.3** and **Appendix B**.

The impact assessment criteria used in the AQIA are presented in **Section 1.3**

**Table 17** Predicted maximum cumulative impacts – gas

Pollutant	Averaging Period	BG	100% load, gas	75% load, gas	50% load, gas	25% load, gas	Criterion ( $\mu\text{g}\cdot\text{m}^{-3}$ )
CO	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	40	77.47	72.18	65.81	64.76	31,240
	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	50	63.19	64.8	64.12	64.65	11,120
NO <sub>x</sub> as NO <sub>2</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	20.5	81.99	73.31	62.85	61.14	250
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	8.2	8.73	8.7	8.63	8.61	60
PM <sub>10</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	15.7	16.51	16.82	17.07	17.68	50
PM <sub>10</sub> / PM <sub>2.5</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	10.4	11.21	11.52	11.77	12.38	25
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	7.3	7.36	7.37	7.37	7.38	8
SO <sub>2</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	28.6	38.43	37.06	35.43	35.11	570
	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	5.8	6.98	6.93	7.08	7.33	230
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	0.2	0.28	0.28	0.27	0.27	60
Formaldehyde	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	0.0	0.61	2.25	1.79	1.52	n/a
	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	0.0	1.11	4.09	3.26	2.76	44

**Note:** Exceedance of the relevant criterion is highlighted in **bold red text**

The cumulative impacts presented in **Table 17** include a contribution from background sources (as presented in **Section 3.3.3** and **Table 3**). There are no predicted exceedances of the Air EPP standards, as presented in **Table 1**.

## 6.2.2. Operating on Diesel

**Table 16** presents a summary of the predicted cumulative ground level concentrations (GLC) of the turbines operating on diesel at various loads.

Detailed results schedules (of incremental impacts) are presented in **Appendix E** and summarised in **Table 16**, and background data is presented in **Section 3.3** and **Appendix B**.

The impact assessment criteria used in the AQIA are presented in **Section 1.3**.

**Table 18** Predicted maximum incremental impacts – diesel

Pollutant	Averaging Period	BG	100% load, diesel	75% load, diesel	50% load, diesel	25% load, diesel	Criterion ( $\mu\text{g}\cdot\text{m}^{-3}$ )
CO	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	40	74.27	69.37	67.04	63.74	31,240
	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	50	63.76	64.27	63.73	64.46	11,120
NO <sub>x</sub> as NO <sub>2</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	20.5	211.97	184.47	171.57	153.07	250
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	8.2	9.94	9.79	9.69	9.57	60
PM <sub>10</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	15.7	16.65	16.89	16.95	17.87	50
PM <sub>2.5</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	10.4	11.35	11.59	11.65	12.57	25
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	7.3	7.36	7.37	7.37	7.39	8
SO <sub>2</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	28.6	29.46	29.33	29.29	29.2	570
	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	5.8	5.92	5.92	5.92	5.96	230
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	0.2	0.21	0.21	0.21	0.21	60
Formaldehyde	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	0.0	0.12	0.1	0.11	0.11	n/a
	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	0.0	0.21	0.19	0.2	0.21	44

**Note:** Exceedance of the relevant criterion is highlighted in **bold red text**

The cumulative impacts presented in **Table 18** include a contribution from background sources (as presented in **Section 3.3.3** and **Table 3**). There are no predicted exceedances of the Air EPP standards, as presented in **Table 1**.



### 6.3. Predicted Start-Up Impacts

The predicted start up impacts have been assessed as described in **Section 4.2.3**.

Using the data presented in **Figure 11** and **Table 8**, the predicted short-term effect of start-up emissions of CO and NO<sub>x</sub> (as NO<sub>2</sub>) may be assessed using a time weighted averaging methodology:

$$SER_{p,60} = \frac{10(F_p \times ER_p) + 50(ER_p)}{60}$$

Where

$SER_{p,60}$  = time-weighted start-up emission rate for pollutant  $p$  over 60-mins

$F_p$  = start-up weighting factor for pollutant  $p$

$ER_p$  = emission rate for pollutant  $p$

**Table 19 Predicted maximum start-up impacts (all receptors) – gas and diesel**

Pollutant	BG	Increment	$F_p$	TWA Start Up Impact	Start Up Impact	Criterion ( $\mu\text{g}\cdot\text{m}^{-3}$ )
Gas						
CO $\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	40	37.47 at 100% load	25.12	$40 + \left( \frac{10(25.12 \times 37.47) + 50(1 \times 37.47)}{60} \right)$	228.1	31,240
NO <sub>x</sub> as NO <sub>2</sub> $\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	20.5	61.49 at 100% load	2.07	$20.5 + \left( \frac{10(2.07 \times 61.49) + 50(1 \times 61.49)}{60} \right)$	93.0 (NO <sub>x</sub> )	250 (NO <sub>2</sub> )
Diesel						
CO $\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	40	34.27 at 100% load	25.12	$40 + \left( \frac{10(25.12 \times 34.27) + 50(1 \times 34.27)}{60} \right)$	212.0	31,240
NO <sub>x</sub> as NO <sub>2</sub> $\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	20.5	191.47 at 100% load	2.07	$20.5 + \left( \frac{10(2.07 \times 191.47) + 50(1 \times 191.47)}{60} \right)$	246.1 (NO <sub>x</sub> )	250 (NO <sub>2</sub> )

**Note:** Exceedance of the relevant criterion is highlighted in **bold red text**

The cumulative impacts presented in **Table 19** include a contribution from background sources (as presented in **Section 3.3.3** and **Table 3**), and are time weighted by the start-up weighting factors discussed in **Section 4.2.3** and presented in **Table 8**.

There are no predicted exceedances of the Air EPP standards, as presented in **Table 1**.

As a conservative measure, the maximum ratio of measured 1-minute start up emissions to steady operational emissions has been assumed, and applied to the entire 10-minute start-up period.

Further conservatism assumes that 100% of all emitted NO<sub>x</sub> is NO<sub>2</sub>, which is a highly conservative assumption.

Page left intentionally blank

## 7. DISCUSSION

Arcadis Australia Pacific Pty Ltd has engaged Northstar Air Quality Pty Ltd to perform an assessment of the potential impacts upon air quality associated with the construction and operation of the Reeves Plains Power Station, South Australia.

### 7.1. Construction Phase Air Quality Impacts

Construction phase activities have the potential to generate short-term emissions of particulates. Generally, these are associated with uncontrolled dust emissions and are typically experienced by neighbours as amenity impacts, such as dust deposition and visible dust plumes, rather than associated with health-related impacts.

The construction phase impacts associated with the Project have been assessed using a risk-based assessment procedure. The advantage of this approach is that it determines the activities that pose the greatest risk, which allows the Construction Environmental Management Plan (CEMP) to focus controls to manage that risk appropriately, and reduce the impact through proactive management. For this risk assessment, Northstar has adapted a methodology presented in the *IAQM Guidance on the Assessment of Dust from Demolition and Construction*.

The risk assessment determined that the land use value (predominantly residential properties) was *high*, and taken in conjunction with the existing low background particulate concentrations the sensitivity of the area was *low*.

Given the nature, scale and location of the construction activities, the potential magnitude of impacts was assessed as being *negligible* (screened out) for earthworks, construction and dirt track-out onto Gawler Road, and *small* for the potential magnitude of impacts from construction traffic. Based upon the above, the risk from construction traffic was assessed as being *negligible*.

However, a range of construction mitigation measures have been proposed to ensure that off-site impacts are maintained at a level that would not give rise to complaints, and representative of effective and proper dust control. It is recommended that these are incorporated into a dust action plan as part of the Construction Environmental Management Plan (CEMP).

## 7.2. Operational Phase Air Quality Impacts

The operational phase air quality assessment has been performed using a dispersion modelling study, conducted in general accordance with Environment Protection Authority (2016) Ambient Air Quality Assessment<sup>7</sup> guidelines.

The impact assessment has used technical specifications provided by the proponent for the open cycle GE LM6000 Sprint® gas turbines. The primary focus is the assessment of emissions from the operation of the 6 turbines operating on natural gas as a peaking plant. In the event that the gas supply is unexpectedly interrupted, the turbines are specified so that they are able to operate using diesel as the fuel, and this AQIA has considered those emissions also.

The dispersion modelling has been performed using the CSIRO TAPM and the USEPA AERMOD models, and using multiple year meteorological data, validated against meteorological data measured by the Australian Bureau of Meteorology automatic weather stations at RAAF Edinburgh and Outer Harbour. Overall, **Appendix A** shows that the site-specific meteorological data used in this air quality impact assessment validates well.

To understand the existing conditions at the site, measured air pollutant concentration data measured by the Environment Protection Authority at Elizabeth Downs, Adelaide Northfield and Netley have been used. The measured data and the methodology used to use that data in the air quality impact assessment has been documented in **Appendix B**.

The emission estimations for the six turbines operating concurrently with (a) gas and (b) diesel has been assessed at various operating loads are outlined in **Appendix C**, and are discussed in **Section 4.2**. Further to this, the short-term emissions associated with start-up and shut-down have also been assessed, as the six turbines simultaneously warming through the start-up cycle to the point at which peak emission rates are achieved has also been assessed.

The emission estimations of the above, considers potential emissions of:

- carbon monoxide (CO);
- oxides of nitrogen (NO<sub>x</sub> as NO<sub>2</sub>)
- particulate matter (PM<sub>2.5</sub>)
- sulphur dioxide (SO<sub>2</sub>)
- hazardous air pollutants, assessed as formaldehyde (CH<sub>2</sub>O),

The above pollutants have been assessed for the six (6) turbines operating concurrently using:

- natural gas
- diesel

The emissions have been assessed for operations at:

- normal operating load (100%)

- normal operating load (75%)
- normal operating load (50%) normal operating load (25%)
- start up (idling to normal operating loads).

The predicted impacts have been predicted at 51 discrete receptor locations, as well as at a series of 25 m uniform receptors across the modelling domain which covers an area of 20 km by 20 km.

The results of the dispersion modelling assessment and have been presented as:

- Incremental impacts – relating to the concentrations predicted as a result of the operation of the power station in isolation.
- Cumulative impacts – relating to the concentrations predicted as a result of the operation of the power station plus the background air quality concentrations discussed in **Section 3.3**.

The results of the dispersion modelling, performed using a meteorological period from January-December 2015 are presented in **Appendix E** and summarised in **Section 6.2**.

### 7.2.1. Operating on Gas

**Table 20** presents a summary of the assumed background, maximum increment (of any receptor at any load operating on gas), and presents those values as a percentage of the standards applied to this AQIA (**Table 1**).

**Table 20 Summary of impacts (gas) and comparison against Air EPP**

Pollutant (Gas)	Units / Ave	Back-ground	Maximum Increment	Air EPP	% of Air EPP Standard		
					Back-ground	Maximum Increment	Cumulative
CO	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	40	37.47	31,240	0.13%	0.12%	0.25%
	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	50	14.8	11,120	0.45%	0.13%	0.58%
NO <sub>x</sub> as NO <sub>2</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	20.5	61.49	250	8.20%	24.60%	32.80%
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	8.2	0.53	60	13.67%	0.88%	14.55%
PM <sub>10</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	15.7	1.98	50	31.40%	3.96%	35.36%
PM <sub>2.5</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	10.4	1.98	25	41.60%	7.92%	49.52%
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	7.3	0.08	8	91.25%	1.00%	92.25%
SO <sub>2</sub>	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	28.6	9.83	570	5.02%	1.72%	6.74%
	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	5.8	1.53	230	2.52%	0.67%	3.19%
	$\mu\text{g}\cdot\text{m}^{-3}$ annual	0.2	0.08	60	0.33%	0.13%	0.47%
CH <sub>2</sub> O	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	0	2.25	n/a	n/a	n/a	n/a
	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	0	4.09	44	0.00%	9.30%	9.30%

**Note:** Exceedence of the relevant criterion is highlighted in **bold red text**

<sup>7</sup> [http://www.epa.sa.gov.au/environmental\\_info/air\\_quality/assistance\\_and\\_advice](http://www.epa.sa.gov.au/environmental_info/air_quality/assistance_and_advice)

**Table 20** demonstrates that none of the discrete or cumulative impacts exceed the Air EPP standards. The maximum *incremental* impact may be seen to be 1-hour NO<sub>x</sub> as NO<sub>2</sub>, which is estimated to represent 24.6% of the 250 µg·m<sup>-3</sup> 1-hour standard. It is noted that this assessment has assumed a conservative 100% conversion from NO<sub>x</sub> to NO<sub>2</sub>, and as such the above evaluation may be seen as being highly conservative.

The most significant *cumulative* impacts (expressed as a fractions of the Air EPP standard) may be seen to be associated with the annual average PM<sub>2.5</sub> standard, but it may be seen that these are significantly driven by high background contributions with the associated increment being only 1% of the Air EPP standard.

### 7.2.2. Operating on Diesel

**Table 21** presents a summary of the assumed background, maximum increment (of any receptor at any load operating on diesel), and presents those values as a percentage of the Air EPP standard (or standard applied to this AQIA).

**Table 21 Summary of impacts (diesel) and comparison against Air EPP**

Pollutant (Diesel)	Units / Ave	Back-ground	Maximum Increment	Air EPP	% of Air EPP Standard		
					Back-ground	Maximum Increment	Cumulative
CO	µg·m <sup>-3</sup> 1-hour	40	34.27	31,240	0.13%	0.11%	0.24%
	µg·m <sup>-3</sup> 8-hour	50	14.46	11,120	0.45%	0.13%	0.58%
NO <sub>x</sub> as NO <sub>2</sub>	µg·m <sup>-3</sup> 1-hour	20.5	191.47	250	8.20%	76.59%	84.79%
	µg·m <sup>-3</sup> annual	8.2	1.74	60	13.67%	2.90%	16.57%
PM <sub>10</sub>	µg·m <sup>-3</sup> 24-hour	15.7	2.17	50	31.40%	4.34%	35.74%
PM <sub>2.5</sub>	µg·m <sup>-3</sup> 24-hour	10.4	2.17	25	41.60%	8.68%	50.28%
	µg·m <sup>-3</sup> annual	7.3	0.09	8	91.25%	1.13%	92.38%
SO <sub>2</sub>	µg·m <sup>-3</sup> 1-hour	28.6	0.86	570	5.02%	0.15%	5.17%
	µg·m <sup>-3</sup> 24-hour	5.8	0.16	230	2.52%	0.07%	2.59%
	µg·m <sup>-3</sup> annual	0.2	0.01	60	0.33%	0.02%	0.35%
CH <sub>2</sub> O	µg·m <sup>-3</sup> 1-hour	0	0.12	n/a	n/a	n/a	n/a
	µg·m <sup>-3</sup> 3-min	0	0.21	44	0.00%	0.48%	0.48%

**Note:** Exceedence of the relevant criterion is highlighted in **bold red text**

**Table 21** demonstrates that none of the discrete or cumulative impacts exceed the Air EPP standards. The maximum *incremental* impact may be seen to be 1-hour NO<sub>x</sub> as NO<sub>2</sub>, at 76.6% of the 250 µg·m<sup>-3</sup> 1-hour standard. As noted above, this assessment has assumed a conservative 100% conversion from NO<sub>x</sub> to NO<sub>2</sub>, and as such the above evaluation may be seen as being highly conservative.

The most significant *cumulative* impacts (as fractions of the Air EPP standard) may be seen to be associated with the 1-hour NO<sub>x</sub> as NO<sub>2</sub>, and the annual average PM<sub>2.5</sub> standards, but none are predicted to exceed the Air EPP standards.

### 7.2.3. Start Up Emissions

The conservative assessment of start-up impacts assumes that the maximum peak in emissions, relative to normal operations measured at the comparable Bairnsdale Power Station is applied to the entire 10-minute start-up cycle. It further assumes that 100% of NO<sub>x</sub> is emitted as NO<sub>2</sub>, which is highly conservative.

The start-up emissions are not predicted to exceed the Air EPP standards.

## 7.3. Conclusions

Based upon the information and assumptions presented in this AQIA, it is concluded that construction dust emissions may be adequately controlled through the application of a range of suitable construction management practices, and that these should be documented within a Construction Environmental Management Plan (CEMP).

The potential impacts from the operation of the proposed power station have been assessed using a referenced dispersion modelling assessment, using meteorological data as requested by the EPA, representative background monitoring and using emission rates derived directly from Alinta Energy. Based upon the assumptions presented in the AQIA it is predicted that the operation of the power station on either gas or mineral diesel will not result in a breach of the standards prescribed in the Air EPP.

Notwithstanding the foregoing assessment, it is recommended that a suitable campaign of compliance monitoring should be implemented to the satisfaction of the EPA. It is considered that the demonstration that the engines are capable of being operated as set out in this AQIA is of critical importance, and that a program of emissions testing with the engines operating on gas and diesel and at various loads should be implemented as a condition of approval.

Whilst the AQIA predicts that the air quality risks associated with operation at full capacity (300 MW) are within acceptable limits, it is considered that the environmental risks are further managed by the proposed staged development. Implementing the recommended program of compliance emissions monitoring during the initial stage (150 MW installed capacity) would provide the EPA with increased assurance that the proposed plant is able to achieve its performance objectives prior to operating the second stage (300 MW installed capacity).

In light of the above, and in consideration of the proposed verification studies, it is considered to be reasonable to conclude that the proposed construction and operation of the Project should not be refused on grounds of air quality.

Page left intentionally blank



---

## 8. REFERENCES

Environment Protection Authority (2016) Ambient Air Quality Assessment (EPA 2016)

*Environment Protection (Air Quality) Policy 2016* (Air EPP)

Environment Protection Authority (2016) Ambient Air Quality Assessment (EPA, 2016)

GE Energy (2008) *LM6000-50/60 Hz Gas Turbine Generator Set Product Specification* (GE Energy 2008),

Institute of Air Quality Management (2014) *Guidance on the Assessment of Dust from Demolition and Construction* (IAQM 2014)

US EPA (1995) *Compilation of Air Pollutant Emission Factors AP-42, Volume 1, Chapter 3: Stationary Internal Combustion Sources (fifth edition)* (USEPA 1995)

Page left intentionally blank

## APPENDIX A

### METEOROLOGY

As discussed in **Section 3.4** a meteorological modelling exercise has been performed to characterise the meteorology of the Project site in the absence of site specific measurements. The meteorological monitoring has been based on measurements taken at a number of surrounding automatic weather stations (AWS) operated by the Bureau of Meteorology (BoM). A summary of the relevant monitoring sites is provided in **Table A-1**.


**Table A-1 Details of the Meteorological Monitoring Surrounding the Project Site**

Site Name	Approximate Location (Latitude, Longitude)	
	°S	°E
Edinburgh RAAF – Station # 023083	34.71	138.62
Outer Harbour – Station # 023052	34.73	138.47

Meteorological conditions at Edinburgh RAAF AWS have been examined to determine a ‘typical’ or representative dataset for use in dispersion modelling.

Annual wind roses for the most recent years of data measured at Edinburgh RAAF AWS over the period from 2012 to 2016 are presented in **Figure A-1**.

Figure A-1 Annual wind roses 2012 to 2016, Edinburgh RAAF AWS




Source: Northstar Air Quality

The wind roses indicate that from 2012 to 2016, winds at Edinburgh RAAF AWS show a predominant southwesterly wind direction with a north-easterly and south-easterly components also evident. The majority of wind speeds experienced at the Edinburgh RAAF AWS between 2012 and 2016 are generally in the range 1.5 metres per second (m·s<sup>-1</sup>) to 5.5 m·s<sup>-1</sup> with the highest wind speeds (greater than 8 m·s<sup>-1</sup>) occurring from a south easterly direction. Winds of this speed are rare and occur during 1.1% of the observed hours during the years. Calm winds (<0.5 m·s<sup>-1</sup>) occur for less than 3.7% of hours across the years.


Presented in **Figure A-2** is the long-term wind rose for the 2012 to 2016 period and the annual wind speed distribution for Edinburgh RAAF AWS.

Figure A-2 Long-term wind rose (2012 to 2016), Edinburgh RAAF AWS



Source: Northstar Air Quality

Figure A-3 Annual wind speed distribution Edinburgh RAAF AWS



Source: Northstar Air Quality

## Meteorological Processing

The BoM data adequately covers the issues of data quality assurance, however it is limited by its location compared to the Project site. To address these uncertainties, a multi-phased assessment of the meteorology data has been performed.

In absence of any measured onsite meteorological data, site representative meteorological data for this Project was generated using the TAPM meteorological model (refer **Section 4.2**).

Meteorological modelling using The Air Pollution Model (TAPM, v 4.0.5) has been performed to predict the meteorological parameters required for AERMOD. TAPM, developed by the Commonwealth Scientific and Industrial Research Organisation (CSIRO) is a prognostic model which may be used to predict three-dimensional meteorological data and air pollution concentrations.

TAPM predicts wind speed and direction, temperature, pressure, water vapour, cloud, rain water and turbulence. The program allows the user to generate synthetic observations by referencing databases (covering terrain, vegetation and soil type, sea surface temperature and synoptic scale meteorological analyses) which are subsequently used in the model input to generate site-specific hourly meteorological observations at user-defined levels within the atmosphere.


The parameters used in TAPM modelling are presented in **Table A-2**.

**Table A-2 Meteorological Parameters used for this Study**

TAPM v 4.0.5	
Modelling period	1 January 2009 to 31 December 2009
Centre of analysis	280,713 mE, 6179,316 mN (UTM Coordinates)
Number of grid points	70 × 70 × 25
Number of grids (spacing)	4 (20 km, 10 km, 3 km, 1 km)
Terrain	AUSLIG 9 second DEM
Data assimilation	None

A comparison of the TAPM generated meteorological data, and that observed at the Edinburgh RAAF AWS is presented in **Figure A-4**. These data generally compare well which provides confidence that the meteorological conditions modelled as part of this assessment are appropriate.

Figure A-4 Modelled and observed meteorological data –2009, 2012-2016




Source: Northstar Air Quality

The following provides a summary of the modelled meteorological dataset. Given the nature of the pollutant emission sources at the Project site, detailed discussion of the humidity, evaporation, cloud cover, katabatic air drainage and air recirculation potential of the Project site has not been provided. Details of the predictions of wind speed and direction, mixing height and temperature at the Project site are provided below.

Diurnal variations in maximum and average mixing heights predicted by TAPM at the Project site during 2009 period are illustrated in **Figure A-5**.

As expected, an increase in mixing height during the morning is apparent, arising due to the onset of vertical mixing following sunrise. Maximum mixing heights occur in the mid to late afternoon, due to the dissipation of ground based temperature inversions and growth of the convective mixing layer.

**Figure A-5 Predicted mixing height – Project site 2009**




Source: Northstar Air Quality

The modelled temperature variations predicted at the Project site during 2009 are presented in **Figure A-6**. The maximum temperature of 42°C was predicted on 9 January 2009 and the minimum temperature of 5°C was predicted on 7 July 2009.




Figure A-6 Predicted temperature – Project site 2009



Source: Northstar Air Quality

The modelled wind speed and direction at the Project site during 2009 are presented in Figure A-7.

Figure A-7 Predicted wind speed and direction – Project site 2009



Source: Northstar Air Quality

## APPENDIX B

### BACKGROUND AIR QUALITY

Background air quality assumptions are introduced in **Section 3.3** of the AQIA. The data presented below presents a summary of the measured air quality concentrations at Elizabeth Downs air quality monitoring station (AQMS) and at Netley AQMS during 2015. The data has been accessed and the summary statistics derived from the Data SA website, maintained by the SA Government.

Elizabeth Downs AQMS has been used to represent background air quality at the Project site as it is the closest monitoring station. The EPA raised questions about the applicability of particulate data at Elizabeth Downs AQMS, and recommended that Netley AQMS was used instead to characterise background particulate concentrations.

The data accessed from the Data SA web resource<sup>8</sup> was downloaded and is summarised in **Table B-1** below:

---

<sup>8</sup> <https://data.sa.gov.au/>

**Table B-1 Summary background air quality data (Elizabeth Downs & Netley AQMS, 2015)**

Pollutant:	PM <sub>10</sub>		PM <sub>2.5</sub>	NO	NO <sub>2</sub>	NO <sub>x</sub>	CO	
Average Period	24-h all	24-h Air EPP <sup>D</sup>	24-h all	1-h	1-h	1-h	1-h	8-h
AQMS	Netley	Netley	Netley	Elizabeth Downs			Elizabeth Downs	
Units <sup>A</sup>	µg.m <sup>-3</sup> <sub>TEOM</sub>	µg.m <sup>-3</sup> <sub>TEOM</sub>	µg.m <sup>-3</sup> <sub>TEOM</sub>	ppm	ppm	ppm	ppm	ppm
Mean	15.7	15.5	7.3	0.001	0.004	0.005	0.022	0.022
Std Deviation	7.5	6.1	2.5	0.002	0.004	0.006	0.072	0.051
Skew <sup>B</sup>	4.2	1.0	1.2	8.5	2.1	3.3	16.4	9.7
Kurtosis <sup>C</sup>	41.2	1.2	2.1	112.3	5.2	16.8	411.6	137.7
Minimum	1.4	1.4	1.8	-0.001	-0.001	-0.001	-0.040	-0.040
Percentile 1	5.4	5.4	3.4	0.000	0.000	0.000	-0.020	-0.020
Percentile 2	6.2	6.2	3.7	0.000	0.000	0.000	-0.020	-0.010
Percentile 3	6.8	6.8	3.8	0.000	0.000	0.000	-0.020	-0.010
Percentile 4	7.4	7.4	3.9	0.000	0.000	0.000	-0.010	-0.010
Percentile 5	7.8	7.7	4.0	0.000	0.000	0.000	-0.010	-0.010
Percentile 10	9.2	9.2	4.6	0.000	0.001	0.001	0.000	0.000
Percentile 25	11.1	11.1	5.5	0.000	0.001	0.002	0.000	0.000
Percentile 50	14.8	14.8	6.9	0.000	0.003	0.003	0.010	0.010
Percentile 75	18.2	18.1	8.4	0.001	0.005	0.006	0.020	0.020
Percentile 90	23.8	23.7	10.4	0.002	0.010	0.011	0.040	0.050
Percentile 95	28.1	28.0	11.8	0.003	0.013	0.016	0.080	0.080
Percentile 96	29.2	28.8	12.3	0.004	0.014	0.017	0.100	0.090
Percentile 97	30.2	30.1	13.5	0.005	0.016	0.020	0.130	0.110
Percentile 98	31.2	30.6	15.1	0.007	0.017	0.023	0.160	0.130
Percentile 99	35.1	34.8	15.9	0.011	0.020	0.030	0.240	0.170
Maximum	98.7	39.6	17.1	0.056	0.028	0.079	2.580	0.980
Count	365	364	345	8,337	8,337	8,337	8,528	8,561
Capture	100%	99.7%	95%	95%	95%	95%	97%	98%

Note: A. All data is presented in the stated units except skew and kurtosis, which are dimensionless, count which is a numerical value and capture which is expressed as a percentage.

B. Skew is a dimensionless metric describing the distribution of the measured values in the range to a normal distribution.

C. Kurtosis is a dimensionless metric describing the 'peakedness' of the distribution to a normal distribution.

D. Data presented excluding the maximum measured value of 98.7 µg·m<sup>-3</sup>.


The data accessed for Elizabeth Downs AQMS and Netley AQMS did not contain measured SO<sub>2</sub> data.

## Particulates (as PM<sub>10</sub>)

The data for PM<sub>10</sub> measured at Netley AQMS during 2015 is presented as measured 24-hour average data. It may be seen that the 24-hour PM<sub>10</sub> concentration exceeds the Air EPP 24-hour criterion of 50 µg·m<sup>-3</sup> on one occasion during 2015.

The time-series plot for the measured 24-hour PM<sub>10</sub> concentration is illustrated in **Figure B-1**.

**Figure B-1** Time series plot of measured 24-hour PM<sub>10</sub> (Netley AQMS 2015)



**Source:** Northstar Air Quality


The single exceedences of the Air EPP 24-hour PM<sub>10</sub> criterion of 50 µg·m<sup>-3</sup> is indicated as 98.7 µg·m<sup>-3</sup> on 4 May 2015. To use this data meaningfully, the period of exceedence of the Air EPP standard has been removed and the resultant dataset recalculated (listed in the table as “24-h Air EPP”).

Consequentially, the maximum background 24-hour PM<sub>10</sub> concentration value for 2015 is 39.6 µg·m<sup>-3</sup> with an annual average PM<sub>10</sub> concentration of 15.7 µg·m<sup>-3</sup>. The 90<sup>th</sup> percentile of 24-hour PM<sub>10</sub> measured at Netley AQMS is 23.8 µg·m<sup>-3</sup>, including the Air EPP exceedence value in that calculation.

## Particulates (as PM<sub>2.5</sub>)

The corresponding background PM<sub>2.5</sub> measurements at Netley AQMS in 2015 are presented in **Figure B-2** below:

**Figure B-2** Time series plot of measured 24-hour PM<sub>2.5</sub> (Netley AQMS 2015)



**Source:** Northstar Air Quality

There are no exceedences of the Air EPP 24-hour PM<sub>2.5</sub> criterion of 25  $\mu\text{g}\cdot\text{m}^{-3}$  measured at Netley AQMS in 2015.


The maximum background 24-hour PM<sub>2.5</sub> concentration value for 2015 is 17.1  $\mu\text{g}\cdot\text{m}^{-3}$  with an annual average PM<sub>10</sub> concentration of 7.3  $\mu\text{g}\cdot\text{m}^{-3}$ .

The 90<sup>th</sup> percentile of 24-hour PM<sub>2.5</sub> measured at Netley AQMS is 10.4  $\mu\text{g}\cdot\text{m}^{-3}$ .

## Nitrogen Dioxide

The time series plot of the measured NO<sub>2</sub> and NO<sub>x</sub> is shown in **Figure B-3** below:

**Figure B-3** Time series plot of measured 1-hour NO<sub>2</sub> and NO<sub>x</sub> (Elizabeth Downs AQMS 2015)



**Source:** Northstar Air Quality


The maximum 1-hour NO<sub>2</sub> concentration measured at Elizabeth Downs over the 2015 monitoring period was 0.028 ppm (57.4  $\mu\text{g}\cdot\text{m}^{-3}$ ), measured on 23 April 2015 and the 90<sup>th</sup> percentile value was 0.010 ppm (20.5  $\mu\text{g}\cdot\text{m}^{-3}$ ).

The annual average NO<sub>2</sub> concentration was measured as 0.004 ppm (8.2  $\mu\text{g}\cdot\text{m}^{-3}$ ).

## Carbon Monoxide

The time series plot of the measured 1-hour and 8-hour CO concentrations is shown in **Figure B-4** below:

**Figure B-4 Time series plot of measured 1-hour and 8-hour CO (Elizabeth Downs AQMS 2015)**



**Source:** Northstar Air Quality

The maximum 1-hour CO concentration measured at Elizabeth Downs over the 2015 monitoring period was 2.58 ppm (3.23 mg·m<sup>-3</sup>), measured on 3 January 2015 and the corresponding maximum rolling 8-hour average was measured as 0.98 ppm (1.23 mg·m<sup>-3</sup>) measured on 4 January 2015. The corresponding 90<sup>th</sup> percentile 1-hour and 8-hour average values were 0.040 ppm (0.05 mg·m<sup>-3</sup>) and 0.050 ppm (0.06 mg·m<sup>-3</sup>) respectively.

## Sulphur Dioxide

Sulphur dioxide (SO<sub>2</sub>) monitoring is performed by the EPA in SA at the following AQMS:

- Adelaide – Northfield (NOR01)
- Adelaide – North Haven (NHV01)
- Spencer – Port Pirie Oliver Street (PTP01)

The National Environment Protection Council (NEPC) annual report<sup>9</sup> makes the following comments regarding SO<sub>2</sub> in SA (2014-15):

<sup>9</sup> <http://www.nepc.gov.au/system/files/resources/e3da1ed8-68f0-48e5-937a-5de0045feb62/files/nepc-annual-report-2014-15.pdf>

*“In Port Pirie, exceedences of the 1-hour SO<sub>2</sub> standard were recorded on 68 occasions on 38 different days. There were 4 exceedences of the 24-hr standard for SO<sub>2</sub>. Therefore, the 1-hour and 24-hour SO<sub>2</sub> standards and goals were not met at Oliver Street [Port Pirie] station. However there was not an exceedence of the 1-year standard for SO<sub>2</sub>.”*

*“For SO<sub>2</sub> the 1-hour, 1-day and 1-year standards and goals were met at the Adelaide metropolitan stations. The 1-year standard and goal was met at Port Pirie Oliver Street station, however there were 38 exceedences of the 1-hour and 4 exceedences of the 1-day standards at Oliver Street station so the 1-hour and 1-day goals were not achieved.”*

In order to represent background SO<sub>2</sub> concentrations at the Project site, the data from Adelaide Northfield has been accessed. For the year 2015 the following maximum concentration values were determined:

- 1-hour maximum: 28.6 µg·m<sup>-3</sup>
- 1-day maximum: 5.8 µg·m<sup>-3</sup>
- Annual average: 0.2 µg·m<sup>-3</sup>

In lieu of more site-specific measurements, the assumption that background SO<sub>2</sub> is comparable to that measured at Northfield is considered to be highly conservative.



Page left intentionally blank

## APPENDIX C

### EMISSIONS ESTIMATION

Presented below is a breakdown of the emissions data used in the AQIA for operations using natural gas and diesel.

The estimated emission rates for oxides of nitrogen ( $\text{NO}_x$ ), carbon monoxide (CO), sulphur dioxide ( $\text{SO}_2$ ) and particulate matter ( $\text{PM}_{2.5}$ ) for natural gas are presented in **Table C-1**. The corresponding estimations for formaldehyde as derived from emission estimates published in US EPA *AP-42 Volume 1, Chapter 3, Section 3.1* are presented in **Table C-2**. The graphical representation of emission rates by load are presented in **Figure C-1**.

The estimated emission rates for oxides of nitrogen ( $\text{NO}_x$ ), carbon monoxide (CO), sulphur dioxide ( $\text{SO}_2$ ) and particulate matter ( $\text{PM}_{2.5}$ ) for diesel are presented in **Table C-3**. The corresponding estimations for formaldehyde as derived from emission estimates published in US EPA *AP-42 Volume 1, Chapter 3, Section 3.1* are presented in **Table C-4**. The graphical representation of emission rates by load are presented in **Figure C-2**.

The estimated gas discharge rate and temperature profile variance with operating load is presented in **Figure C-3**.

**Table C-1 Estimated emission rates (NO<sub>x</sub>, CO, SO<sub>2</sub>, PM<sub>2.5</sub>) with load (%) on gas**


Fuel	Units	Load (%)			
		100%	75%	50%	25%
Stack temperature	degrees C	395	390	434	421
NO <sub>x</sub> (as NO <sub>2</sub> )	mg.Nm <sup>-3</sup> ref O <sub>2</sub>	51.2	51.2	51.2	51.2
CO	mg.Nm <sup>-3</sup> ref O <sub>2</sub>	31.2	31.2	31.2	31.2
NO <sub>x</sub> (as NO <sub>2</sub> )	kg.hr <sup>-1</sup>	12.38	10.09	7.87	6.6
SO <sub>2</sub>	kg.hr <sup>-1</sup>	1.98	1.62	1.27	1.06
Discharge rate	Nm <sup>3</sup> .hr <sup>-1</sup> ref O <sub>2</sub>	241796.9	197070.3	153710.9	128906.3
Stack diameter	m	3.50	3.50	3.50	3.50
Velocity	m.s <sup>-1</sup>	17.08	13.82	11.49	9.45
NO <sub>x</sub> (as NO <sub>2</sub> )	g.s <sup>-1</sup>	3.4389	2.8028	2.1861	1.8333
CO	g.s <sup>-1</sup>	2.0956	1.7079	1.3322	1.1172
SO <sub>2</sub>	g.s <sup>-1</sup>	0.5496	0.4488	0.3524	0.2935
PM <sub>2.5</sub>	g.s <sup>-1</sup>	0.3780	0.3780	0.3780	0.3780

**Note:** PM<sub>2.5</sub> emissions are derived from a constant maximum emission rate of 3 pounds (lb) per hour. It is reasonably assumed that 100% of particulate is <1µm, and represented as PM<sub>2.5</sub>.

**Table C-2 Estimated emission rates (Formaldehyde) with load (%) on gas**

Fuel	Units	Load (%)			
		100%	75%	50%	25%
Stack temperature	degrees C	395	390	434	421
Formaldehyde	lb·MMscf <sup>-1</sup> <sub>(fuel)</sub>	0.723	3.18	3.18	3.18
Formaldehyde	g·m <sup>-3</sup> <sub>(fuel, 60°F)</sub>	0.011	0.048	0.048	0.048
Fuel consumption	Nm <sup>3</sup> ·hr <sup>-1</sup>	11,215	8,904	6,904	5,109
Discharge rate	Nm <sup>3</sup> ·hr <sup>-1</sup> ref O <sub>2</sub>	241796.9	197070.3	153710.9	128906.3
Stack diameter	m	3.50	3.50	3.50	3.50
Velocity	m·s <sup>-1</sup>	17.08	13.82	11.49	9.45
Formaldehyde	g·s <sup>-1</sup>	0.034	0.119	0.092	0.068

Figure C-1 Estimated emission rates (NO<sub>x</sub>, CO, SO<sub>2</sub>, PM<sub>2.5</sub>, CH<sub>2</sub>O) with load (%) on gas



Source: Northstar Air Quality

**Table C-3 Estimated emission rates (NO<sub>x</sub>, CO, SO<sub>2</sub>, PM<sub>2.5</sub>) with load (%) on diesel**


Fuel	Units	Load (%)			
		100%	75%	50%	25%
Stack temperature	degrees C	399	413	437	423
NO <sub>x</sub> (as NO <sub>2</sub> )	mg.Nm <sup>-3</sup> ref O <sub>2</sub>	174.3	174.2	174.3	174.2
CO	mg.Nm <sup>-3</sup> ref O <sub>2</sub>	31.2	31.2	31.2	31.2
NO <sub>x</sub> (as NO <sub>2</sub> )	kg.h <sup>-1</sup>	37.68	31.08	28.49	21.38
SO <sub>2</sub>	kg.h <sup>-1</sup>	0.17	0.14	0.13	0.10
Discharge rate	Nm <sup>3</sup> .hr <sup>-1</sup> ref O <sub>2</sub>	216179.0	178415.6	163453.8	122732.5
Stack diameter	m	3.50	3.50	3.50	3.50
Velocity	m.s <sup>-1</sup>	15.36	12.95	12.40	9.03
NO <sub>x</sub> (as NO <sub>2</sub> )	g.s <sup>-1</sup>	10.4667	8.6333	7.9139	5.9389
CO	g.s <sup>-1</sup>	1.8736	1.5463	1.4166	1.0637
SO <sub>2</sub>	g.s <sup>-1</sup>	0.0468	0.0386	0.0361	0.0271
PM <sub>2.5</sub>	g.s <sup>-1</sup>	0.3780	0.3780	0.3780	0.3780

**Note:** PM<sub>2.5</sub> emissions are derived from a constant maximum emission rate of 3 pounds (lb) per hour. It is reasonably assumed that 100% of particulate is <1µm, and represented as PM<sub>2.5</sub>.

**Table C-4 Estimated emission rates (formaldehyde) with load (%) on diesel**

Fuel	Units	Load (%)			
		100%	75%	50%	25%
Stack temperature	degrees C	399	413	437	423
Formaldehyde	lb·1000 gal <sup>-1</sup> <sub>(fuel)</sub>	0.039	0.034	0.034	0.034
Formaldehyde	g·kg <sup>-1</sup> <sub>(fuel, 60°F)</sub>	0.005639	0.00491	0.00491	0.00491
Fuel consumption	kg·hr <sup>-1</sup> <sub>(fuel)</sub>	8,473	6,891	5,708	4,168
Discharge rate	Nm <sup>3</sup> ·hr <sup>-1</sup> ref O <sub>2</sub>	216179.0	178415.6	163453.8	122732.5
Stack diameter	m	3.50	3.50	3.50	3.50
Velocity	m·s <sup>-1</sup>	15.36	12.95	12.40	9.03
Formaldehyde	g·s <sup>-1</sup>	0.013	0.009	0.008	0.006


Figure C-2 Estimated emission rates (NO<sub>x</sub>, CO, SO<sub>2</sub>, PM<sub>2.5</sub>, CH<sub>2</sub>O) with load (%) on diesel



Source: Northstar Air Quality



Figure C-3 Estimated discharge rates and temperature with load (%)



Source: Northstar Air Quality

## APPENDIX D

### CONSTRUCTION PHASE RISK ASSESSMENT METHODOLOGY

Provided below is a summary of the risk assessment methodology used in this assessment. It is based upon IAQM (2016) *Guidance on the assessment of dust from demolition and construction* (version 1.1), and adapted by Northstar Air Quality.

#### Adaptions to the Published Methodology Made by Northstar Air Quality

The adaptions made by Northstar Air Quality from the IAQM published methodology are:

- **PM<sub>10</sub> criterion:** an amended criterion representing the annual average PM<sub>10</sub> criterion relevant to Australia rather than the UK;
- **Nomenclature:** a change in nomenclature from “receptor sensitivity” to “land use value” to avoid misinterpretation of values attributed to “receptor sensitivity” and “sensitivity of the area” which may be assessed as having different values;
- **Construction traffic:** the separation of construction vehicle movements as a discrete risk assessment profile from those associated with the ‘on-site’ activities of demolition, earthworks and construction. The IAQM methodology considers five risk profiles of: “demolition”, “earthworks”, “construction” and “trackout”. The adaption by Northstar Air Quality introduces a fifth risk assessment profile of “construction traffic” to the existing four risk profiles; and,
- **Tables:** minor adjustments in the visualisation of some tables.

#### Step 1 – Screening Based on Separation Distance

The Step 1 screening criteria provided by the IAQM guidance suggests screening out any assessment of impacts from construction activities where sensitive receptors are located:

- more than 350 m from the boundary of the site;
- more than 50 m from the route used by construction vehicles on public roads; and,
- more than 500 m from the site entrance.

This step is noted as having deliberately been chosen to be conservative, and would require assessments for most developments.

#### Step 2 – Risk from Construction Activities

Step 2 of the assessment provides “dust emissions magnitudes” for each of the dust generating activities; demolition, earthworks, construction, and track-out (the movement of site material onto public roads by vehicles) and construction traffic.

The magnitudes are: Large; Medium; or Small, with suggested definitions for each category as follows:

**Table D-1 Dust Emission Magnitude Activities**

Activity	Large	Medium	Small
<b>Demolition</b>			
- total building volume*	• >50,000 m <sup>3</sup>	• 20,000 m <sup>3</sup> to 50,000 m <sup>3</sup>	• <20,000 m <sup>3</sup>
- demolition height	• > 20m AGL	• 10 m and 20 m AGL	• <10 m AGL
- onsite crushing	• yes	• no	• no
- onsite screening	• yes	• no	• no
- demolition of materials with high dust potential	• yes	• yes	• no
- demolition timing	• any time of the year	• any time of the year	• wet months only
<b>Earthworks</b>			
- total area	• >10,000 m <sup>2</sup>	• 2,500 m <sup>2</sup> to 10,000 m <sup>2</sup>	• <2,500 m <sup>2</sup>
- soil types	• potentially dusty soil type (e.g., clay, which would be prone to suspension when dry due to small particle size)	• moderately dusty soil type (e.g., silt),	• soil type with large grain size (e.g., sand)
- heavy earth moving vehicles	• >10 heavy earth moving vehicles active at any time	• 5 to 10 heavy earth moving vehicles active at any one time	• <5 heavy earth moving vehicles active at any one time
- formation of bunds	• >8m AGL	• 4m to 8m AGL	• <4m AGL
- material moved	• >100,000 t	• 20,000 t to 100,000 t	• <20,000 t
- earthworks timing	• any time of the year	• any time of the year	• wet months only
<b>Construction</b>			
- total building volume	• 100,000 m <sup>3</sup>	• 25,000 m <sup>3</sup> to 100,000 m <sup>3</sup>	• <25,000 m <sup>3</sup>
- piling	• yes	• yes	• no
- concrete batching	• yes	• yes	• no
- sandblasting	• yes	• no	• no
- materials	• concrete	• concrete	• metal cladding or timber
<b>Trackout (within 100 m of construction site entrance)</b>			
- outward heavy vehicles movements per day	• >50	• 10 to 50	• <10
- surface materials	• high potential	• moderate potential	• low potential

Activity	Large	Medium	Small
- unpaved road length	<ul style="list-style-type: none"> <li>&gt;100m</li> </ul>	<ul style="list-style-type: none"> <li>50m to 100m</li> </ul>	<ul style="list-style-type: none"> <li>&lt;50m</li> </ul>
<b>Construction Traffic (from construction site entrance to construction vehicle origin)</b>			
Demolition traffic - total building volume	<ul style="list-style-type: none"> <li>&gt;50,000 m<sup>3</sup></li> </ul>	<ul style="list-style-type: none"> <li>20,000 m<sup>3</sup> to 50,000 m<sup>3</sup></li> </ul>	<ul style="list-style-type: none"> <li>&lt;10,000 m<sup>3</sup></li> </ul>
Earthworks traffic - total area	<ul style="list-style-type: none"> <li>&gt;10,000 m<sup>2</sup></li> </ul>	<ul style="list-style-type: none"> <li>2,500 m<sup>2</sup> to 10,000 m<sup>2</sup></li> </ul>	<ul style="list-style-type: none"> <li>&lt;2,500 m<sup>2</sup></li> </ul>
Earthworks traffic - soil types	<ul style="list-style-type: none"> <li>potentially dusty soil type (e.g., clay, which would be prone to suspension when dry due to small particle size)</li> </ul>	<ul style="list-style-type: none"> <li>moderately dusty soil type (e.g., silt),</li> </ul>	<ul style="list-style-type: none"> <li>soil type with large grain size (e.g., sand)</li> </ul>
Earthworks traffic - material moved	<ul style="list-style-type: none"> <li>&gt;100,000 t</li> </ul>	<ul style="list-style-type: none"> <li>20,000 t to 100,000 t</li> </ul>	<ul style="list-style-type: none"> <li>&lt;20,000 t</li> </ul>
Construction traffic - total building volume	<ul style="list-style-type: none"> <li>100,000 m<sup>3</sup></li> </ul>	<ul style="list-style-type: none"> <li>25,000 m<sup>3</sup> to 100,000 m<sup>3</sup></li> </ul>	<ul style="list-style-type: none"> <li>&lt;25,000 m<sup>3</sup></li> </ul>
Total traffic - heavy vehicles movements per day when compared to existing heavy vehicle traffic	<ul style="list-style-type: none"> <li>&gt;50% of heavy vehicle movement contribution by Project</li> </ul>	<ul style="list-style-type: none"> <li>10% to 50% of heavy vehicle movement contribution by Project</li> </ul>	<ul style="list-style-type: none"> <li>&lt;10% of heavy vehicle movement contribution by Project</li> </ul>

### Step 3 – Sensitivity of the Area

Step 3 of the assessment process requires the sensitivity of the area to be defined. The sensitivity of the area takes into account:

- The specific sensitivities that identified land use values have to dust deposition and human health impacts;
- The proximity and number of those receptors locations;
- In the case of PM<sub>10</sub>, the local background concentration; and
- Other site-specific factors, such as whether there are natural shelters such as trees to reduce the risk of wind-blown dust.

#### Land Use Value

Individual receptor locations may be attributed different land use values based on the land use of the land, and may be classified as having high, medium or low values relative to dust deposition and human health impacts (ecological receptors are not addressed using this approach).

Essentially, land use value is a metric of the level of amenity expectations for that land use.

The IAQM method provides guidance on the land use value with regard to dust soiling and health effects and is shown in the table below. It is noted that user expectations of amenity levels (dust soiling) is dependent on existing deposition levels.

**Table D-2 IAQM Guidance for Categorising Land Use Value**

Value	High Land Use Value	Medium Land Use Value	Low Land Use Value
Health effects	<ul style="list-style-type: none"> <li>• Locations where the public are exposed over a time period relevant to the air quality objective for PM<sub>10</sub> (in the case of the 24-hour objectives, a relevant location would be one where individuals may be exposed for eight hours or more in a day).</li> </ul> <p><i>Examples: Residential properties, hospitals, schools and residential care homes.</i></p>	<ul style="list-style-type: none"> <li>• Locations where the people exposed are workers, and exposure is over a time period relevant to the air quality objective for PM<sub>10</sub> (in the case of the 24-hour objectives, a relevant location would be one where individuals may be exposed for eight hours or more in a day).</li> </ul> <p><i>Examples: Office and shop workers, but would generally not include workers occupationally exposed to PM<sub>10</sub>.</i></p>	<ul style="list-style-type: none"> <li>• Locations where human exposure is transient.</li> </ul> <p><i>Examples: Public footpaths, playing fields, parks and shopping street.</i></p>

Value	High Land Use Value	Medium Land Use Value	Low Land Use Value
Dust soiling	<ul style="list-style-type: none"> <li>Users can reasonably expect a high level of amenity; or</li> <li>The appearance, aesthetics or value of their property would be diminished by soiling, and the people or property would reasonably be expected to be present continuously, or at least regularly for extended periods as part of the normal pattern of use of the land.</li> </ul> <p><i>Examples: Dwellings, museums, medium and long term car parks and car showrooms.</i></p>	<ul style="list-style-type: none"> <li>Users would expect to enjoy a reasonable level of amenity, but would not reasonably expect to enjoy the same level of amenity as in their home; or</li> <li>The appearance, aesthetics or value of their property could be diminished by soiling; or</li> <li>The people or property wouldn't reasonably be expected to be present here continuously or regularly for extended periods as part of the normal pattern of use of the land.</li> </ul> <p><i>Examples: Parks and places of work.</i></p>	<ul style="list-style-type: none"> <li>The enjoyment of amenity would not reasonably be expected; or</li> <li>Property would not reasonably be expected to be diminished in appearance, aesthetics or value by soiling; or</li> <li>There is transient exposure, where the people or property would reasonably be expected to be present only for limited periods of time as part of the normal pattern of use of the land.</li> </ul> <p><i>Examples: Playing fields, farmland (unless commercially-sensitive horticultural), footpaths, short term car parks and roads.</i></p>

### Sensitivity of the Area

The assessed land use value (as described above) is then used to assess the *sensitivity of the area* surrounding the active construction area, taking into account the proximity and number of those receptors, and the local background PM<sub>10</sub> concentration (in the case of potential health impacts) and other site-specific factors.

Additional factors to consider when determining the sensitivity of the area include:

- any history of dust generating activities in the area;
- the likelihood of concurrent dust generating activity on nearby sites;
- any pre-existing screening between the source and the receptors;
- any conclusions drawn from analysing local meteorological data which accurately represent the area; and if relevant, the season during which the works would take place;
- any conclusions drawn from local topography;
- duration of the potential impact, as a receptor may become more sensitive over time; and
- any known specific receptor sensitivities which go beyond the classifications given in the IAQM document

## Sensitivity of the Area - Health Impacts

For high land use values, the method takes the existing background concentrations of PM<sub>10</sub> (as an annual average) experienced in the area of interest into account, and professional judgement may be used to determine alternative sensitivity categories, taking into account the following:

- any history of dust generating activities in the area;
- the likelihood of concurrent dust generating activity on nearby sites;
- any pre-existing screening between the source and the receptors;
- any conclusions drawn from analysing local / seasonal meteorological data;
- any conclusions drawn from local topography;
- duration of the potential impact, as a receptor may become more sensitive over time; and
- any known specific receptor sensitivities which go beyond the classifications given in the IAQM document.

**Tabld D-3 IAQM Guidance for Categorising the Sensitivity of an Area to Dust Health Effects**

Land Use Value	Annual Mean PM <sub>10</sub> Concentration (µg·m <sup>-3</sup> )	Number of Receptors <sup>(a)</sup>	Distance from the Source (m) <sup>(b)</sup>				
			<20	<50	<100	<200	<350
High	>30	>100	High	High	High	Medium	Low
		10-100	High	High	Medium	Low	Low
		1-10	High	Medium	Low	Low	Low
	26 – 30	>100	High	High	Medium	Low	Low
		10-100	High	Medium	Low	Low	Low
		1-10	High	Medium	Low	Low	Low
	22 – 26	>100	High	Medium	Low	Low	Low
		10-100	High	Medium	Low	Low	Low
		1-10	Medium	Low	Low	Low	Low
	≤22	>100	Medium	Low	Low	Low	Low
		10-100	Low	Low	Low	Low	Low
		1-10	Low	Low	Low	Low	Low
Medium	-	>10	High	Medium	Low	Low	Low
	-	1-10	Medium	Low	Low	Low	Low
Low	-	>1	Low	Low	Low	Low	Low

Note: (a) Estimate the total within the stated distance (e.g. the total within 350 m and not the number between 200 and 350 m), noting that only the highest level of area sensitivity from the table needs to be considered. In the case of high sensitivity areas with high occupancy (such as schools or hospitals) approximate the number of people likely to be present. In the case of residential dwellings, just include the number of properties.

(b) With regard to potential 'construction traffic' impacts, the distance criteria of <20m and <50m from the source (roadside) are used (i.e. the first two columns only). Any locations beyond 50m may be screened out of the assessment (as per Step 1) and the corresponding sensitivity is negligible'.

## Sensitivity of the Area - Dust Soiling

The IAQM guidance for assessing the sensitivity of an area to dust soiling is shown in the table below

**Tabl D-4 IAQM Guidance for Categorising the Sensitivity of an Area to Dust Soiling Effects**

Land Use Values	Number of receptors <sup>(a)</sup>	Distance from the source (m) <sup>(b)</sup>			
		<20	<50	<100	<350
High	>100	High	High	Medium	Low
	10-100	High	Medium	Low	Low
	1-10	Medium	Low	Low	Low
Medium	>1	Medium	Low	Low	Low
Low	>1	Low	Low	Low	Low

Note: (a) Estimate the total number of receptors within the stated distance. Only the highest level of area sensitivity from the table needs to be considered.

(b) With regard to potential 'construction traffic' impacts, the distance criteria of <20m and <50m from the source (roadside) are used (i.e. the first two columns only). Any locations beyond 50m may be screened out of the assessment (as per Step 1) and the corresponding sensitivity is negligible'.



## Step 4 - Risk Assessment (Pre-Mitigation)

The matrices shown for each activity determine the risk category with no mitigation applied.

**Table D-5 Risk of dust impacts from earthworks**

Sensitivity of Area	Pre-Mitigated Dust Emission Magnitude ( <b>Earthworks</b> )		
	Large	Medium	Small
High	High Risk	Medium Risk	Low Risk
Medium	Medium Risk	Medium Risk	Low Risk
Low	Low Risk	Low Risk	Negligible

**Table D-6 Risk of dust impacts from construction activities**

Sensitivity of Area	Pre-Mitigated Dust Emission Magnitude ( <b>Construction</b> )		
	Large	Medium	Small
High	High Risk	Medium Risk	Low Risk
Medium	Medium Risk	Medium Risk	Low Risk
Low	Low Risk	Low Risk	Negligible

**Table D-7 Risk of dust impacts from demolition activities**

Sensitivity of Area	Pre-Mitigated Dust Emission Magnitude ( <b>Demolition</b> )		
	Large	Medium	Small
High	High Risk	Medium Risk	Medium Risk
Medium	High Risk	Medium Risk	Low Risk
Low	Medium Risk	Low Risk	Negligible

**Table D-8 Risk of dust impacts from trackout (within 100m of construction site entrance)**

Sensitivity of Area	Pre-Mitigated Dust Emission Magnitude ( <b>Trackout</b> )		
	Large	Medium	Small
High	High Risk	Medium Risk	Low Risk
Medium	Medium Risk	Low Risk	Negligible
Low	Low Risk	Low Risk	Negligible

**Table D-9 Risk of dust impacts from construction traffic (from construction site entrance to origin)**

Sensitivity of Area	Pre-Mitigated Dust Emission Magnitude ( <b>Construction Traffic</b> )		
	Large	Medium	Small
High	High Risk	Medium Risk	Low Risk
Medium	Medium Risk	Low Risk	Negligible
Low	Low Risk	Low Risk	Negligible

## Step 5 – Identify Mitigation

Once the risk categories are determined for each of the relevant activities, site-specific management measures can be identified based on whether the site is a low, medium or high risk site.

The identified mitigation measures are presented as follows:

- **N** = not required (although they may be implemented voluntarily)
- **D** = desirable (to be considered as part of the CEMP, but may be discounted if justification is provided);
- **H** = highly recommended (to be implemented as part of the CEMP, and should only be discounted if site-specific conditions render the requirement invalid or otherwise undesirable).

The table below presents the complete mitigation table, not that assessed as required for any specific project or activity:

**Table D-10 Construction dust mitigation requirements (by risk)**

Identified Mitigation		Unmitigated Risk		
		Low	Medium	High
<b>1 Communications</b>				
1.1	Develop and implement a stakeholder communications plan that includes community engagement before work commences on site.	N	H	H
1.1	Display the name and contact details of person(s) accountable for air quality and dust issues on the site boundary. This may be the environment manager/engineer or the site manager.	H	H	H
1.2	Display the head or regional office contact information.	H	H	H
1.3	Develop and implement a Dust Management Plan (DMP), which may include measures to control other emissions, approved by the relevant regulatory bodies.	D	H	H
<b>2 Site Management</b>				
2.1	Record all dust and air quality complaints, identify cause(s), take appropriate measures to reduce emissions in a timely manner, and record the measures taken.	H	H	H
2.2	Make the complaints log available to the local authority when asked.	H	H	H
2.3	Record any exceptional incidents that cause dust and/or air emissions, either on- or offsite, and the action taken to resolve the situation in the log book.	H	H	H
2.4	Hold regular liaison meetings with other high-risk construction sites within 500 m of the site boundary, to ensure plans are coordinated and dust and particulate matter emissions are minimised. It is important to understand the interactions of the off-site transport/ deliveries which might be using the same strategic road network routes.	N	N	H

Identified Mitigation		Unmitigated Risk		
		Low	Medium	High
<b>3 Monitoring</b>				
3.1	Undertake daily on-site and off-site inspections where receptors (including roads) are nearby, to monitor dust, record inspection results, and make the log available to the local authority when asked. This should include regular dust soiling checks of surfaces such as street furniture, cars and window sills within 100m of site boundary.	D	D	H
3.2	Carry out regular site inspections to monitor compliance with the dust management plan / CEMP, record inspection results, and make an inspection log available to the local authority when asked.	H	H	H
3.3	Increase the frequency of site inspections by the person accountable for air quality and dust issues on site when activities with a high potential to produce dust are being carried out and during prolonged dry or windy conditions.	H	H	H
3.4	Agree dust deposition, dust flux, or real-time continuous monitoring locations with the relevant regulatory bodies. Where possible commence baseline monitoring at least three months before work commences on site or, if it a large site, before work on a phase commences.	N	H	H
<b>4 Preparing and Maintaining the Site</b>				
4.1	Plan site layout so that machinery and dust causing activities are located away from receptors, as far as is possible.	H	H	H
4.2	Erect solid screens or barriers around dusty activities or the site boundary that they are at least as high as any stockpiles on site.	H	H	H
4.3	Fully enclose site or specific operations where there is a high potential for dust production and the site is active for an extensive period.	D	H	H
4.4	Avoid site runoff of water or mud.	H	H	H
4.5	Keep site fencing, barriers and scaffolding clean using wet methods.	D	H	H
4.6	Remove materials that have a potential to produce dust from site as soon as possible, unless being re-used on site. If they are being re-used on-site cover as described below	D	H	H
4.7	Cover, seed or fence stockpiles to prevent wind erosion	D	H	H
<b>5 Operating Vehicle/Machinery and Sustainable Travel</b>				
5.1	Ensure all on-road vehicles comply with relevant vehicle emission standards, where applicable	H	H	H
5.2	Ensure all vehicles switch off engines when stationary - no idling vehicles	H	H	H
5.3	Avoid the use of diesel or petrol-powered generators and use mains electricity or battery powered equipment where practicable	H	H	H

Identified Mitigation		Unmitigated Risk		
		Low	Medium	High
5.4	Impose and signpost a maximum-speed-limit of 25 km·h <sup>-1</sup> on surfaced and 15 km·h <sup>-1</sup> on unsurfaced haul roads and work areas (if long haul routes are required these speeds may be increased with suitable additional control measures provided, subject to the approval of the nominated undertaker and with the agreement of the local authority, where appropriate	D	D	H
5.4	Produce a Construction Logistics Plan to manage the sustainable delivery of goods and materials.	N	H	H
5.5	Implement a Travel Plan that supports and encourages sustainable travel (public transport, cycling, walking, and car-sharing)	N	D	H
<b>6 Operations</b>				
6.1	Only use cutting, grinding or sawing equipment fitted or in conjunction with suitable dust suppression techniques such as water sprays or local extraction, e.g. suitable local exhaust ventilation systems	H	H	H
6.2	Ensure an adequate water supply on the site for effective dust/particulate matter suppression/ mitigation, using non-potable water where possible and appropriate	H	H	H
6.3	Use enclosed chutes and conveyors and covered skips	H	H	H
6.4	Minimise drop heights from conveyors, loading shovels, hoppers and other loading or handling equipment and use fine water sprays on such equipment wherever appropriate	H	H	H
6.5	Ensure equipment is readily available on site to clean any dry spillages, and clean up spillages as soon as reasonably practicable after the event using wet cleaning methods.	D	H	H
<b>7 Waste Management</b>				
7.1	Avoid bonfires and burning of waste materials.	H	H	H
<b>8 Measures Specific to Demolition</b>				
8.1	Soft strip inside buildings before demolition (retaining walls and windows in the rest of the building where possible, to provide a screen against dust).	D	D	H
8.2	Ensure effective water suppression is used during demolition operations. Hand held sprays are more effective than hoses attached to equipment as the water can be directed to where it is needed. In addition, high volume water suppression systems, manually controlled, can produce fine water droplets that effectively bring the dust particles to the ground.	H	H	H
8.3	Avoid explosive blasting, using appropriate manual or mechanical alternatives.	H	H	H
8.4	Bag and remove any biological debris or damp down such material before demolition.	H	H	H

Identified Mitigation		Unmitigated Risk		
		Low	Medium	High
8.5	Re-vegetate earthworks and exposed areas/soil stockpiles to stabilise surfaces as soon as practicable.	N	D	H
8.6	Use Hessian, mulches or trackifiers where it is not possible to re-vegetate or cover with topsoil, as soon as practicable.	N	D	H
8.7	Only remove the cover in small areas during work and not all at once	N	D	H
<b>9 Measures Specific to Construction</b>				
8.1	Avoid scabbling (roughening of concrete surfaces) if possible	D	D	H
8.2	Ensure sand and other aggregates are stored in bunded areas and are not allowed to dry out, unless this is required for a particular process, in which case ensure that appropriate additional control measures are in place	D	H	H
8.3	Ensure bulk cement and other fine powder materials are delivered in enclosed tankers and stored in silos with suitable emission control systems to prevent escape of material and overfilling during delivery.	N	D	H
8.4	For smaller supplies of fine power materials ensure bags are sealed after use and stored appropriately to prevent dust	N	D	D
<b>10 Measures Specific to Track-Out</b>				
10.1	Use water-assisted dust sweeper(s) on the access and local roads to remove, as necessary, any material tracked out of the site.	D	H	H
10.2	Avoid dry sweeping of large areas.	D	H	H
10.3	Ensure vehicles entering and leaving sites are covered to prevent escape of materials during transport.	D	H	H
10.4	Inspect on-site haul routes for integrity and instigate necessary repairs to the surface as soon as reasonably practicable.	H	H	H
10.5	Record all inspections of haul routes and any subsequent action in a site log book.	D	H	H
10.6	Install hard surfaced haul routes, which are regularly damped down with fixed or mobile sprinkler systems, or mobile water bowzers and regularly cleaned.	N	H	H
10.7	Implement a wheel washing system (with rumble grids to dislodge accumulated dust and mud prior to leaving the site where reasonably practicable).	D	H	H
10.8	Ensure there is an adequate area of hard surfaced road between the wheel wash facility and the site exit, wherever site size and layout permits.	N	H	H
10.9	Access gates to be located at least 10 m from receptors where possible.	N	H	H
<b>11 Specific Measures to Construction Traffic (adapted)</b>				
5.1	Ensure all on-road vehicles comply with relevant vehicle emission standards, where applicable	H	H	H

Identified Mitigation		Unmitigated Risk		
		Low	Medium	High
8.3	Ensure bulk cement and other fine powder materials are delivered in enclosed tankers and stored in silos with suitable emission control systems to prevent escape of material and overfilling during delivery.	N	D	H
10.3	Ensure vehicles entering and leaving sites are covered to prevent escape of materials during transport.	D	H	H
10.4	Inspect on-site haul routes for integrity and instigate necessary repairs to the surface as soon as reasonably practicable.	H	H	H
10.5	Record all inspections of haul routes and any subsequent action in a site log book.	D	H	H

## Step 6 – Risk Assessment (post-mitigation)

Following Step 5, the residual impact is then determined.

The objective of the mitigation is to manage the construction phase risks to an acceptable level, and therefore it is assumed that application of the identified mitigation would result in a *low* or *negligible* residual risk (post mitigation).

## APPENDIX E

### DISPERSION MODELLING RESULTS

#### Tabulated Results – Ground Level Concentration Values

The predicted ground level concentration (GLC) results of the dispersion modelling are presented in the following tables:

##### Six turbines operating on gas

- Table E-1 Predicted incremental impact, CO, gas
- Table E-2 Predicted incremental impact, NO<sub>2</sub>, gas
- Table E-3 Predicted incremental impact, PM<sub>2.5</sub>, gas
- Table E-4 Predicted incremental impact, SO<sub>2</sub>, gas
- Table E-5 Predicted incremental impact, formaldehyde, gas

##### Six turbines operating on diesel

- Table E-6 Predicted incremental impact, CO, diesel
- Table E-7 Predicted incremental impact, NO<sub>2</sub>, diesel
- Table E-8 Predicted incremental impact, PM<sub>10</sub> / PM<sub>2.5</sub>, diesel
- Table E-9 Predicted incremental impact, SO<sub>2</sub>, diesel
- Table E-10 Predicted incremental impact, formaldehyde, diesel

#### Isopleth Plots – Selected Ground Level Concentration Values

The isopleth plots of predicted ground level concentrations (GLC) are presented in a series of figures. Not all results have been presented as plots, due to the large number that would need to be generated to cover off all the predictions (96 plots). For each pollutant, the respective maximum prediction for each fuel and operating load have generally been plotted however due to the low-order of impacts, some pollutants (e.g. CO) and some averaging periods (e.g. annual average NO<sub>x</sub>) have not been presented.

Please note that the scale and scale bar used to depict the concentrations may not be linear, and care must be applied when interpreting the illustrated values. This has been necessary to illustrate the predicted concentration values on a scale with the relevant Air EPP criterion.

##### Six turbines operating on gas

- Figure E-1 Predicted incremental impact, CO, 1-hour, gas
- Figure E-2 Predicted incremental impact, CO, 8-hour, gas
- Figure E-3 Predicted incremental impact, NO<sub>x</sub> as NO<sub>2</sub>, 1-hour, gas
- Figure E-4 Predicted incremental impact, NO<sub>x</sub> as NO<sub>2</sub>, annual average
- Figure E-5 Predicted incremental impact, PM<sub>10</sub>, 24-hour, gas



- Figure E-6 Predicted incremental impact, PM<sub>2.5</sub>, 24-hour, gas
- Figure E-7 Predicted incremental impact, PM<sub>2.5</sub>, annual average, gas
- Figure E-8 Predicted incremental impact, SO<sub>2</sub>, 1-hour, gas
- Figure E-9 Predicted incremental impact, SO<sub>2</sub>, 24-hour, gas
- Figure E-10 Predicted incremental impact, SO<sub>2</sub>, annual average, gas
- Figure E-11 Predicted incremental impact, CH<sub>2</sub>O, 1-hour, gas
- Figure E-12 Predicted incremental impact, CH<sub>2</sub>O, 3-min, gas

#### **Six turbines operating on diesel**

- Figure E-13 Predicted incremental impact, CO, 1-hour, gas
- Figure E-14 Predicted incremental impact, CO, 8-hour, gas
- Figure E-15 Predicted incremental impact, NO<sub>x</sub> as NO<sub>2</sub>, 1-hour, gas
- Figure E-16 Predicted incremental impact, NO<sub>x</sub> as NO<sub>2</sub>, annual average
- Figure E-17 Predicted incremental impact, PM<sub>10</sub>, 24-hour, gas
- Figure E-18 Predicted incremental impact, PM<sub>2.5</sub>, 24-hour, gas
- Figure E-19 Predicted incremental impact, PM<sub>2.5</sub>, annual average, gas
- Figure E-20 Predicted incremental impact, SO<sub>2</sub>, 1-hour, gas
- Figure E-21 Predicted incremental impact, SO<sub>2</sub>, 24-hour, gas
- Figure E-22 Predicted incremental impact, SO<sub>2</sub>, annual average, gas
- Figure E-23 Predicted incremental impact, CH<sub>2</sub>O, 1-hour, gas
- Figure E-24 Predicted incremental impact, CH<sub>2</sub>O, 3-min, gas

**Table E-1 Predicted incremental impact, CO, gas**

Load	CO, 100% load, gas		CO, 75% load, gas		CO, 50% load, gas		CO, 25% load, gas	
Units	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour
R1	27.84	7.35	32.18	6.55	24.39	5.66	17.19	4.95
R2	29.12	6.58	31.30	5.94	22.44	5.16	17.83	4.26
R3	21.82	4.61	21.71	3.87	15.70	3.16	11.60	2.54
R4	27.35	5.69	22.06	4.13	16.76	3.36	10.35	2.88
R5	26.70	5.60	21.90	4.02	16.00	3.24	10.24	2.78
R6	21.58	4.89	17.61	4.30	11.55	3.73	10.82	2.79
R7	18.48	3.80	13.98	3.71	11.22	3.37	10.14	2.86
R8	23.96	3.45	17.04	3.51	13.75	3.15	12.09	3.14
R9	31.71	5.91	26.55	6.00	22.66	5.66	21.01	5.00
R10	20.97	4.99	15.84	4.77	13.36	4.37	17.77	4.57
R11	20.31	4.63	16.68	4.41	15.11	4.12	17.43	4.85
R12	19.23	5.35	14.02	6.18	17.45	5.97	14.76	6.59
R13	15.21	6.34	16.14	6.63	16.36	6.01	10.75	6.12
R14	15.60	4.88	14.72	5.17	15.52	4.73	13.83	4.88
R15	19.19	3.45	17.30	3.41	13.37	2.94	15.79	2.79
R16	19.38	3.71	16.85	3.76	12.64	3.29	15.97	3.17
R17	22.20	4.18	17.93	3.55	14.30	3.14	13.14	3.08
R18	37.47	5.51	32.09	4.93	25.81	3.87	22.64	3.46

Load	CO, 100% load, gas		CO, 75% load, gas		CO, 50% load, gas		CO, 25% load, gas	
	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour
R19	17.83	3.38	13.84	2.98	9.48	2.54	12.82	2.47
R20	26.67	4.89	21.66	4.20	17.24	3.42	15.52	3.07
R21	13.68	6.94	11.57	6.98	9.18	6.23	7.83	6.05
R22	7.85	4.74	11.44	4.44	6.26	3.74	5.60	3.49
R23	11.28	3.53	7.40	3.08	8.30	2.55	5.59	2.19
R24	11.04	1.82	8.03	2.08	8.25	1.85	5.93	1.75
R25	8.09	4.45	6.65	3.02	4.90	2.67	4.80	2.61
R26	7.75	4.39	6.77	2.61	5.04	2.21	5.26	2.30
R27	12.70	1.84	6.18	3.15	5.07	2.01	4.26	1.95
R28	5.45	2.62	5.61	2.59	3.80	2.24	4.60	2.16
R29	7.05	2.01	6.27	1.72	4.92	1.43	4.05	1.31
R30	20.57	6.51	17.08	5.55	12.92	4.42	11.83	4.16
R31	10.25	2.91	7.77	2.55	5.61	2.07	5.52	1.86
R32	6.58	2.69	5.61	2.07	4.55	1.85	3.81	1.86
R33	12.76	3.34	9.36	3.15	8.40	2.82	5.98	2.79
R34	23.93	13.19	20.19	14.80	17.77	14.12	16.95	14.65
R35	8.43	2.47	7.45	2.60	7.14	2.48	6.68	2.78
R36	6.89	2.15	6.47	2.46	9.37	2.35	5.40	2.62
R37	15.06	4.72	12.55	4.05	13.79	3.38	10.47	3.40

Load	CO, 100% load, gas		CO, 75% load, gas		CO, 50% load, gas		CO, 25% load, gas	
Units	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour
R38	9.84	4.25	8.55	4.07	7.47	3.46	7.34	3.25
R39	7.20	2.90	7.61	2.69	6.87	2.27	6.87	2.26
R40	7.33	1.50	8.19	1.71	7.19	1.50	10.74	1.80
R41	18.78	3.10	8.82	2.34	6.95	2.17	6.16	1.85
R42	11.83	2.43	11.24	2.36	11.29	1.92	12.42	1.92
R43	12.27	2.68	13.17	2.26	12.77	2.00	14.29	1.80
R44	15.73	2.42	15.74	2.47	15.70	1.99	13.57	1.74
R45	16.79	2.25	18.19	2.42	14.75	1.89	10.88	1.68
R46	22.40	3.72	11.75	2.26	7.76	2.02	6.91	1.98
R47	10.44	2.46	8.94	2.61	13.28	2.29	8.49	2.47
R48	10.43	2.43	8.93	3.08	8.27	2.67	9.95	2.16
R49	17.61	5.20	16.69	4.18	14.93	3.90	14.35	3.69
R50	18.25	7.13	16.28	7.98	14.90	7.55	14.51	7.89
R51	23.25	3.58	25.71	4.79	24.95	4.46	24.76	4.14
Max ( $\mu\text{g}\cdot\text{m}^{-3}$ )	37.47	13.19	32.18	14.80	25.81	14.12	24.76	14.65
Criterion <sup>(A)</sup>	31,240 $\mu\text{g}\cdot\text{m}^{-3}$ (31.24 $\text{mg}\cdot\text{m}^{-3}$ )	11,120 $\mu\text{g}\cdot\text{m}^{-3}$ (11.12 $\text{mg}\cdot\text{m}^{-3}$ )	31,240 $\mu\text{g}\cdot\text{m}^{-3}$ (31.24 $\text{mg}\cdot\text{m}^{-3}$ )	11,120 $\mu\text{g}\cdot\text{m}^{-3}$ (11.12 $\text{mg}\cdot\text{m}^{-3}$ )	31,240 $\mu\text{g}\cdot\text{m}^{-3}$ (31.24 $\text{mg}\cdot\text{m}^{-3}$ )	11,120 $\mu\text{g}\cdot\text{m}^{-3}$ (11.12 $\text{mg}\cdot\text{m}^{-3}$ )	31,240 $\mu\text{g}\cdot\text{m}^{-3}$ (31.24 $\text{mg}\cdot\text{m}^{-3}$ )	11,120 $\mu\text{g}\cdot\text{m}^{-3}$ (11.12 $\text{mg}\cdot\text{m}^{-3}$ )
Plotted	No	No	No	No	No	No	No	No

**Note:** (A) The criterion is applicable to the predicted cumulative impact, but has been provided for context. (B) Exceedence of the criterion is indicated by red highlighting

**Table E-2 Predicted incremental impact, NO<sub>2</sub>, gas**

Load	NO <sub>x</sub> (as NO <sub>2</sub> ), 100% load, gas		NO <sub>x</sub> (as NO <sub>2</sub> ), 75% load, gas		NO <sub>x</sub> (as NO <sub>2</sub> ), 50% load, gas		NO <sub>x</sub> (as NO <sub>2</sub> ), 25% load, gas	
	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual
R1	45.68	0.33	52.81	0.32	40.03	0.27	28.21	0.26
R2	47.79	0.30	51.37	0.28	36.82	0.24	29.25	0.23
R3	35.81	0.17	35.62	0.16	25.76	0.14	19.04	0.13
R4	44.88	0.16	36.20	0.14	27.50	0.12	16.99	0.11
R5	43.81	0.15	35.94	0.14	26.26	0.12	16.80	0.11
R6	35.42	0.19	28.91	0.18	18.96	0.15	17.75	0.14
R7	30.33	0.24	22.94	0.22	18.42	0.19	16.64	0.18
R8	39.32	0.29	27.96	0.27	22.56	0.23	19.85	0.22
R9	52.04	0.53	43.57	0.50	37.19	0.43	34.47	0.41
R10	34.41	0.32	25.99	0.30	21.92	0.26	29.16	0.26
R11	33.34	0.27	27.37	0.26	24.80	0.22	28.60	0.22
R12	31.56	0.24	23.01	0.23	28.63	0.20	24.23	0.21
R13	24.96	0.21	26.49	0.20	26.84	0.18	17.64	0.18
R14	25.60	0.20	24.15	0.20	25.46	0.17	22.70	0.17
R15	31.49	0.23	28.39	0.21	21.93	0.18	25.92	0.18
R16	31.81	0.25	27.66	0.23	20.74	0.20	26.21	0.19
R17	36.43	0.28	29.42	0.26	23.46	0.22	21.56	0.21
R18	61.49	0.41	52.67	0.39	42.35	0.33	37.15	0.32
R19	29.27	0.22	22.72	0.21	15.56	0.17	21.04	0.17

Load	NO <sub>x</sub> (as NO <sub>2</sub> ), 100% load, gas		NO <sub>x</sub> (as NO <sub>2</sub> ), 75% load, gas		NO <sub>x</sub> (as NO <sub>2</sub> ), 50% load, gas		NO <sub>x</sub> (as NO <sub>2</sub> ), 25% load, gas	
	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual
R20	43.76	0.24	35.55	0.22	28.29	0.19	25.47	0.18
R21	22.44	0.26	18.98	0.26	15.07	0.23	12.86	0.23
R22	12.88	0.19	18.77	0.18	10.28	0.16	9.20	0.15
R23	18.51	0.14	12.15	0.13	13.62	0.11	9.18	0.11
R24	18.12	0.15	13.17	0.14	13.54	0.12	9.74	0.11
R25	13.28	0.12	10.91	0.11	8.03	0.09	7.87	0.09
R26	12.72	0.12	11.11	0.11	8.28	0.09	8.63	0.08
R27	20.85	0.11	10.14	0.10	8.32	0.09	7.00	0.08
R28	8.94	0.14	9.20	0.13	6.24	0.11	7.55	0.11
R29	11.57	0.14	10.28	0.13	8.07	0.11	6.65	0.10
R30	33.76	0.23	28.03	0.21	21.21	0.18	19.42	0.18
R31	16.82	0.15	12.76	0.14	9.20	0.12	9.05	0.11
R32	10.80	0.14	9.21	0.13	7.46	0.11	6.25	0.10
R33	20.95	0.17	15.36	0.15	13.79	0.13	9.81	0.12
R34	39.26	0.36	33.13	0.37	29.16	0.33	27.81	0.35
R35	13.83	0.16	12.23	0.16	11.71	0.14	10.96	0.15
R36	11.31	0.16	10.62	0.16	15.38	0.15	8.86	0.15
R37	24.71	0.25	20.60	0.24	22.63	0.20	17.17	0.19
R38	16.15	0.18	14.03	0.18	12.26	0.16	12.04	0.16

Load	NO <sub>x</sub> (as NO <sub>2</sub> ), 100% load, gas		NO <sub>x</sub> (as NO <sub>2</sub> ), 75% load, gas		NO <sub>x</sub> (as NO <sub>2</sub> ), 50% load, gas		NO <sub>x</sub> (as NO <sub>2</sub> ), 25% load, gas	
	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual
R39	11.81	0.18	12.49	0.17	11.28	0.15	11.27	0.15
R40	12.03	0.13	13.45	0.13	11.80	0.12	17.63	0.12
R41	30.83	0.13	14.47	0.12	11.40	0.10	10.11	0.10
R42	19.41	0.12	18.44	0.11	18.52	0.10	20.38	0.09
R43	20.14	0.12	21.61	0.11	20.95	0.09	23.45	0.09
R44	25.81	0.12	25.83	0.11	25.76	0.09	22.27	0.09
R45	27.56	0.12	29.86	0.11	24.21	0.09	17.85	0.08
R46	36.76	0.14	19.29	0.13	12.73	0.11	11.33	0.11
R47	17.13	0.15	14.67	0.14	21.80	0.13	13.93	0.13
R48	17.11	0.12	14.65	0.11	13.56	0.10	16.34	0.09
R49	28.91	0.24	27.38	0.23	24.49	0.19	23.55	0.18
R50	29.95	0.29	26.71	0.30	24.45	0.28	23.82	0.30
R51	38.15	0.22	42.20	0.21	40.94	0.18	40.64	0.17
Max (µg·m <sup>-3</sup> )	61.49	0.53	52.81	0.50	42.35	0.43	40.64	0.41
Criterion <sup>(A)</sup>	250 µg·m <sup>-3</sup> (0.25 mg·m <sup>-3</sup> )	60 µg·m <sup>-3</sup> (0.06 mg·m <sup>-3</sup> )	250 µg·m <sup>-3</sup> (0.25 mg·m <sup>-3</sup> )	60 µg·m <sup>-3</sup> (0.06 mg·m <sup>-3</sup> )	250 µg·m <sup>-3</sup> (0.25 mg·m <sup>-3</sup> )	60 µg·m <sup>-3</sup> (0.06 mg·m <sup>-3</sup> )	250 µg·m <sup>-3</sup> (0.25 mg·m <sup>-3</sup> )	60 µg·m <sup>-3</sup> (0.06 mg·m <sup>-3</sup> )
Plotted	Yes	Yes	No	No	No	No	No	No

**Note:** (A) The criterion is applicable to the predicted cumulative impact, but has been provided for context. (B) Exceedence of the criterion is indicated by red highlighting (C) Assumes a 100% NO<sub>x</sub> to NO<sub>2</sub> conversion

**Table E-3 Predicted incremental impact, PM10 / PM2.5, gas**

Load	PM, 100% load, gas		PM, 75% load, gas		PM, 50% load, gas		PM, 25% load, gas	
Units	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual
R1	0.44	0.04	0.57	0.04	0.65	0.05	0.64	0.05
R2	0.40	0.03	0.54	0.04	0.59	0.04	0.54	0.05
R3	0.28	0.02	0.31	0.02	0.34	0.02	0.30	0.03
R4	0.34	0.02	0.31	0.02	0.32	0.02	0.33	0.02
R5	0.34	0.02	0.30	0.02	0.31	0.02	0.31	0.02
R6	0.30	0.02	0.32	0.02	0.35	0.03	0.32	0.03
R7	0.27	0.03	0.29	0.03	0.32	0.03	0.33	0.04
R8	0.33	0.03	0.38	0.04	0.40	0.04	0.44	0.04
R9	0.57	0.06	0.62	0.07	0.65	0.07	0.77	0.08
R10	0.38	0.03	0.42	0.04	0.45	0.04	0.52	0.05
R11	0.32	0.03	0.34	0.04	0.40	0.04	0.56	0.05
R12	0.33	0.03	0.47	0.03	0.58	0.04	0.76	0.04
R13	0.40	0.02	0.51	0.03	0.59	0.03	0.72	0.04
R14	0.30	0.02	0.39	0.03	0.45	0.03	0.56	0.04
R15	0.28	0.02	0.28	0.03	0.30	0.03	0.38	0.04
R16	0.28	0.03	0.32	0.03	0.32	0.03	0.37	0.04
R17	0.34	0.03	0.38	0.04	0.40	0.04	0.44	0.04
R18	0.49	0.05	0.54	0.05	0.57	0.06	0.61	0.07
R19	0.26	0.02	0.31	0.03	0.34	0.03	0.48	0.04



Load	PM, 100% load, gas		PM, 75% load, gas		PM, 50% load, gas		PM, 25% load, gas	
Units	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual
R20	0.38	0.03	0.40	0.03	0.42	0.03	0.51	0.04
R21	0.63	0.03	0.80	0.03	0.96	0.04	1.23	0.05
R22	0.54	0.02	0.66	0.02	0.74	0.03	0.86	0.03
R23	0.22	0.02	0.23	0.02	0.25	0.02	0.27	0.02
R24	0.17	0.02	0.21	0.02	0.25	0.02	0.29	0.02
R25	0.34	0.01	0.42	0.01	0.47	0.02	0.54	0.02
R26	0.38	0.01	0.44	0.01	0.47	0.02	0.55	0.02
R27	0.23	0.01	0.28	0.01	0.34	0.01	0.43	0.02
R28	0.34	0.02	0.42	0.02	0.46	0.02	0.53	0.02
R29	0.32	0.02	0.35	0.02	0.37	0.02	0.41	0.02
R30	0.61	0.02	0.68	0.03	0.72	0.03	0.78	0.04
R31	0.26	0.02	0.27	0.02	0.29	0.02	0.35	0.02
R32	0.24	0.02	0.25	0.02	0.24	0.02	0.24	0.02
R33	0.30	0.02	0.29	0.02	0.33	0.02	0.38	0.03
R34	0.81	0.04	1.12	0.05	1.37	0.06	1.73	0.07
R35	0.28	0.02	0.39	0.02	0.48	0.02	0.64	0.03
R36	0.28	0.02	0.38	0.02	0.45	0.03	0.56	0.03
R37	0.46	0.03	0.55	0.03	0.62	0.04	0.74	0.04
R38	0.51	0.02	0.61	0.02	0.66	0.03	0.75	0.03

Load	PM, 100% load, gas		PM, 75% load, gas		PM, 50% load, gas		PM, 25% load, gas	
Units	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual
R39	0.29	0.02	0.34	0.02	0.39	0.03	0.45	0.03
R40	0.16	0.01	0.23	0.02	0.29	0.02	0.40	0.02
R41	0.23	0.01	0.27	0.02	0.31	0.02	0.36	0.02
R42	0.17	0.01	0.20	0.02	0.20	0.02	0.28	0.02
R43	0.18	0.01	0.19	0.02	0.21	0.02	0.31	0.02
R44	0.16	0.01	0.20	0.01	0.24	0.02	0.30	0.02
R45	0.15	0.01	0.20	0.01	0.24	0.02	0.25	0.02
R46	0.26	0.02	0.28	0.02	0.32	0.02	0.38	0.02
R47	0.20	0.02	0.23	0.02	0.27	0.02	0.39	0.03
R48	0.16	0.01	0.23	0.02	0.26	0.02	0.25	0.02
R49	0.35	0.03	0.39	0.03	0.42	0.03	0.47	0.04
R50	0.45	0.03	0.74	0.04	1.15	0.05	1.98	0.06
R51	0.31	0.02	0.42	0.03	0.49	0.03	0.54	0.04
Max ( $\mu\text{g}\cdot\text{m}^{-3}$ )	0.81	0.06	1.12	0.07	1.37	0.07	1.98	0.08
Criterion <sup>(B)</sup>	25 $\mu\text{g}\cdot\text{m}^{-3}$ (0.025 $\text{mg}\cdot\text{m}^{-3}$ )	8 $\mu\text{g}\cdot\text{m}^{-3}$ (0.008 $\text{mg}\cdot\text{m}^{-3}$ )	25 $\mu\text{g}\cdot\text{m}^{-3}$ (0.025 $\text{mg}\cdot\text{m}^{-3}$ )	8 $\mu\text{g}\cdot\text{m}^{-3}$ (0.008 $\text{mg}\cdot\text{m}^{-3}$ )	25 $\mu\text{g}\cdot\text{m}^{-3}$ (0.025 $\text{mg}\cdot\text{m}^{-3}$ )	8 $\mu\text{g}\cdot\text{m}^{-3}$ (0.008 $\text{mg}\cdot\text{m}^{-3}$ )	25 $\mu\text{g}\cdot\text{m}^{-3}$ (0.025 $\text{mg}\cdot\text{m}^{-3}$ )	8 $\mu\text{g}\cdot\text{m}^{-3}$ (0.008 $\text{mg}\cdot\text{m}^{-3}$ )
Plotted	No	No	No	No	No	No	Yes	Yes

**Note:** (A) The criterion is applicable to the predicted cumulative impact, but has been provided for context.

(B) Exceedence of the criterion is indicated by red highlighting

**Table E-4 Predicted incremental impact, SO<sub>2</sub>, gas**

Load	SO <sub>2</sub> , 100% load, gas			SO <sub>2</sub> , 75% load, gas			SO <sub>2</sub> , 50% load, gas			SO <sub>2</sub> , 25% load, gas		
Units	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann
R1	7.30	0.65	0.05	8.46	0.68	0.05	6.45	0.61	0.04	4.52	0.49	0.04
R2	7.64	0.58	0.05	8.23	0.64	0.05	5.94	0.55	0.04	4.68	0.42	0.04
R3	5.72	0.41	0.03	5.70	0.37	0.03	4.15	0.32	0.02	3.05	0.23	0.02
R4	7.17	0.50	0.02	5.80	0.36	0.02	4.43	0.30	0.02	2.72	0.25	0.02
R5	7.00	0.49	0.02	5.75	0.35	0.02	4.23	0.29	0.02	2.69	0.24	0.02
R6	5.66	0.43	0.03	4.63	0.38	0.03	3.06	0.33	0.02	2.84	0.25	0.02
R7	4.85	0.40	0.04	3.67	0.34	0.04	2.97	0.30	0.03	2.66	0.26	0.03
R8	6.28	0.48	0.05	4.48	0.45	0.04	3.64	0.37	0.04	3.18	0.34	0.03
R9	8.32	0.83	0.08	6.98	0.74	0.08	5.99	0.60	0.07	5.52	0.60	0.07
R10	5.50	0.55	0.05	4.16	0.50	0.05	3.53	0.42	0.04	4.67	0.40	0.04
R11	5.33	0.46	0.04	4.38	0.41	0.04	4.00	0.37	0.04	4.58	0.43	0.04
R12	5.04	0.48	0.04	3.68	0.56	0.04	4.62	0.54	0.03	3.88	0.59	0.03
R13	3.99	0.57	0.03	4.24	0.60	0.03	4.33	0.55	0.03	2.82	0.56	0.03
R14	4.09	0.43	0.03	3.87	0.46	0.03	4.10	0.42	0.03	3.63	0.43	0.03
R15	5.03	0.40	0.04	4.55	0.33	0.03	3.54	0.28	0.03	4.15	0.29	0.03
R16	5.08	0.41	0.04	4.43	0.38	0.04	3.34	0.30	0.03	4.20	0.29	0.03
R17	5.82	0.49	0.04	4.71	0.46	0.04	3.78	0.37	0.04	3.45	0.34	0.03
R18	9.83	0.71	0.07	8.43	0.64	0.06	6.83	0.53	0.05	5.95	0.47	0.05
R19	4.68	0.38	0.04	3.64	0.37	0.03	2.51	0.32	0.03	3.37	0.37	0.03

Load	SO <sub>2</sub> , 100% load, gas			SO <sub>2</sub> , 75% load, gas			SO <sub>2</sub> , 50% load, gas			SO <sub>2</sub> , 25% load, gas		
Units	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann
R20	6.99	0.55	0.04	5.69	0.48	0.04	4.56	0.39	0.03	4.08	0.39	0.03
R21	3.59	0.92	0.04	3.04	0.95	0.04	2.43	0.89	0.04	2.06	0.95	0.04
R22	2.06	0.78	0.03	3.01	0.78	0.03	1.66	0.69	0.03	1.47	0.67	0.02
R23	2.96	0.31	0.02	1.95	0.27	0.02	2.20	0.23	0.02	1.47	0.21	0.02
R24	2.90	0.24	0.02	2.11	0.25	0.02	2.18	0.24	0.02	1.56	0.22	0.02
R25	2.12	0.50	0.02	1.75	0.49	0.02	1.30	0.43	0.01	1.26	0.42	0.01
R26	2.03	0.55	0.02	1.78	0.52	0.02	1.33	0.44	0.01	1.38	0.43	0.01
R27	3.33	0.33	0.02	1.62	0.33	0.02	1.34	0.31	0.01	1.12	0.33	0.01
R28	1.43	0.50	0.02	1.47	0.49	0.02	1.01	0.43	0.02	1.21	0.41	0.02
R29	1.85	0.46	0.02	1.65	0.41	0.02	1.30	0.34	0.02	1.06	0.32	0.02
R30	5.39	0.89	0.04	4.49	0.81	0.03	3.42	0.67	0.03	3.11	0.61	0.03
R31	2.69	0.38	0.02	2.04	0.32	0.02	1.48	0.27	0.02	1.45	0.27	0.02
R32	1.73	0.35	0.02	1.47	0.29	0.02	1.20	0.22	0.02	1.00	0.19	0.02
R33	3.35	0.44	0.03	2.46	0.34	0.02	2.22	0.31	0.02	1.57	0.30	0.02
R34	6.27	1.18	0.06	5.30	1.33	0.06	4.70	1.28	0.05	4.45	1.34	0.06
R35	2.21	0.40	0.03	1.96	0.46	0.02	1.89	0.45	0.02	1.76	0.50	0.02
R36	1.81	0.41	0.03	1.70	0.45	0.03	2.48	0.42	0.02	1.42	0.44	0.02
R37	3.95	0.67	0.04	3.30	0.65	0.04	3.65	0.58	0.03	2.75	0.57	0.03
R38	2.58	0.75	0.03	2.25	0.72	0.03	1.98	0.62	0.03	1.93	0.58	0.03

Load	SO <sub>2</sub> , 100% load, gas			SO <sub>2</sub> , 75% load, gas			SO <sub>2</sub> , 50% load, gas			SO <sub>2</sub> , 25% load, gas		
Units	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann
R39	1.89	0.42	0.03	2.00	0.41	0.03	1.82	0.36	0.02	1.80	0.35	0.02
R40	1.92	0.23	0.02	2.15	0.28	0.02	1.90	0.27	0.02	2.82	0.31	0.02
R41	4.93	0.33	0.02	2.32	0.33	0.02	1.84	0.29	0.02	1.62	0.28	0.02
R42	3.10	0.25	0.02	2.95	0.24	0.02	2.99	0.19	0.02	3.26	0.22	0.02
R43	3.22	0.27	0.02	3.46	0.22	0.02	3.38	0.20	0.02	3.75	0.24	0.01
R44	4.12	0.23	0.02	4.14	0.24	0.02	4.15	0.23	0.01	3.57	0.23	0.01
R45	4.40	0.22	0.02	4.78	0.24	0.02	3.90	0.22	0.01	2.86	0.20	0.01
R46	5.87	0.38	0.02	3.09	0.33	0.02	2.05	0.30	0.02	1.81	0.30	0.02
R47	2.74	0.29	0.02	2.35	0.27	0.02	3.51	0.25	0.02	2.23	0.30	0.02
R48	2.73	0.23	0.02	2.35	0.28	0.02	2.19	0.24	0.02	2.62	0.19	0.01
R49	4.62	0.51	0.04	4.38	0.47	0.04	3.95	0.39	0.03	3.77	0.36	0.03
R50	4.79	0.65	0.05	4.28	0.88	0.05	3.94	1.07	0.05	3.81	1.53	0.05
R51	6.10	0.45	0.03	6.76	0.50	0.03	6.60	0.46	0.03	6.51	0.42	0.03
Max (µg·m <sup>-3</sup> )	9.83	1.18	0.08	8.46	1.33	0.08	6.83	1.28	0.07	6.51	1.53	0.07
Criterion <sup>(A)</sup>	570 µg·m <sup>-3</sup> 0.57 mg·m <sup>-3</sup>	230 µg·m <sup>-3</sup> 0.23 mg·m <sup>-3</sup>	60 µg·m <sup>-3</sup> 0.06 mg·m <sup>-3</sup>	570 µg·m <sup>-3</sup> 0.57 mg·m <sup>-3</sup>	230 µg·m <sup>-3</sup> 0.23 mg·m <sup>-3</sup>	60 µg·m <sup>-3</sup> 0.06 mg·m <sup>-3</sup>	570 µg·m <sup>-3</sup> 0.57 mg·m <sup>-3</sup>	230 µg·m <sup>-3</sup> 0.23 mg·m <sup>-3</sup>	60 µg·m <sup>-3</sup> 0.06 mg·m <sup>-3</sup>	570 µg·m <sup>-3</sup> 0.57 mg·m <sup>-3</sup>	230 µg·m <sup>-3</sup> 0.23 mg·m <sup>-3</sup>	60 µg·m <sup>-3</sup> 0.06 mg·m <sup>-3</sup>
Plotted	Yes	No	No	No	No	No	No	No	No	No	Yes	No

**Note:** (A) The criterion is applicable to the predicted cumulative impact, but has been provided for context.

(B) Exceedence of the criterion is indicated by red highlighting

**Table E-5 Predicted incremental impact, formaldehyde, gas**

Load	Formaldehyde, 100% load, gas		Formaldehyde, 75% load, gas		Formaldehyde, 50% load, gas		Formaldehyde, 25% load, gas	
	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min
R1	0.45	0.82	2.25	4.09	1.69	3.08	1.05	1.92
R2	0.47	0.86	2.18	3.98	1.56	2.83	1.09	1.99
R3	0.36	0.65	1.52	2.76	1.09	1.98	0.71	1.29
R4	0.45	0.81	1.54	2.80	1.16	2.12	0.63	1.15
R5	0.43	0.79	1.53	2.78	1.11	2.02	0.63	1.14
R6	0.35	0.64	1.23	2.24	0.80	1.46	0.66	1.21
R7	0.30	0.55	0.98	1.78	0.78	1.42	0.62	1.13
R8	0.39	0.71	1.19	2.16	0.95	1.74	0.74	1.35
R9	0.52	0.94	1.85	3.37	1.57	2.86	1.29	2.34
R10	0.34	0.62	1.11	2.01	0.93	1.69	1.09	1.98
R11	0.33	0.60	1.16	2.12	1.05	1.91	1.07	1.94
R12	0.31	0.57	0.98	1.78	1.21	2.20	0.90	1.65
R13	0.25	0.45	1.13	2.05	1.13	2.07	0.66	1.20
R14	0.25	0.46	1.03	1.87	1.08	1.96	0.85	1.54
R15	0.31	0.57	1.21	2.20	0.93	1.69	0.97	1.76
R16	0.32	0.57	1.18	2.14	0.88	1.60	0.98	1.78
R17	0.36	0.66	1.25	2.28	0.99	1.81	0.80	1.46
R18	0.61	1.11	2.24	4.08	1.79	3.26	1.39	2.52
R19	0.29	0.53	0.97	1.76	0.66	1.20	0.79	1.43

Load	Formaldehyde, 100% load, gas		Formaldehyde, 75% load, gas		Formaldehyde, 50% load, gas		Formaldehyde, 25% load, gas	
Units	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min
R20	0.43	0.79	1.51	2.75	1.20	2.18	0.95	1.73
R21	0.22	0.41	0.81	1.47	0.64	1.16	0.48	0.87
R22	0.13	0.23	0.80	1.45	0.43	0.79	0.34	0.62
R23	0.18	0.33	0.52	0.94	0.58	1.05	0.34	0.62
R24	0.18	0.33	0.56	1.02	0.57	1.04	0.36	0.66
R25	0.13	0.24	0.46	0.84	0.34	0.62	0.29	0.53
R26	0.13	0.23	0.47	0.86	0.35	0.64	0.32	0.59
R27	0.21	0.38	0.43	0.79	0.35	0.64	0.26	0.48
R28	0.09	0.16	0.39	0.71	0.26	0.48	0.28	0.51
R29	0.11	0.21	0.44	0.80	0.34	0.62	0.25	0.45
R30	0.33	0.61	1.19	2.17	0.90	1.63	0.72	1.32
R31	0.17	0.30	0.54	0.99	0.39	0.71	0.34	0.61
R32	0.11	0.19	0.39	0.71	0.32	0.57	0.23	0.42
R33	0.21	0.38	0.65	1.19	0.58	1.06	0.37	0.67
R34	0.39	0.71	1.41	2.57	1.23	2.24	1.04	1.89
R35	0.14	0.25	0.52	0.95	0.49	0.90	0.41	0.74
R36	0.11	0.20	0.45	0.82	0.65	1.18	0.33	0.60
R37	0.25	0.45	0.88	1.60	0.96	1.74	0.64	1.17
R38	0.16	0.29	0.60	1.09	0.52	0.94	0.45	0.82

Load	Formaldehyde, 100% load, gas		Formaldehyde, 75% load, gas		Formaldehyde, 50% load, gas		Formaldehyde, 25% load, gas	
Units	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min
R39	0.12	0.21	0.53	0.97	0.48	0.87	0.42	0.77
R40	0.12	0.22	0.57	1.04	0.50	0.91	0.66	1.20
R41	0.31	0.56	0.62	1.12	0.48	0.88	0.38	0.69
R42	0.19	0.35	0.78	1.43	0.78	1.43	0.76	1.38
R43	0.20	0.36	0.92	1.67	0.89	1.61	0.88	1.59
R44	0.26	0.47	1.10	2.00	1.09	1.98	0.83	1.51
R45	0.27	0.50	1.27	2.31	1.02	1.86	0.67	1.21
R46	0.36	0.66	0.82	1.49	0.54	0.98	0.42	0.77
R47	0.17	0.31	0.62	1.14	0.92	1.68	0.52	0.95
R48	0.17	0.31	0.62	1.13	0.57	1.04	0.61	1.11
R49	0.29	0.52	1.16	2.12	1.04	1.88	0.88	1.60
R50	0.30	0.54	1.14	2.07	1.03	1.88	0.89	1.62
R51	0.38	0.69	1.79	3.27	1.73	3.15	1.52	2.76
Max ( $\mu\text{g}\cdot\text{m}^{-3}$ )	0.61	1.11	2.25	4.09	1.79	3.26	1.52	2.76
Criterion <sup>(A)</sup>	-	44 $\mu\text{g}\cdot\text{m}^{-3}$ (0.044 $\text{mg}\cdot\text{m}^{-3}$ )	-	44 $\mu\text{g}\cdot\text{m}^{-3}$ (0.044 $\text{mg}\cdot\text{m}^{-3}$ )	-	44 $\mu\text{g}\cdot\text{m}^{-3}$ (0.044 $\text{mg}\cdot\text{m}^{-3}$ )	-	44 $\mu\text{g}\cdot\text{m}^{-3}$ (0.044 $\text{mg}\cdot\text{m}^{-3}$ )
Potted	No	No	No	Yes	No	No	No	No

**Note:** (A) The criterion is applicable to the predicted cumulative impact as a 3-minute average, but has been provided for context. This has been converted using the method outlined in **Section 4.2.6**

(B) Exceedence of the criterion is indicated by **red highlighting**



**Table E-6 Predicted incremental impact, CO, diesel**

Load	CO, 100% load, diesel		CO, 75% load, diesel		CO, 50% load, diesel		CO, 25% load, diesel	
	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour
R1	31.51	6.71	29.37	6.10	26.83	5.73	16.15	4.74
R2	31.95	5.98	28.14	5.55	25.41	5.20	16.84	4.06
R3	20.70	4.08	19.69	3.55	17.84	3.28	10.51	2.42
R4	24.34	4.68	19.88	3.74	18.14	3.48	9.96	2.76
R5	23.99	4.62	19.78	3.62	18.07	3.36	9.70	2.67
R6	19.32	4.37	15.39	4.03	12.13	3.78	10.80	2.67
R7	19.70	3.62	12.49	3.53	11.60	3.35	9.77	2.63
R8	20.43	3.42	15.59	3.33	14.39	3.15	11.63	2.89
R9	28.11	5.67	24.71	5.77	23.09	5.52	20.44	4.73
R10	19.98	4.79	14.73	4.48	13.74	4.27	17.33	4.52
R11	18.30	4.46	15.65	4.10	14.68	3.87	16.55	4.91
R12	15.75	5.67	15.46	5.97	15.87	5.75	13.24	6.59
R13	11.56	6.42	16.72	6.28	16.37	5.96	11.08	6.04
R14	13.42	4.97	14.05	4.91	13.58	4.67	12.44	4.83
R15	18.19	3.40	15.75	3.18	14.44	2.98	15.56	2.71
R16	18.19	3.70	15.21	3.52	13.86	3.31	16.06	3.09
R17	19.43	3.81	16.33	3.33	15.03	3.14	14.09	3.01
R18	34.27	5.04	29.32	4.51	27.04	4.12	21.76	3.34
R19	16.11	3.01	12.17	2.77	10.88	2.59	13.39	2.60

Load	CO, 100% load, diesel		CO, 75% load, diesel		CO, 50% load, diesel		CO, 25% load, diesel	
Units	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour
R20	23.49	4.44	19.72	3.86	18.15	3.57	15.30	3.00
R21	12.48	6.82	10.51	6.57	9.67	6.22	8.37	5.90
R22	11.33	4.54	9.45	4.11	7.78	3.83	5.34	3.40
R23	6.06	3.27	8.10	2.84	8.15	2.70	5.77	2.10
R24	7.03	1.95	7.92	1.98	7.63	1.86	5.37	1.71
R25	12.17	3.16	6.07	2.84	5.36	2.67	5.01	2.55
R26	10.64	3.90	6.10	2.28	5.54	2.16	5.06	2.28
R27	6.14	2.96	5.29	2.69	5.01	2.37	3.94	1.95
R28	7.69	2.58	4.35	2.42	4.01	2.27	4.38	2.11
R29	6.59	1.81	5.71	1.59	5.24	1.48	3.96	1.27
R30	18.77	5.96	15.37	5.07	13.99	4.66	11.39	4.07
R31	9.01	2.69	6.85	2.33	6.14	2.16	5.20	1.87
R32	6.03	2.37	5.13	1.93	5.25	1.83	3.78	1.83
R33	10.11	3.09	9.04	2.97	8.57	2.81	5.19	2.73
R34	21.90	13.76	18.92	14.27	17.89	13.73	17.61	14.46
R35	7.01	2.39	7.04	2.49	6.65	2.39	6.62	2.82
R36	6.64	2.26	5.97	2.36	6.16	2.26	5.47	2.63
R37	13.69	4.34	12.25	3.70	12.61	3.41	10.76	3.35
R38	8.49	4.12	8.04	3.78	7.51	3.52	7.21	3.17

Load	CO, 100% load, diesel		CO, 75% load, diesel		CO, 50% load, diesel		CO, 25% load, diesel	
Units	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 8-hour
R39	7.24	2.75	7.20	2.50	6.80	2.33	6.75	2.23
R40	7.48	1.61	7.73	1.61	7.26	1.52	11.02	1.83
R41	14.10	2.42	8.85	2.34	7.23	2.25	6.28	1.82
R42	9.21	2.61	11.09	2.05	10.76	1.89	12.60	1.93
R43	11.59	2.46	12.66	2.16	12.05	2.04	14.08	1.78
R44	14.65	2.08	15.85	2.27	15.43	2.08	12.77	1.64
R45	15.50	2.21	17.17	2.18	15.93	2.03	9.95	1.66
R46	17.58	3.01	10.25	2.23	8.07	2.12	6.65	1.97
R47	8.51	2.54	8.59	2.45	8.18	2.31	7.61	2.51
R48	9.55	2.78	8.59	2.92	8.14	2.74	10.21	1.96
R49	15.37	4.41	15.82	4.03	14.94	3.85	13.94	3.52
R50	16.94	7.41	15.56	7.69	14.83	7.38	14.15	8.23
R51	22.29	3.45	25.02	4.62	24.06	4.40	23.74	3.97
Max ( $\mu\text{g}\cdot\text{m}^{-3}$ )	34.27	13.76	29.37	14.27	27.04	13.73	23.74	14.46
Criterion <sup>(A)</sup>	31,240 $\mu\text{g}\cdot\text{m}^{-3}$ (31.24 $\text{mg}\cdot\text{m}^{-3}$ )	11,120 $\mu\text{g}\cdot\text{m}^{-3}$ (11.12 $\text{mg}\cdot\text{m}^{-3}$ )	31,240 $\mu\text{g}\cdot\text{m}^{-3}$ (31.24 $\text{mg}\cdot\text{m}^{-3}$ )	11,120 $\mu\text{g}\cdot\text{m}^{-3}$ (11.12 $\text{mg}\cdot\text{m}^{-3}$ )	31,240 $\mu\text{g}\cdot\text{m}^{-3}$ (31.24 $\text{mg}\cdot\text{m}^{-3}$ )	11,120 $\mu\text{g}\cdot\text{m}^{-3}$ (11.12 $\text{mg}\cdot\text{m}^{-3}$ )	31,240 $\mu\text{g}\cdot\text{m}^{-3}$ (31.24 $\text{mg}\cdot\text{m}^{-3}$ )	11,120 $\mu\text{g}\cdot\text{m}^{-3}$ (11.12 $\text{mg}\cdot\text{m}^{-3}$ )
Plotted	No	No	No	No	No	No	No	No

**Note:** (A) The criterion is applicable to the predicted cumulative impact, but has been provided for context.

(B) Exceedence of the criterion is indicated by red highlighting

**Table E-7 Predicted incremental impact, NO<sub>2</sub>, diesel**

Load	NO <sub>x</sub> (as NO <sub>2</sub> ), 100% load, diesel		NO <sub>x</sub> (as NO <sub>2</sub> ), 75% load, diesel		NO <sub>x</sub> (as NO <sub>2</sub> ), 50% load, diesel		NO <sub>x</sub> (as NO <sub>2</sub> ), 25% load, diesel	
	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual
R1	176.04	1.09	163.97	1.01	149.88	0.95	90.17	0.86
R2	178.50	0.97	157.10	0.90	141.93	0.84	94.01	0.75
R3	115.67	0.55	109.96	0.51	99.67	0.48	58.68	0.43
R4	135.96	0.49	111.02	0.46	101.34	0.43	55.61	0.38
R5	134.05	0.47	110.43	0.44	100.96	0.41	54.18	0.36
R6	107.92	0.61	85.92	0.55	67.76	0.52	60.28	0.48
R7	110.07	0.77	69.74	0.69	64.78	0.65	54.53	0.59
R8	114.13	0.94	87.02	0.86	80.37	0.80	64.95	0.72
R9	157.07	1.74	137.94	1.59	128.98	1.49	114.13	1.37
R10	111.61	1.04	82.25	0.95	76.73	0.89	96.76	0.86
R11	102.25	0.89	87.36	0.82	82.01	0.77	92.42	0.75
R12	88.00	0.79	86.31	0.74	88.67	0.69	73.90	0.70
R13	64.56	0.69	93.35	0.65	91.47	0.61	61.84	0.62
R14	74.97	0.67	78.44	0.62	75.88	0.58	69.46	0.58
R15	101.61	0.74	87.92	0.67	80.69	0.63	86.89	0.60
R16	101.60	0.81	84.92	0.73	77.44	0.68	89.67	0.65
R17	108.53	0.91	91.20	0.82	83.99	0.76	78.66	0.71
R18	191.47	1.35	163.71	1.23	151.07	1.14	121.51	1.05
R19	90.01	0.73	67.95	0.65	60.76	0.61	74.77	0.57

Load	NO <sub>x</sub> (as NO <sub>2</sub> ), 100% load, diesel		NO <sub>x</sub> (as NO <sub>2</sub> ), 75% load, diesel		NO <sub>x</sub> (as NO <sub>2</sub> ), 50% load, diesel		NO <sub>x</sub> (as NO <sub>2</sub> ), 25% load, diesel	
Units	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual
R20	131.22	0.78	110.13	0.70	101.38	0.65	85.40	0.60
R21	69.73	0.87	58.70	0.83	54.05	0.78	46.73	0.78
R22	63.27	0.62	52.74	0.57	43.48	0.54	29.84	0.51
R23	33.85	0.45	45.20	0.42	45.52	0.39	32.23	0.36
R24	39.26	0.50	44.21	0.46	42.60	0.43	29.98	0.37
R25	68.01	0.40	33.90	0.35	29.93	0.32	27.99	0.29
R26	59.43	0.39	34.05	0.34	30.96	0.31	28.24	0.28
R27	34.33	0.36	29.54	0.32	27.99	0.30	21.99	0.27
R28	42.98	0.46	24.31	0.42	22.41	0.39	24.45	0.36
R29	36.81	0.45	31.89	0.41	29.29	0.38	22.12	0.34
R30	104.86	0.73	85.80	0.67	78.16	0.63	63.61	0.59
R31	50.36	0.48	38.25	0.43	34.29	0.41	29.03	0.37
R32	33.66	0.44	28.64	0.40	29.34	0.38	21.08	0.33
R33	56.47	0.54	50.46	0.48	47.88	0.44	28.99	0.41
R34	122.34	1.21	105.65	1.18	99.95	1.11	98.33	1.21
R35	39.16	0.52	39.31	0.50	37.13	0.48	36.97	0.50
R36	37.08	0.53	33.32	0.52	34.40	0.50	30.55	0.53
R37	76.48	0.84	68.42	0.76	70.47	0.71	60.05	0.64
R38	47.45	0.59	44.86	0.57	41.97	0.54	40.28	0.55

Load	NO <sub>x</sub> (as NO <sub>2</sub> ), 100% load, diesel		NO <sub>x</sub> (as NO <sub>2</sub> ), 75% load, diesel		NO <sub>x</sub> (as NO <sub>2</sub> ), 50% load, diesel		NO <sub>x</sub> (as NO <sub>2</sub> ), 25% load, diesel	
	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual	µg·m <sup>-3</sup> 1-hour	µg·m <sup>-3</sup> annual
R39	40.47	0.60	40.17	0.55	38.00	0.52	37.67	0.50
R40	41.81	0.43	43.17	0.42	40.57	0.39	61.50	0.41
R41	78.75	0.42	49.40	0.39	40.41	0.36	35.07	0.34
R42	51.46	0.39	61.93	0.36	60.09	0.34	70.37	0.31
R43	64.74	0.39	70.70	0.35	67.30	0.33	78.60	0.30
R44	81.84	0.38	88.50	0.34	86.18	0.32	71.29	0.29
R45	86.58	0.38	95.87	0.34	89.01	0.31	55.58	0.28
R46	98.21	0.45	57.21	0.42	45.08	0.39	37.13	0.37
R47	47.56	0.49	47.98	0.46	45.69	0.43	42.48	0.42
R48	53.36	0.39	47.97	0.35	45.48	0.33	57.01	0.31
R49	85.88	0.78	88.31	0.71	83.46	0.66	77.85	0.61
R50	94.65	0.99	86.90	0.98	82.83	0.93	78.99	1.03
R51	124.56	0.72	139.70	0.67	134.43	0.63	132.57	0.58
Max (µg·m <sup>-3</sup> )	191.47	1.74	163.97	1.59	151.07	1.49	132.57	1.37
Criterion <sup>(A)</sup>	250 µg·m <sup>-3</sup> (0.25 mg·m <sup>-3</sup> )	60 µg·m <sup>-3</sup> (0.06 mg·m <sup>-3</sup> )	250 µg·m <sup>-3</sup> (0.25 mg·m <sup>-3</sup> )	60 µg·m <sup>-3</sup> (0.06 mg·m <sup>-3</sup> )	250 µg·m <sup>-3</sup> (0.25 mg·m <sup>-3</sup> )	60 µg·m <sup>-3</sup> (0.06 mg·m <sup>-3</sup> )	250 µg·m <sup>-3</sup> (0.25 mg·m <sup>-3</sup> )	60 µg·m <sup>-3</sup> (0.06 mg·m <sup>-3</sup> )
Plotted	Yes	Yes	No	No	No	No	No	No

**Note:** (A) The criterion is applicable to the predicted cumulative impact, but has been provided for context. (B) Exceedence of the criterion is indicated by red highlighting (C) Assumes a 100% NO<sub>x</sub> to NO<sub>2</sub> conversion

**Table E-8 Predicted incremental impact, PM10 / PM2.5, diesel**

Load	PM, 100% load, diesel		PM, 75% load, diesel		PM, 50% load, diesel		PM, 25% load, diesel	
	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual
R1	0.48	0.04	0.60	0.04	0.62	0.05	0.61	0.05
R2	0.47	0.04	0.56	0.04	0.57	0.04	0.51	0.05
R3	0.28	0.02	0.32	0.02	0.33	0.02	0.29	0.03
R4	0.32	0.02	0.31	0.02	0.31	0.02	0.33	0.02
R5	0.31	0.02	0.30	0.02	0.30	0.02	0.32	0.02
R6	0.30	0.02	0.33	0.02	0.34	0.02	0.32	0.03
R7	0.28	0.03	0.29	0.03	0.30	0.03	0.34	0.04
R8	0.35	0.03	0.38	0.04	0.39	0.04	0.45	0.05
R9	0.61	0.06	0.63	0.07	0.64	0.07	0.79	0.09
R10	0.40	0.04	0.43	0.04	0.44	0.04	0.54	0.06
R11	0.34	0.03	0.35	0.04	0.36	0.04	0.59	0.05
R12	0.39	0.03	0.50	0.03	0.53	0.03	0.80	0.04
R13	0.45	0.02	0.53	0.03	0.55	0.03	0.74	0.04
R14	0.34	0.02	0.41	0.03	0.42	0.03	0.58	0.04
R15	0.33	0.03	0.27	0.03	0.28	0.03	0.40	0.04
R16	0.35	0.03	0.30	0.03	0.30	0.03	0.40	0.04
R17	0.36	0.03	0.38	0.04	0.38	0.04	0.46	0.05
R18	0.51	0.05	0.54	0.05	0.55	0.05	0.61	0.07
R19	0.32	0.03	0.29	0.03	0.30	0.03	0.52	0.04

Load	PM, 100% load, diesel		PM, 75% load, diesel		PM, 50% load, diesel		PM, 25% load, diesel	
	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual
R20	0.39	0.03	0.41	0.03	0.41	0.03	0.55	0.04
R21	0.70	0.03	0.84	0.04	0.87	0.04	1.29	0.05
R22	0.59	0.02	0.68	0.03	0.70	0.03	0.89	0.03
R23	0.22	0.02	0.24	0.02	0.24	0.02	0.28	0.02
R24	0.17	0.02	0.23	0.02	0.24	0.02	0.30	0.02
R25	0.38	0.01	0.43	0.02	0.44	0.02	0.55	0.02
R26	0.41	0.01	0.45	0.01	0.45	0.01	0.57	0.02
R27	0.25	0.01	0.30	0.01	0.31	0.01	0.45	0.02
R28	0.38	0.02	0.43	0.02	0.44	0.02	0.55	0.02
R29	0.33	0.02	0.35	0.02	0.35	0.02	0.42	0.02
R30	0.64	0.03	0.69	0.03	0.70	0.03	0.80	0.04
R31	0.27	0.02	0.27	0.02	0.28	0.02	0.37	0.02
R32	0.25	0.02	0.24	0.02	0.24	0.02	0.25	0.02
R33	0.28	0.02	0.30	0.02	0.31	0.02	0.39	0.03
R34	0.95	0.04	1.19	0.05	1.25	0.05	1.80	0.08
R35	0.33	0.02	0.41	0.02	0.43	0.02	0.69	0.03
R36	0.32	0.02	0.39	0.02	0.41	0.02	0.59	0.03
R37	0.49	0.03	0.57	0.03	0.58	0.03	0.76	0.04
R38	0.56	0.02	0.62	0.02	0.64	0.03	0.77	0.03



Load	PM, 100% load, diesel		PM, 75% load, diesel		PM, 50% load, diesel		PM, 25% load, diesel	
	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual	$\mu\text{g}\cdot\text{m}^{-3}$ 24-hour	$\mu\text{g}\cdot\text{m}^{-3}$ annual
R39	0.31	0.02	0.36	0.02	0.36	0.02	0.46	0.03
R40	0.19	0.02	0.25	0.02	0.26	0.02	0.43	0.03
R41	0.25	0.02	0.28	0.02	0.29	0.02	0.37	0.02
R42	0.20	0.01	0.20	0.02	0.19	0.02	0.30	0.02
R43	0.19	0.01	0.20	0.02	0.20	0.02	0.32	0.02
R44	0.16	0.01	0.21	0.02	0.21	0.02	0.30	0.02
R45	0.17	0.01	0.21	0.01	0.22	0.02	0.25	0.02
R46	0.25	0.02	0.29	0.02	0.30	0.02	0.40	0.02
R47	0.21	0.02	0.23	0.02	0.24	0.02	0.42	0.03
R48	0.19	0.01	0.24	0.02	0.25	0.02	0.24	0.02
R49	0.37	0.03	0.40	0.03	0.41	0.03	0.48	0.04
R50	0.52	0.04	0.84	0.04	0.93	0.04	2.17	0.07
R51	0.32	0.03	0.45	0.03	0.46	0.03	0.54	0.04
Max ( $\mu\text{g}\cdot\text{m}^{-3}$ )	0.95	0.06	1.19	0.07	1.25	0.07	2.17	0.09
Criterion PM <sub>2.5</sub> <sup>(B)</sup>	25 $\mu\text{g}\cdot\text{m}^{-3}$ (0.025 mg·m <sup>-3</sup> )	8 $\mu\text{g}\cdot\text{m}^{-3}$ (0.008 mg·m <sup>-3</sup> )	25 $\mu\text{g}\cdot\text{m}^{-3}$ (0.025 mg·m <sup>-3</sup> )	8 $\mu\text{g}\cdot\text{m}^{-3}$ (0.008 mg·m <sup>-3</sup> )	25 $\mu\text{g}\cdot\text{m}^{-3}$ (0.025 mg·m <sup>-3</sup> )	8 $\mu\text{g}\cdot\text{m}^{-3}$ (0.008 mg·m <sup>-3</sup> )	25 $\mu\text{g}\cdot\text{m}^{-3}$ (0.025 mg·m <sup>-3</sup> )	8 $\mu\text{g}\cdot\text{m}^{-3}$ (0.008 mg·m <sup>-3</sup> )
Plotted	No	No	No	No	No	No	Yes	Yes

**Note:** (A) The criterion is applicable to the predicted cumulative impact, but has been provided for context.

(B) Exceedence of the criterion is indicated by red highlighting

**Table E-9 Predicted incremental impact, SO<sub>2</sub>, diesel**

Load	SO <sub>2</sub> , 100% load, diesel			SO <sub>2</sub> , 75% load, diesel			SO <sub>2</sub> , 50% load, diesel			SO <sub>2</sub> , 25% load, diesel		
	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann
R1	0.79	0.06	0.00	0.73	0.06	0.00	0.68	0.06	0.00	0.41	0.04	0.00
R2	0.80	0.06	0.00	0.70	0.06	0.00	0.65	0.05	0.00	0.43	0.04	0.00
R3	0.52	0.03	0.00	0.49	0.03	0.00	0.45	0.03	0.00	0.27	0.02	0.00
R4	0.61	0.04	0.00	0.50	0.03	0.00	0.46	0.03	0.00	0.25	0.02	0.00
R5	0.60	0.04	0.00	0.49	0.03	0.00	0.46	0.03	0.00	0.25	0.02	0.00
R6	0.48	0.04	0.00	0.38	0.03	0.00	0.31	0.03	0.00	0.28	0.02	0.00
R7	0.49	0.03	0.00	0.31	0.03	0.00	0.30	0.03	0.00	0.25	0.02	0.00
R8	0.51	0.04	0.00	0.39	0.04	0.00	0.37	0.04	0.00	0.30	0.03	0.00
R9	0.70	0.07	0.01	0.62	0.06	0.01	0.59	0.06	0.01	0.52	0.06	0.01
R10	0.50	0.05	0.00	0.37	0.04	0.00	0.35	0.04	0.00	0.44	0.04	0.00
R11	0.46	0.04	0.00	0.39	0.04	0.00	0.37	0.03	0.00	0.42	0.04	0.00
R12	0.39	0.05	0.00	0.39	0.05	0.00	0.40	0.05	0.00	0.34	0.06	0.00
R13	0.29	0.06	0.00	0.42	0.05	0.00	0.42	0.05	0.00	0.28	0.05	0.00
R14	0.34	0.04	0.00	0.35	0.04	0.00	0.35	0.04	0.00	0.32	0.04	0.00
R15	0.45	0.04	0.00	0.39	0.03	0.00	0.37	0.03	0.00	0.40	0.03	0.00
R16	0.45	0.04	0.00	0.38	0.03	0.00	0.35	0.03	0.00	0.41	0.03	0.00
R17	0.49	0.05	0.00	0.41	0.04	0.00	0.38	0.04	0.00	0.36	0.03	0.00
R18	0.86	0.06	0.01	0.73	0.06	0.01	0.69	0.05	0.01	0.55	0.04	0.00
R19	0.40	0.04	0.00	0.30	0.03	0.00	0.28	0.03	0.00	0.34	0.04	0.00

Load	SO <sub>2</sub> , 100% load, diesel			SO <sub>2</sub> , 75% load, diesel			SO <sub>2</sub> , 50% load, diesel			SO <sub>2</sub> , 25% load, diesel		
Units	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann
R20	0.59	0.05	0.00	0.49	0.04	0.00	0.46	0.04	0.00	0.39	0.04	0.00
R21	0.31	0.09	0.00	0.26	0.09	0.00	0.25	0.08	0.00	0.21	0.09	0.00
R22	0.28	0.07	0.00	0.24	0.07	0.00	0.20	0.07	0.00	0.14	0.06	0.00
R23	0.15	0.03	0.00	0.20	0.02	0.00	0.21	0.02	0.00	0.15	0.02	0.00
R24	0.18	0.02	0.00	0.20	0.02	0.00	0.19	0.02	0.00	0.14	0.02	0.00
R25	0.30	0.05	0.00	0.15	0.04	0.00	0.14	0.04	0.00	0.13	0.04	0.00
R26	0.27	0.05	0.00	0.15	0.05	0.00	0.14	0.04	0.00	0.13	0.04	0.00
R27	0.15	0.03	0.00	0.13	0.03	0.00	0.13	0.03	0.00	0.10	0.03	0.00
R28	0.19	0.05	0.00	0.11	0.04	0.00	0.10	0.04	0.00	0.11	0.04	0.00
R29	0.16	0.04	0.00	0.14	0.04	0.00	0.13	0.03	0.00	0.10	0.03	0.00
R30	0.47	0.08	0.00	0.38	0.07	0.00	0.36	0.07	0.00	0.29	0.06	0.00
R31	0.23	0.03	0.00	0.17	0.03	0.00	0.16	0.03	0.00	0.13	0.03	0.00
R32	0.15	0.03	0.00	0.13	0.02	0.00	0.13	0.02	0.00	0.10	0.02	0.00
R33	0.25	0.03	0.00	0.23	0.03	0.00	0.22	0.03	0.00	0.13	0.03	0.00
R34	0.55	0.12	0.01	0.47	0.12	0.01	0.46	0.12	0.01	0.45	0.13	0.01
R35	0.18	0.04	0.00	0.18	0.04	0.00	0.17	0.04	0.00	0.17	0.05	0.00
R36	0.17	0.04	0.00	0.15	0.04	0.00	0.16	0.04	0.00	0.14	0.04	0.00
R37	0.34	0.06	0.00	0.31	0.06	0.00	0.32	0.06	0.00	0.27	0.05	0.00
R38	0.21	0.07	0.00	0.20	0.06	0.00	0.19	0.06	0.00	0.18	0.06	0.00

Load	SO <sub>2</sub> , 100% load, diesel			SO <sub>2</sub> , 75% load, diesel			SO <sub>2</sub> , 50% load, diesel			SO <sub>2</sub> , 25% load, diesel		
Units	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann	µg·m <sup>-3</sup> 1h	µg·m <sup>-3</sup> 24h	µg·m <sup>-3</sup> ann
R39	0.18	0.04	0.00	0.18	0.04	0.00	0.17	0.03	0.00	0.17	0.03	0.00
R40	0.19	0.02	0.00	0.19	0.03	0.00	0.19	0.03	0.00	0.28	0.03	0.00
R41	0.35	0.03	0.00	0.22	0.03	0.00	0.18	0.03	0.00	0.16	0.03	0.00
R42	0.23	0.03	0.00	0.28	0.02	0.00	0.27	0.02	0.00	0.32	0.02	0.00
R43	0.29	0.02	0.00	0.32	0.02	0.00	0.31	0.02	0.00	0.36	0.02	0.00
R44	0.37	0.02	0.00	0.40	0.02	0.00	0.39	0.02	0.00	0.33	0.02	0.00
R45	0.39	0.02	0.00	0.43	0.02	0.00	0.41	0.02	0.00	0.25	0.02	0.00
R46	0.44	0.03	0.00	0.26	0.03	0.00	0.21	0.03	0.00	0.17	0.03	0.00
R47	0.21	0.03	0.00	0.21	0.02	0.00	0.21	0.02	0.00	0.19	0.03	0.00
R48	0.24	0.02	0.00	0.21	0.02	0.00	0.21	0.02	0.00	0.26	0.02	0.00
R49	0.38	0.05	0.00	0.39	0.04	0.00	0.38	0.04	0.00	0.36	0.03	0.00
R50	0.42	0.06	0.00	0.39	0.09	0.00	0.38	0.09	0.00	0.36	0.16	0.00
R51	0.56	0.04	0.00	0.62	0.05	0.00	0.61	0.04	0.00	0.60	0.04	0.00
Max (µg·m <sup>-3</sup> )	0.86	0.12	0.01	0.73	0.12	0.01	0.69	0.12	0.01	0.60	0.16	0.01
Criterion <sup>(A)</sup>	570 µg·m <sup>-3</sup> 0.57 mg·m <sup>-3</sup>	230 µg·m <sup>-3</sup> 0.23 mg·m <sup>-3</sup>	60 µg·m <sup>-3</sup> 0.06 mg·m <sup>-3</sup>	570 µg·m <sup>-3</sup> 0.57 mg·m <sup>-3</sup>	230 µg·m <sup>-3</sup> 0.23 mg·m <sup>-3</sup>	60 µg·m <sup>-3</sup> 0.06 mg·m <sup>-3</sup>	570 µg·m <sup>-3</sup> 0.57 mg·m <sup>-3</sup>	230 µg·m <sup>-3</sup> 0.23 mg·m <sup>-3</sup>	60 µg·m <sup>-3</sup> 0.06 mg·m <sup>-3</sup>	570 µg·m <sup>-3</sup> 0.57 mg·m <sup>-3</sup>	230 µg·m <sup>-3</sup> 0.23 mg·m <sup>-3</sup>	60 µg·m <sup>-3</sup> 0.06 mg·m <sup>-3</sup>
Plotted	No	No	No	No	No	No	No	No	No	No	No	No

**Note:** (A) The criterion is applicable to the predicted cumulative impact, but has been provided for context.

(B) Exceedence of the criterion is indicated by **red highlighting**

**Table E-10 Predicted incremental impact, formaldehyde, diesel**

Load	Formaldehyde, 100% load, diesel		Formaldehyde, 75% load, diesel		Formaldehyde, 50% load, diesel		Formaldehyde, 25% load, diesel	
	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min
R1	0.11	0.19	0.10	0.19	0.11	0.20	0.08	0.14
R2	0.11	0.20	0.10	0.18	0.10	0.19	0.08	0.15
R3	0.07	0.13	0.07	0.13	0.07	0.13	0.05	0.09
R4	0.08	0.15	0.07	0.13	0.07	0.14	0.05	0.09
R5	0.08	0.15	0.07	0.13	0.07	0.13	0.05	0.08
R6	0.06	0.12	0.05	0.10	0.05	0.09	0.05	0.09
R7	0.07	0.12	0.04	0.08	0.05	0.09	0.05	0.09
R8	0.07	0.13	0.06	0.10	0.06	0.11	0.06	0.10
R9	0.09	0.17	0.09	0.16	0.09	0.17	0.10	0.18
R10	0.07	0.12	0.05	0.10	0.06	0.10	0.08	0.15
R11	0.06	0.11	0.06	0.10	0.06	0.11	0.08	0.14
R12	0.05	0.10	0.05	0.10	0.06	0.12	0.06	0.12
R13	0.04	0.07	0.06	0.11	0.07	0.12	0.05	0.10
R14	0.05	0.08	0.05	0.09	0.06	0.10	0.06	0.11
R15	0.06	0.11	0.06	0.10	0.06	0.11	0.07	0.14
R16	0.06	0.11	0.05	0.10	0.06	0.10	0.08	0.14
R17	0.07	0.12	0.06	0.11	0.06	0.11	0.07	0.12
R18	0.12	0.21	0.10	0.19	0.11	0.20	0.10	0.19
R19	0.05	0.10	0.04	0.08	0.04	0.08	0.06	0.12


Load	Formaldehyde, 100% load, diesel		Formaldehyde, 75% load, diesel		Formaldehyde, 50% load, diesel		Formaldehyde, 25% load, diesel	
Units	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min
R20	0.08	0.14	0.07	0.13	0.07	0.14	0.07	0.13
R21	0.04	0.08	0.04	0.07	0.04	0.07	0.04	0.07
R22	0.04	0.07	0.03	0.06	0.03	0.06	0.03	0.05
R23	0.02	0.04	0.03	0.05	0.03	0.06	0.03	0.05
R24	0.02	0.04	0.03	0.05	0.03	0.06	0.03	0.05
R25	0.04	0.07	0.02	0.04	0.02	0.04	0.02	0.04
R26	0.04	0.07	0.02	0.04	0.02	0.04	0.02	0.04
R27	0.02	0.04	0.02	0.03	0.02	0.04	0.02	0.03
R28	0.03	0.05	0.02	0.03	0.02	0.03	0.02	0.04
R29	0.02	0.04	0.02	0.04	0.02	0.04	0.02	0.03
R30	0.06	0.11	0.05	0.10	0.06	0.10	0.05	0.10
R31	0.03	0.06	0.02	0.04	0.03	0.05	0.02	0.05
R32	0.02	0.04	0.02	0.03	0.02	0.04	0.02	0.03
R33	0.03	0.06	0.03	0.06	0.04	0.06	0.02	0.05
R34	0.07	0.13	0.07	0.12	0.07	0.13	0.08	0.15
R35	0.02	0.04	0.03	0.05	0.03	0.05	0.03	0.06
R36	0.02	0.04	0.02	0.04	0.03	0.05	0.03	0.05
R37	0.05	0.08	0.04	0.08	0.05	0.09	0.05	0.09
R38	0.03	0.05	0.03	0.05	0.03	0.06	0.03	0.06

Load	Formaldehyde, 100% load, diesel		Formaldehyde, 75% load, diesel		Formaldehyde, 50% load, diesel		Formaldehyde, 25% load, diesel	
Units	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min	$\mu\text{g}\cdot\text{m}^{-3}$ 1-hour	$\mu\text{g}\cdot\text{m}^{-3}$ 3-min
R39	0.02	0.04	0.03	0.05	0.03	0.05	0.03	0.06
R40	0.03	0.05	0.03	0.05	0.03	0.05	0.05	0.10
R41	0.05	0.09	0.03	0.06	0.03	0.05	0.03	0.05
R42	0.03	0.06	0.04	0.07	0.04	0.08	0.06	0.11
R43	0.04	0.07	0.05	0.08	0.05	0.09	0.07	0.12
R44	0.05	0.09	0.06	0.10	0.06	0.11	0.06	0.11
R45	0.05	0.09	0.06	0.11	0.07	0.12	0.05	0.09
R46	0.06	0.11	0.04	0.07	0.03	0.06	0.03	0.06
R47	0.03	0.05	0.03	0.06	0.03	0.06	0.04	0.07
R48	0.03	0.06	0.03	0.06	0.03	0.06	0.05	0.09
R49	0.05	0.09	0.06	0.10	0.06	0.11	0.07	0.12
R50	0.06	0.10	0.06	0.10	0.06	0.11	0.07	0.12
R51	0.07	0.14	0.09	0.16	0.10	0.18	0.11	0.21
Max ( $\mu\text{g}\cdot\text{m}^{-3}$ )	0.12	0.21	0.10	0.19	0.11	0.20	0.11	0.21
Criterion <sup>(A)</sup>	-	44 $\mu\text{g}\cdot\text{m}^{-3}$ (0.044 $\text{mg}\cdot\text{m}^{-3}$ )	-	44 $\mu\text{g}\cdot\text{m}^{-3}$ (0.044 $\text{mg}\cdot\text{m}^{-3}$ )	-	44 $\mu\text{g}\cdot\text{m}^{-3}$ (0.044 $\text{mg}\cdot\text{m}^{-3}$ )	-	44 $\mu\text{g}\cdot\text{m}^{-3}$ (0.044 $\text{mg}\cdot\text{m}^{-3}$ )
Plotted	No	No	No	No	No	No	No	No

**Note:** (A) The criterion is applicable to the predicted cumulative impact as a 3-minute average, but has been provided for context. This has been converted using the method outlined in **Section 4.2.6**

(B) Exceedence of the criterion is indicated by **red highlighting**


Figure E-1 Predicted incremental impact, NO<sub>x</sub> (as NO<sub>2</sub>), 1-hour, 100%, gas



Source: Northstar Air Quality. | Note: Please note that the scale and scale bar used to depict the concentrations may not be linear, and care must be applied when interpreting the illustrated values.




Figure E-2 Predicted incremental impact, NO<sub>x</sub> (as NO<sub>2</sub>), annual average, 100%, gas




Source: Northstar Air Quality. | Note: Please note that the scale and scale bar used to depict the concentrations may not be linear, and care must be applied when interpreting the illustrated values.

Figure E-3 Predicted incremental impact, PM, 24-hour, 25%, gas




Source: Northstar Air Quality. | Note: Please note that the scale and scale bar used to depict the concentrations may not be linear, and care must be applied when interpreting the illustrated values.

Figure E-4 Predicted incremental impact, PM, annual average, 25%, gas




Source: Northstar Air Quality. | Note: Please note that the scale and scale bar used to depict the concentrations may not be linear, and care must be applied when interpreting the illustrated values.

Figure E-5 Predicted incremental impact, SO<sub>2</sub>, 1-hour, 100%, gas




Source: Northstar Air Quality. | Note: Please note that the scale and scale bar used to depict the concentrations may not be linear, and care must be applied when interpreting the illustrated values.

Figure E-6 Predicted incremental impact, SO<sub>2</sub> 24-hour, 25%, gas




Source: Northstar Air Quality. | Note: Please note that the scale and scale bar used to depict the concentrations may not be linear, and care must be applied when interpreting the illustrated values.

Figure E-7 Predicted incremental impact, CH<sub>2</sub>O, 3-minute, 75%, gas




Source: Northstar Air Quality. | Note: Please note that the scale and scale bar used to depict the concentrations may not be linear, and care must be applied when interpreting the illustrated values.

Figure E-8 Predicted incremental impact, NO<sub>x</sub> (as NO<sub>2</sub>), 1-hour, 100%, diesel



Source: Northstar Air Quality. | Note: Please note that the scale and scale bar used to depict the concentrations may not be linear, and care must be applied when interpreting the illustrated values.


Figure E-9 Predicted incremental impact, NO<sub>x</sub> (as NO<sub>2</sub>), annual average, 100%, diesel



Source: Northstar Air Quality. | Note: Please note that the scale and scale bar used to depict the concentrations may not be linear, and care must be applied when interpreting the illustrated values.




Figure E-10 Predicted incremental impact, PM, 24-hour, 25%, diesel



Source: Northstar Air Quality. | Note: Please note that the scale and scale bar used to depict the concentrations may not be linear, and care must be applied when interpreting the illustrated values.

Figure E-11 Predicted incremental impact, PM, annual average, 25%, diesel



Source: Northstar Air Quality. | Note: Please note that the scale and scale bar used to depict the concentrations may not be linear, and care must be applied when interpreting the illustrated values.

## APPENDIX F

### Product Specifications and Drawings

**NOTES:**

1. TOLERANCE ON FLANGE CONNECTIONS  $\pm 1/8"$  [3]  
TOLERANCE ON ELECTRICAL CONNECTIONS  $\pm 1/8"$  [3]  
TOLERANCE ON BOLT HOLES  $\pm 1/16"$  [2] TRUE POSITION
2. DIMENSIONS AND VALUES IN [ ] ARE SI UNITS AND ARE GIVEN FOR REFERENCE ONLY. EQUIPMENT SHALL BE DESIGNED AND MANUFACTURED USING U.S. CUSTOMARY UNITS.
3. ADDITIONAL EXTERIOR LIGHTING TO BE SUPPLIED BY CUSTOMER.
4. MAXIMUM LOAD ON EACH ENGINE REMOVAL FOOT PAD IS 12,000 LBS [5443 kg], (24000 LBS [10886 kg] TOTAL ENGINE REMOVAL LOAD). MAXIMUM LOAD ON EACH GEARBOX REMOVAL PAD IS 28,000 LBS [12700 kg].
5. AUXILIARY SKID & FIRE PROTECTION SKID FOUNDATIONS MUST BE AT THE SAME ELEVATION AS THE MAIN SKID FOUNDATION.
6. CUSTOMER DRAWING NUMBERS CONSIST OF: (ORDER NUMBER)-(STANDARD DRAWING NUMBER), AND ARE REFERENCED AS X-(STANDARD DRAWING NUMBER), WHERE X = ORDER NUMBER.
7. PIPING AND/OR TUBING MATERIAL SPECIFICATION LISTED IN CONNECTION LEGEND SHALL BE USED BY CUSTOMER AS A RECOMMENDATION IN DESIGN OF THEIR PLANT INTERCONNECT PIPING SYSTEM.
8. MLO SKID FOUNDATION MUST BE 1' - 2" [356] LOWER THAN MAIN UNIT
9. AIR FILTER SHOWN AS REFERENCE, FOR ACTUAL CONFIGURATION SEE GA AIR FILTER DRAWING/SUPPLIER DRAWING
10. AUXILIARY SKID CONFIGURATIONS ARE LOCATED IN X-504218.
11. PRECAUTION MUST BE TAKEN WHEN OPENING ENGINE REMOVAL DOORS TO AVOID SURROUNDING EQUIPMENT DAMAGE.


**SAFETY NOTE: CAUTION**

1. GEPLP SHALL NOT BE LIABLE FOR DAMAGE CAUSED BY EXCESSIVE FLANGE LOADS OR INADEQUATE EXPANSION JOINT DESIGN. FAILURE TO PROVIDE FOR ADEQUATE THERMAL EXPANSION OR EXCEEDING ALLOWABLE FLANGE LOADS MAY RESULT IN DAMAGE TO OR DESTRUCTION OF FASTENERS AND ENGINE/EXHAUST SYSTEM RELATED HARDWARE RESULTING IN EXHAUST LEAKS AND ACCELERATED WEAR ON THE EXHAUST DIFFUSER ASSEMBLY. IT IS THE CUSTOMER'S RESPONSIBILITY TO ALLOW A CONSERVATIVE AMOUNT OF EXPANSION CAPABILITY TO ACCOMMODATE INSTALLATION ERRORS AND TOLERANCE STACK-UPS FOR THE COMPLETE EXHAUST SYSTEM.

2. IN THE REMOTE CHANCE OF A HP ROTOR FAILURE THE ENGINE CASING MAY NOT CONTAIN THE ENTIRE FAILURE. IT IS HIGHLY RECOMMENDED THAT NO PERMANENTLY MANNED SPACES BE LOCATED IN THE PLANE OF THE HP TURBINE. IT IS ALSO HIGHLY RECOMMENDED THAT ALL POTENTIALLY HAZARDOUS LINES (i.e. FUEL) OR EQUIPMENT (i.e. SHUTOFF VALVES, CONTROL VALVES) ALSO BE LOCATED OUTSIDE THE PLANE OF THE HP TURBINE.

**REFERENCE DRAWINGS:**

- X-504204 GENERAL ARRANGEMENT, AIR FILTER
- X-504218 GENERAL ARRANGEMENT, AUXILIARY SKID
- X-504221 GENERAL ARRANGEMENT, GENERATOR/GEARBOX MINERAL LUBE OIL SKID



PLAN VIEW

50Hz PF

"0" DATUM - ALL TAIL DIMENSIONS ARE TAKEN FROM GENERATOR END OF SKID

RESERVED

© COPYRIGHT 2017 GENERAL ELECTRIC COMPANY (USA). ALL RIGHTS RESERVED. THE INFORMATION HEREIN IS PROPRIETARY AND TECHNICALLY EXCLUSIVE CONTENT THAT IS SOLELY OWNED BY GENERAL ELECTRIC COMPANY AND/OR ITS AFFILIATES. THIS IS BEING PROVIDED WITH THE EXPLICIT EXPECTATION OF RESTRICTED AND PRIVILEGED USE. ALL PERSONS, OR LEGAL ENTITIES RECEIVING THIS INFORMATION SHALL BE DEEMED BY THE ACT OF ITS RECEIPT TO HAVE CONTRACTUALLY AGREED TO MAKE NO DUPLICATIONS, REPRODUCTIONS OF ANY NATURE BY ANY MEANS, MODIFICATIONS, DISCLOSURES, OR USE ANY PORTION OF THIS MATERIAL, EXCEPT AS IS EXPRESSLY AUTHORIZED IN WRITING BY GENERAL ELECTRIC COMPANY AND/OR ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN	UNIT TYPE
F	UPDATED COPYRIGHT		MR	02/16/17	EN	
E	NO CHANGES THIS SHEET		MR	12/14/16	EN	
D	UPDATED LINE SIDE CUBICLE		MR	11/04/16	EN	
C	UPDATED LINE SIDE CUBICLE TO RH		MR	08/18/16	EN	
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ	
A	ORIGINAL ISSUE		SK	10/28/15	ZJ	

THIRD ANGLE PROJECTION


UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES DO NOT SCALE DRAWING

TOLERANCES  
DECIMALS .XX ± .03  
FRACTIONAL ± 1/8"  
ANGULAR ± 1°

NEXT ASSY.

LM6000®

ADDL INFO		GE CLASS II (INTERNAL)	
GE P&W DISTRIBUTED POWER			
TITLE			
GENERAL ARRANGEMENT MAIN UNIT - RH			
TWP NO.			REV.
7262875-504200			F
SCALE 1/4" = 1'-0"			SHEET 1 OF 17



PLAN VIEW  
AIR FILTER, INTERCONNECT PLATFORM & SKIDS  
REMOVED FOR CLARITY

50Hz PF

RESERVED

DETAIL A  
SEE SHEET 11

3"  
[76] COLD  
3 1/4" [83] HOT  
EXHAUST FLANGE

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN	UNIT TYPE
F	UPDATED COPYRIGHT		MR	02/16/17	EN	
E	ADDED MOT-4017A/B AND MOT-4103A/B TAG		MR	12/14/16	EN	
D	UPDATED DIMENSION AT ZONE B5 AND B6		MR	11/04/16	EN	
C	UPDATED LINE SIDE CUBICLE TO RH		MR	08/18/16	EN	
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ	
A	ORIGINAL ISSUE		SK	10/28/15	ZJ	

THIRD ANGLE  
PROJECTION

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES  
DO NOT SCALE DRAWING

TOLERANCES  
DECIMALS FRACTIONAL ANGULAR  
.XX ± .03 ± 1/8" ± 1°  
.XXX ± .010

TEXT ASSY.

LM6000®

ADDL INFO  
GE CLASS II (INTERNAL)

GE P&W DISTRIBUTED POWER


TITLE  
GENERAL ARRANGEMENT  
MAIN UNIT - RH

REV. F

FIG. NO. 7262875-504200

SCALE 1/4" = 1'-0"

SHEET 2 OF 17



LEFT SIDE ELEVATION  
FIRE PROTECTION SKID NOT SHOWN FOR CLAIRTY

50Hz PF

RESERVED

"0" DATUM  
ALL ELEVATION  
DIMENSIONS ARE  
TAKEN FROM  
BOTTOM OF SKID

© COPYRIGHT 2017  
GENERAL ELECTRIC COMPANY (USA).  
ALL RIGHTS RESERVED. THE  
INFORMATION HEREIN IS PROPRIETARY  
AND TECHNICALLY EXCLUSIVE CONTENT  
THAT IS SOLELY OWNED BY GENERAL  
ELECTRIC COMPANY AND/OR ITS  
AFFILIATES. THIS IS BEING PROVIDED  
WITH THE EXPLICIT EXPECTATION OF  
RESTRICTED AND PRIVILEGED USE. ALL  
PERSONS, OR LEGAL ENTITIES RECEIVING  
THIS INFORMATION SHALL BE DEEMED  
BY THE ACT OF ITS RECEIPT TO HAVE  
CONTRACTUALLY AGREED TO MAKE NO  
DUPLICATIONS, REPRODUCTIONS OF ANY  
NATURE BY ANY MEANS, MODIFICATIONS,  
DISCLOSURES, OR USE ANY PORTION OF  
THIS MATERIAL, EXCEPT AS IS  
EXPRESSLY AUTHORIZED IN WRITING BY  
GENERAL ELECTRIC COMPANY AND/OR  
ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN	UNIT TYPE
F	UPDATED COPYRIGHT		MR	02/16/17	EN	
E	NO CHANGES THIS SHEET		MR	12/14/16	EN	
D	NO CHANGES THIS SHEET		MR	11/04/16	EN	
C	UPDATED TO NEUTRAL SIDE CUBICLE		MR	08/18/16	EN	
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ	
A	ORIGINAL ISSUE		SK	10/28/15	ZJ	
REVISIONS						

THIRD ANGLE  
PROJECTION

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES  
DO NOT SCALE DRAWING

TOLERANCES  
DECIMALS FRACTIONAL ANGULAR  
.XX ± .03 ± 1/8" ± 1°  
.XXX ± .010

TEXT ASSY.

LM6000

ADDL INFO GE CLASS II (INTERNAL)

GE P&W DISTRIBUTED POWER


TITLE GENERAL ARRANGEMENT  
MAIN UNIT - RH

REV. F

DWG NO. 7262875-504200

SCALE 1/4" = 1'-0"

SHEET 3 OF 17



RIGHT SIDE ELEVATION

50Hz PF


RESERVED

© COPYRIGHT 2017  
 GENERAL ELECTRIC COMPANY (USA).  
 ALL RIGHTS RESERVED. THE  
 INFORMATION HEREIN IS PROPRIETARY  
 AND TECHNICALLY EXCLUSIVE CONTENT  
 THAT IS SOLELY OWNED BY GENERAL  
 ELECTRIC COMPANY AND/OR ITS  
 AFFILIATES. THIS IS BEING PROVIDED  
 WITH THE EXPLICIT EXPECTATION OF  
 RESTRICTED AND PRIVILEGED USE. ALL  
 PERSONS, OR LEGAL ENTITIES RECEIVING  
 THIS INFORMATION SHALL BE DEEMED  
 BY THE ACT OF ITS RECEIPT TO HAVE  
 CONTRACTUALLY AGREED TO MAKE NO  
 DUPLICATIONS, REPRODUCTIONS OF ANY  
 NATURE BY ANY MEANS, MODIFICATIONS,  
 DISCLOSURES, OR USE ANY PORTION OF  
 THIS MATERIAL, EXCEPT AS IS  
 EXPRESSLY AUTHORIZED IN WRITING BY  
 GENERAL ELECTRIC COMPANY AND/OR  
 ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN	UNIT TYPE
F	ADDED DIMENSION DETAILS AT ZONE B2 & B3		MR	02/16/17	EN	
E	ADDED MOT-1083 TAG NUMBER		MR	12/14/16	EN	
D	NO CHANGES THIS SHEET		MR	11/04/16	EN	
C	UPDATED VIEW AUXILIARY AND MLO SKID		MR	08/18/16	EN	
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ	
A	ORIGINAL ISSUE		SK	10/28/15	ZJ	
REVISIONS						

THIRD ANGLE PROJECTION	
UNLESS OTHERWISE SPECIFIED, DIMENSIONS ARE IN INCHES. DO NOT SCALE DRAWING.	
DECIMALS	FRACTIONAL
.XX ± .03	± 1/8"
.XXX ± .010	± 1"
NEXT ASSY.	
LM6000	

ADDL INFO		GE CLASS II (INTERNAL)	
GE P&W DISTRIBUTED POWER			
TITLE			
GENERAL ARRANGEMENT MAIN UNIT - RH			
DWG NO.			REV.
7262875-504200			F
SCALE 1/4" = 1'-0"			SHEET 4 OF 17



EXHAUST END VIEW  
SOME SKIDS NOT SHOWN FOR CLARITY

GENERATOR END VIEW  
SOME SKIDS & INTERCONNECT PLATFORM NOT SHOWN FOR CLARITY

50Hz PF

RESERVED

© COPYRIGHT 2017  
GENERAL ELECTRIC COMPANY (USA).  
ALL RIGHTS RESERVED. THE  
INFORMATION HEREIN IS PROPRIETARY  
AND TECHNICALLY EXCLUSIVE CONTENT  
THAT IS SOLELY OWNED BY GENERAL  
ELECTRIC COMPANY AND/OR ITS  
AFFILIATES. THIS IS BEING PROVIDED  
WITH THE EXPLICIT EXPECTATION OF  
RESTRICTED AND PRIVILEGED USE. ALL  
PERSONS, OR LEGAL ENTITIES RECEIVING  
THIS INFORMATION SHALL BE DEEMED  
BY THE ACT OF ITS RECEIPT TO HAVE  
CONTRACTUALLY AGREED TO MAKE NO  
DUPLICATIONS, REPRODUCTIONS OF ANY  
NATURE BY ANY MEANS, MODIFICATIONS,  
DISCLOSURES, OR USE ANY PORTION OF  
THIS MATERIAL, EXCEPT AS IS  
EXPRESSLY AUTHORIZED IN WRITING BY  
GENERAL ELECTRIC COMPANY AND/OR  
ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN	UNIT TYPE
F	UPDATED COPYRIGHT		MR	02/16/17	EN	
E	NO CHANGES THIS SHEET		MR	12/14/16	EN	
D	NO CHANGES THIS SHEET		MR	11/04/16	EN	
C	UPDATED VIEW		MR	08/18/16	EN	
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ	
A	ORIGINAL ISSUE		SK	10/28/15	ZJ	
REVISIONS						

THIRD ANGLE  
PROJECTION

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES  
DO NOT SCALE DRAWING

TOLERANCES  
DECIMALS FRACTIONAL ANGULAR  
.XX ± .03 ± 1/8" ± 1°  
.XXX ± .010

LM6000®

ADDL INFO GE CLASS II (INTERNAL)

**GE P&W DISTRIBUTED POWER**

TITLE  
GENERAL ARRANGEMENT  
MAIN UNIT - RH


TWG NO. 7262875-504200

REV. F

SCALE 1/4" = 1'-0"

SHEET 5 OF 17





VIEW FROM EXHAUST END  
AIR FILTER, INTERCONNECT PLATFORM & SKIDS  
REMOVED FOR CLARITY

VIEW FROM GENERATOR END  
AIR FILTER, GENERATOR EXHAUST, INTERCONNECT  
PLATFORM & SKIDS REMOVED FOR CLARITY

RESERVED

© COPYRIGHT 2017  
GENERAL ELECTRIC COMPANY (USA).  
ALL RIGHTS RESERVED. THE  
INFORMATION HEREIN IS PROPRIETARY  
AND TECHNICALLY EXCLUSIVE CONTENT  
THAT IS SOLELY OWNED BY GENERAL  
ELECTRIC COMPANY AND/OR ITS  
AFFILIATES. THIS INFORMATION SHALL BE  
DEEMED TO BE CONFIDENTIAL AND  
RESTRICTED AND PRIVILEGED USE. ALL  
PERSONS, OR LEGAL ENTITIES RECEIVING  
THIS INFORMATION SHALL BE DEEMED  
BY THE ACT OF ITS RECEIPT TO HAVE  
CONTRACTUALLY AGREED TO MAKE NO  
DUPLICATIONS, REPRODUCTIONS OF ANY  
NATURE BY ANY MEANS, MODIFICATIONS,  
DISCLOSURES, OR USE ANY PORTION OF  
THIS MATERIAL, EXCEPT AS IS  
EXPRESSLY AUTHORIZED IN WRITING BY  
GENERAL ELECTRIC COMPANY AND/OR  
ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN	UNIT TYPE
F	UPDATED COPYRIGHT		MR	02/16/17	EN	
E	NO CHANGES THIS SHEET		MR	12/14/16	EN	
D	NO CHANGES THIS SHEET		MR	11/04/16	EN	
C	UPDATED LINE SIDE CUBICLE TO RH SIDE		MR	08/18/16	EN	
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ	
A	ORIGINAL ISSUE		SK	10/28/15	ZJ	
REVISIONS						

THIRD ANGLE PROJECTION

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES  
DO NOT SCALE DRAWING

TOLERANCES  
DECIMALS FRACTIONAL ANGULAR  
.XX ± .03 ± 1/8" ± 1°  
.XXX ± .010

TEXT ASSY.

LM6000

ADDL INFO GE CLASS II (INTERNAL)

GE P&W DISTRIBUTED POWER


TITLE GENERAL ARRANGEMENT  
MAIN UNIT - RH

DWG NO. 7262875-504200

REV. F

SCALE 1/4" = 1'-0"

SHEET 6 OF 17



RESERVED

© COPYRIGHT 2017  
 GENERAL ELECTRIC COMPANY (USA).  
 ALL RIGHTS RESERVED. THE  
 INFORMATION HEREIN IS PROPRIETARY  
 AND TECHNICALLY EXCLUSIVE CONTENT  
 THAT IS SOLELY OWNED BY GENERAL  
 ELECTRIC COMPANY AND/OR ITS  
 AFFILIATES. THIS IS BEING PROVIDED  
 WITH THE EXPLICIT EXPECTATION OF  
 RESTRICTED AND PRIVILEGED USE. ALL  
 PERSONS, OR LEGAL ENTITIES RECEIVING  
 THIS INFORMATION SHALL BE DEEMED  
 BY THE ACT OF ITS RECEIPT TO HAVE  
 CONTRACTUALLY AGREED TO MAKE NO  
 DUPLICATIONS, REPRODUCTIONS OF ANY  
 NATURE BY ANY MEANS, MODIFICATIONS,  
 DISCLOSURES, OR USE ANY PORTION OF  
 THIS MATERIAL, EXCEPT AS IS  
 EXPRESSLY AUTHORIZED IN WRITING BY  
 GENERAL ELECTRIC COMPANY AND/OR  
 ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN
F	UPDATED COPYRIGHT		MR	02/16/17	EN
E	NO CHANGES THIS SHEET		MR	12/14/16	EN
D	UPDATED DIMENSION AT ZONE B6		MR	11/04/16	EN
C	UPDATED VIEW		MR	08/18/16	EN
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ
A	ORIGINAL ISSUE		SK	10/28/15	ZJ

THIRD ANGLE PROJECTION

UNLESS OTHERWISE SPECIFIED  
 DIMENSIONS ARE IN INCHES  
 DO NOT SCALE DRAWING

TOLERANCES  
 DECIMALS FRACTIONAL ANGULAR  
 .XX ± .03 ± 1/8" ± 1°  
 .XXX ± .010

TEXT ASSY.

LM6000®

ADDL INFO GE CLASS II (INTERNAL)

GE P&W DISTRIBUTED POWER


TITLE GENERAL ARRANGEMENT  
 MAIN UNIT - RH

TWG NO. 7262875-504200


REV. F

SCALE 1/4" = 1'-0"

SHEET 7 OF 17



RESERVED		COPYRIGHT 2017, GENERAL ELECTRIC COMPANY (USA). ALL RIGHTS RESERVED. THE INFORMATION HEREIN IS PROPRIETARY AND TECHNICALLY EXCLUSIVE CONTENT THAT IS SOLELY OWNED BY GENERAL ELECTRIC COMPANY AND/OR ITS AFFILIATES. THIS IS BEING PROVIDED WITH THE EXPLICIT EXPECTATION OF RESTRICTED AND PRIVILEGED USE ALL PERSONS, OR LEGAL ENTITIES RECEIVING THIS INFORMATION SHALL BE DEEMED BY THE ACT OF ITS RECEIPT TO HAVE CONTRACTUALLY AGREED TO MAKE NO DUPLICATIONS, REPRODUCTIONS OF ANY NATURE BY ANY MEANS, MODIFICATIONS, DISCLOSURES, OR USE ANY PORTION OF THIS MATERIAL, EXCEPT AS IS EXPRESSLY AUTHORIZED IN WRITING BY GENERAL ELECTRIC COMPANY AND/OR ITS LEGITIMATE AFFILIATES.		F UPDATED COPYRIGHT		MR	02/16/17	EN	THIRD ANGLE PROJECTION	ADDITIONAL INFO GE CLASS II (INTERNAL)	
		E NO CHANGES THIS SHEET		MR	12/14/16	EN	UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES DO NOT SCALE DRAWING	TITLE GE P&W DISTRIBUTED POWER			
		D UPDATED GAS FUEL CUSTOMER CONNECTION 10		MR	11/04/16	EN		GENERAL ARRANGEMENT MAIN UNIT - RH			
		C UPDATED WITH GAS FUEL AND PF OPTION		MR	08/18/16	EN	TOLERANCES DECIMALS .XX ± .03 FRACTIONAL ± 1/8" ANGULAR ± 1°	REV. NO. 7262875-504200			
		B ADDED CO2 EXTENDED DISCHARGE OPTION		SK	05/17/16	ZJ		REV. F			
		A ORIGINAL ISSUE		SK	10/28/15	ZJ	NEXT ASSY.				
		REV DESCRIPTION		ECO	DRAWN	DATE	DESIGN	UNIT TYPE LM6000			
				REVISIONS				SCALE 3/8" = 1'-0"			
								SHEET 8 OF 17			



50Hz PF

RESERVED

© COPYRIGHT 2017  
 GENERAL ELECTRIC COMPANY (USA).  
 ALL RIGHTS RESERVED. THE  
 INFORMATION HEREIN IS PROPRIETARY  
 AND TECHNICALLY EXCLUSIVE CONTENT  
 THAT IS SOLELY OWNED BY GENERAL  
 ELECTRIC COMPANY AND/OR ITS  
 AFFILIATES. THIS IS BEING PROVIDED  
 WITH THE EXPLICIT EXPECTATION OF  
 RESTRICTED AND PRIVILEGED USE. ALL  
 PERSONS, OR LEGAL ENTITIES RECEIVING  
 THIS INFORMATION SHALL BE DEEMED  
 BY THE ACT OF ITS RECEIPT TO HAVE  
 CONTRACTUALLY AGREED TO MAKE NO  
 DUPLICATIONS, REPRODUCTIONS OF ANY  
 NATURE BY ANY MEANS, MODIFICATIONS,  
 DISCLOSURES, OR USE ANY PORTION OF  
 THIS MATERIAL, EXCEPT AS IS  
 EXPRESSLY AUTHORIZED IN WRITING BY  
 GENERAL ELECTRIC COMPANY AND/OR  
 ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN	UNIT TYPE
F	ADDED CUSTOMER CONNECTION 75 & 315		MR	02/16/17	EN	
E	NO CHANGES THIS SHEET		MR	12/14/16	EN	
D	NO CHANGES THIS SHEET		MR	11/04/16	EN	
C	UPDATED WITH GAS FUEL AND PF OPTION		MR	08/18/16	EN	
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ	
A	ORIGINAL ISSUE		SK	10/28/15	ZJ	
REVISIONS						

THIRD ANGLE  
 PROJECTION  
 UNLESS OTHERWISE SPECIFIED  
 DIMENSIONS ARE IN INCHES  
 DO NOT SCALE DRAWING  
 TOLERANCES  
 DECIMALS FRACTIONAL ANGULAR  
 .XX ± .03 ± 1/16" ± 1°  
 .XXX ± .010 ± 1/16" ± 1°  
 NEXT ASSY.  
 LM6000®

ADDL INFO  
 GE CLASS II (INTERNAL)

**GE P&W DISTRIBUTED POWER**

TITLE  
 GENERAL ARRANGEMENT  
 MAIN UNIT - RH

TWG NO.  
 7262875-504200

REV.  
 F

SCALE 3/8" = 1'-0"  
 SHEET 9 OF 17

CUSTOMER CONNECTION LEGEND:

- \* 2 HYDRAULIC STARTER SUPPLY – 1 1/2"–6000# FF, SAE CODE 62, TP304 PIPE SCH XXS
- \* 3 HYDRAULIC STARTER RETURN – 1 1/2"–3000# FF, SAE CODE 61, TP304 PIPE SCH 40S
- \* 5 HYDRAULIC STARTER CASE DRAIN – 1"–3000# FF, SAE CODE 61, TP304 PIPE SCH 40S
- 6 TURBINE SUMP DRAIN – 2" FNPT 3000#, CPLG, 304SS
- 7 EXHAUST DRAIN – 1"–150# RF, TP304 PIPE SCH 40S
  
- 10 GAS FUEL INLET – 3" WELDED PIPE, TP304 SCH 40S
- 11 GAS FUEL VENT – 1" WELDED PIPE, TP304 SCH 40S
- 13 TURBINE EXHAUST DUCT CONNECTION – N/A
- 14 GENERATOR/GEARBOX SUMP DRAIN – 1" FNPT 3000#, CPLG, 304SS
- 24 GAS FUEL VENT – 1" WELDED PIPE, TP304 SCH 40S
  
- \* 55 INSTRUMENT AIR SUPPLY – 1"–3000# FF, SAE CODE 61, TP304 PIPE SCH 40S
- \* 57 SCAVENGE LUBE OIL FILTER/COOLER SUPPLY – 1 1/2"–3000# FF, SAE CODE 61, TP304 PIPE SCH 40S
- \* 68 GEARBOX LUBE OIL RETURN LINE – 12" PIPE, TP304 SCH 10S
- \* 69 GENERATOR LUBE OIL SUPPLY – 4"–3000# FF, SAE CODE 61, TP304 PIPE SCH 40S
  
- \* 71 TURBINE LUBE OIL PUMP SUPPLY – 1 1/2"–3000# FF, SAE CODE 61, TP304 PIPE SCH 40S
- \* 72 WATER WASH SUPPLY – 1"–3000# FF, SAE CODE 61, TP304 PIPE SCH 40S
- 75 TURBINE LUBE OIL HEAT EXCHANGER SUPPLY – 1 1/2"–150# RF, TP304 PIPE SCH 40S
- \* 78 TURBINE LUBE OIL AIR/OIL PRE-SEPARATOR RETURN – 1 1/2"–3000# FF, SAE CODE 61, TP304 SCH 40S
- \* 81 GENERATOR LUBE OIL DRAIN LINE – 6" PIPE, TP304 SCH 10S
  
- \* 104 JACKING OIL RETURN – 3/4" COMPRESSION TUBE FITTING, TP304 TUBING 0.065" WT MINIMUM
- \* 105 JACKING OIL RETURN – 3/4" COMPRESSION TUBE FITTING, TP304 TUBING 0.065" WT MINIMUM
- \* 106 JACKING OIL RETURN – 3/4" COMPRESSION TUBE FITTING, TP304 TUBING 0.065" WT MINIMUM
- \* 107 JACKING OIL RETURN – 3/4" COMPRESSION TUBE FITTING, TP304 TUBING 0.065" WT MINIMUM
- \* 124 TURBINE LUBE OIL AIR/OIL SEPARATOR RETURN – 1/2" JIC, TP304 TUBING 0.049" WT MINIMUM

- 149 INLET VOLUTE DRAIN – 2"–150# RF, TP304 PIPE SCH 40S
- \* 161 CO2 – 1 1/4" FNPT 3000#, CPLG, 304SS
  
- 183 8TH STAGE BLEED AIR CONNECTION – 10"–150# RF, TP304 PIPE SCH 10S
- 184 CDP BLEED AIR CONNECTION – 6"–300# RF, TP321 PIPE SCH 10S
- 185 INSTRUMENT AIR FOR DAMPER RESET – 1/4" FNPT, 304SS
- 187 VBV DUCT DRAIN – 1"–150# RF, TP304 PIPE SCH 40S
- \* 193 FIRE PROTECTION, EXTENDED DISCHARGE, CO2 INLET – 1/2" NPT 304SS
- 194 COMBUSTOR DRAIN – 1"–150# RF, TP304 PIPE SCH 40S
  
- 228 TURBINE LUBE OIL OVERBOARD DRAIN VENT – 1"–150# RF, TP304 PIPE SCH 40S
- 229 TURBINE LUBE OIL OVERBOARD DRAIN – 1"–150# RF, TP304 PIPE SCH 40S
  
- \* 292 SPRINT SYSTEM DEMINERALIZED WATER LPC INLET – 1" 150# RF, TP316 PIPE SCH40S
- 297 GAS FUEL VENT – 1" PIPE, TP304 SCH 40S
  
- \* 291 SPRINT SYSTEM DEMINERALIZED WATER HPC INLET – 1" 150# RF, TP316 PIPE SCH40S
- 315 TURBINE LUBE OIL FILTER SUPPLY – 1 1/2"–150# RF, TP304 PIPE SCH 40S
  
- 418 STARTER CLUTCH SEAL TELL-TALE DRAIN – 1"–150# RF, TP304 PIPE SCH 40S

NOTES:

1. AN ASTERISK (\*) INDICATES CONNECTION HARDWARE BY GEPPLP.
2. FOR CUSTOMER CONNECTION FLANGES MAXIMUM ALLOWABLE LOADS, REFER TO DRAWING 806125.

50Hz PF


RESERVED

© COPYRIGHT, 2017, GENERAL ELECTRIC COMPANY (USA). ALL RIGHTS RESERVED. THE INFORMATION HEREIN IS PROPRIETARY AND TECHNICALLY EXCLUSIVE CONTENT THAT IS SOLELY OWNED BY GENERAL ELECTRIC COMPANY AND/OR ITS AFFILIATES. THIS IS BEING PROVIDED WITH THE EXPLICIT EXPECTATION OF RESTRICTED AND PRIVILEGED USE ALL PERSONS, OR LEGAL ENTITIES RECEIVING THIS INFORMATION SHALL BE DEEMED BY THE ACT OF ITS RECEIPT TO HAVE CONTRACTUALLY AGREED TO MAKE NO DUPLICATIONS, REPRODUCTIONS OF ANY NATURE BY ANY MEANS, MODIFICATIONS, DISCLOSURES, OR USE ANY PORTION OF THIS MATERIAL, EXCEPT AS IS EXPRESSLY AUTHORIZED IN WRITING BY GENERAL ELECTRIC COMPANY AND/OR ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN	UNIT TYPE
F	ADDED CUSTOMER CONNECTION 75 & 315 DETAILS		MR	02/16/17	EN	
E	NO CHANGES THIS SHEET		MR	12/14/16	EN	
D	NO CHANGES THIS SHEET		MR	11/04/16	EN	
C	UPDATED WITH GAS FUEL AND PF OPTION		MR	08/18/16	EN	
B	ADDED CO2 EXTENDED DISCHARGE OPTION		SK	05/17/16	ZJ	
A	ORIGINAL ISSUE		SK	10/28/15	ZJ	

THIRD ANGLE PROJECTION	
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES DO NOT SCALE DRAWING	
DECIMALS	TOLERANCES
.XX ± .03	FRACTIONAL ± 1/8"
.XXX ± .010	ANGULAR ± 1°
NEXT ASSY.	
LM6000®	

ADDL INFO		GE CLASS II (INTERNAL)	
GE P&W DISTRIBUTED POWER			
TITLE GENERAL ARRANGEMENT MAIN UNIT – RH			
DWG NO.		REV.	
7262875-504200		F	
SCALE NONE		SHEET 10 OF 17	




1/2" [13] PLATE  
4X ø1 1/16" [ø27] HOLE  
(SEE NOTE 2)

9" [229]  
7" [178]  
1" [25]  
1" [25]  
7" [178]  
9" [229]

1/2" [13] SHIM ALLOWANCE  
"0" DATUM


**DETAIL A**  
ENGINE & GEARBOX REMOVAL FOOT PAD  
SEE SHEET 2  
(SEE NOTE 4, SHEET 1)



W 30 X 132 (REF)  
8X 3/8"-16 UNC X 1/2" [13] DEEP

2 3/16" [56]  
1 11/16" [43]


**DETAIL B**  
GROUNDING LUG  
SEE SHEET 3 & 4



2X 9 3/8" [239]  
10 5/16" [262]  
10 1/4" [260]

2X 5 1/2" [140]  
3 1/2" [88]

**DETAIL B**  
TURBINE ROXTEC ENTRANCE  
SEE SHEET 3 & 4



2X 5 1/2" [140]  
2X 9 3/8" [238]  
3 1/2" [88]  
1'-5 1/4" [438]  
8 13/16" [224]

**DETAIL C**  
7-290 GENERATOR ROXTEC ENTRANCE  
FOR 50HZ PF  
SEE SHEET 3 & 4

**NOTES:**  
1. ALL ANCHORING HARDWARE TO BE SUPPLIED BY CUSTOMER.  
2. BOLT HOLE TOLERANCE ± 1/8" [3], TRUE POSITION.

RESERVED

© COPYRIGHT 2017  
GENERAL ELECTRIC COMPANY (USA).  
ALL RIGHTS RESERVED. THE  
INFORMATION HEREIN IS PROPRIETARY  
AND TECHNICALLY EXCLUSIVE CONTENT  
THAT IS SOLELY OWNED BY GENERAL  
ELECTRIC COMPANY AND/OR ITS  
AFFILIATES. THIS, IT IS BEING PROVIDED  
WITH THE EXPLICIT EXPECTATION OF  
RESTRICTED AND PRIVILEGED USE. ALL  
PERSONS, OR LEGAL ENTITIES RECEIVING  
THIS INFORMATION SHALL BE DEEMED  
BY THE ACT OF ITS RECEIPT TO HAVE  
CONTRACTUALLY AGREED TO MAKE NO  
DUPLICATIONS, REPRODUCTIONS OF ANY  
NATURE BY ANY MEANS, MODIFICATIONS,  
DISCLOSURES, OR USE ANY PORTION OF  
THIS MATERIAL, EXCEPT AS IS  
EXPRESSLY AUTHORIZED IN WRITING BY  
GENERAL ELECTRIC COMPANY AND/OR  
ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN	UNIT TYPE
F	UPDATED COPYRIGHT		MR	02/16/17	EN	
E	NO CHANGES THIS SHEET		MR	12/14/16	EN	
D	NO CHANGES THIS SHEET		MR	11/04/16	EN	
C	RENUMBERED THIS SHEET		MR	08/18/16	EN	
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ	
A	ORIGINAL ISSUE		SK	10/28/15	ZJ	
REVISIONS						

THIRD ANGLE PROJECTION

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES  
DO NOT SCALE DRAWING

TOLERANCES  
DECIMALS FRACTIONAL ANGULAR  
.XX ± .03 ± 1/8" ± 1"  
.XXX ± .010

LM6000®

ADDL INFO  
GE CLASS II (INTERNAL)

**GE P&W DISTRIBUTED POWER**

TITLE  
GENERAL ARRANGEMENT  
MAIN UNIT - RH

TWG NO.  
7262875-504200

REV.  
F


SCALE 3" = 1'-0"  
SHEET 11 OF 17

LOADS ON CUSTOMER CONNECTIONS

	LOAD CASE	FORCE-X lbs	FORCE-Y lbs	FORCE-Z lbs	MOMENT-X ft-lbs	MOMENT-Y ft-lbs	MOMENT-Z ft-lbs
CDP	OPERATING LOAD	1314	-273	-16	70	-43	-915
	SEISMIX X-0.5g	115	1	-1	0	-1	-67
	SEISMIX Z-0.5g	0	0	59	9	10	-2
8TH STAGE	OPERATING LOAD	4596	-340	-8	130	-37	-1629
	SEISMIX X-0.5g	114	-9	-31	12	-51	-34
	SEISMIX Z-0.5g	0	0	123	-53	138	1

NOTES:

1. THESE ARE FORCES EXERTED AT CUSTOMER CONNECTIONS BY AERO PIPING. CUSTOMER NEEDS TO CONSIDER THESE FORCES IN THEIR DESIGN. THESE ARE NOT THE ALLOWABLE LOADS AT GE FLANGES.
2. OPERATING LOAD IS RESULT OF TEMPERATURE, PRESSURE AND WEIGHT OF THE SYSTEM.
3. FY OPERATING LOAD IS THE WEIGHT OF THE SYSTEM EXERTED ON THE CUSTOMER CONNECTION.
4. CUSTOMER SHOULD INCLUDE THE VERTICAL SEISMIC LOAD EFFECT  $E_V = +/-0.2 SDS D = +/-0.24 D$  IN CONNECTION DESIGN PER ASCE 7-10 SECTION 12.4.



CDP BLEED

8TH STAGE BLEED

RESERVED

© COPYRIGHT 2017  
 GENERAL ELECTRIC COMPANY (USA).  
 ALL RIGHTS RESERVED. THE  
 INFORMATION HEREIN IS PROPRIETARY  
 AND TECHNICALLY EXCLUSIVE CONTENT  
 THAT IS SOLELY OWNED BY GENERAL  
 ELECTRIC COMPANY AND/OR ITS  
 AFFILIATES. THIS IS BEING PROVIDED  
 WITH THE EXPLICIT EXPECTATION OF  
 RESTRICTED AND PRIVILEGED USE. ALL  
 PERSONS, OR LEGAL ENTITIES RECEIVING  
 THIS INFORMATION SHALL BE DEEMED  
 BY THE ACT OF ITS RECEIPT TO HAVE  
 CONTRACTUALLY AGREED TO MAKE NO  
 DUPLICATIONS, REPRODUCTIONS OF ANY  
 NATURE BY ANY MEANS, MODIFICATIONS,  
 DISCLOSURES, OR USE ANY PORTION OF  
 THIS MATERIAL, EXCEPT AS IS  
 EXPRESSLY AUTHORIZED IN WRITING BY  
 GENERAL ELECTRIC COMPANY AND/OR  
 ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN
F	UPDATED COPYRIGHT		MR	02/16/17	EN
E	NO CHANGES THIS SHEET		MR	12/14/16	EN
D	NO CHANGES THIS SHEET		MR	11/04/16	EN
C	ADDED THIS SHEET		MR	08/18/16	EN

THIRD ANGLE PROJECTION

UNLESS OTHERWISE SPECIFIED  
 DIMENSIONS ARE IN INCHES  
 DO NOT SCALE DRAWING

TOLERANCES  
 DECIMALS .XX ± .03  
 FRACTIONAL ± 1/8"  
 ANGULAR ± 1°

TEXT ASSY.

LM6000

ADDL INFO GE CLASS II (INTERNAL)

GE P&W DISTRIBUTED POWER

TITLE GENERAL ARRANGEMENT  
 MAIN UNIT - RH

TWG NO. 7262875-504200

REV. F

SCALE 3/4" = 1'-0"

SHEET 12 OF 17

**NOTES:**


1. INTERIOR OF THE TURBINE ROOM IS CONSIDERED ZONE 2, ATEX CATEGORY 3 PER IEC 60079-10 AND NEC 505 WHEN VENTILATION FANS ARE NOT OPERATING. WHEN FANS ARE OPERATING, AREA IS CONSIDERED UNCLASSIFIED.
2. INSIDE GENERATOR ENCLOSURE, CONSIDERED NON-HAZARDOUS AREA.
3. DIMENSIONS AND VALUES IN [ ] ARE U.S. CUSTOMARY UNITS. SI UNITS ARE GIVEN FOR REFERENCE ONLY. EQUIPMENT SHALL BE DESIGNED AND MANUFACTURED USING U.S. CUSTOMARY UNITS.
4. AREA OUTSIDE OF TURBINE ENCLOSURE CAN BECOME UNCLASSIFIED WHEN GAS FUEL SUPPLY PIPE INTERFACE IS SEAL WELDED. EXCLUSIVE OF THE TURBINE FAN AND VBV EXHAUST PATHS
5. CUSTOMER DRAWING NUMBERS CONSIST OF: (ORDER NUMBER)-(STANDARD DRAWING NUMBER), AND ARE REFERENCED AS X-(STANDARD DRAWING NUMBER), WHERE X = ORDER NUMBER.
6. IT IS THE CUSTOMERS SCOPE OF RESPONSIBILITY TO ROUTE GAS VENT LINES TO A SAFE AREA.
7. REFERENCE GENERAL ARRANGEMENT FOR EQUIPMENT LAYOUT.
8. LOCATION OF WOBBE METER/ GAS CHROMATOGRAPH SHALL BE AS FAR AS POSSIBLE FROM FILTER HOUSE TO AVOID INGRESS OF GAS TO THE ENGINE AIR INLET FLOW PATH.

**LEGEND:**

-  ZONE 1, ATEX CAT 2 (50 Hz)
-  ZONE 2, ATEX CAT 3 (50 Hz)

**REFERENCE DRAWINGS:**

- X-504691 AREA CLASSIFICATION REPORT
- X-504204 GENERAL ARRANGEMENT AIR FILTER
- X-504245 F&ID FUEL SYSTEM (DLE)



**AREA CLASSIFICATION**

ADDL INFO GE CLASS II (INTERNAL)

RESERVED	<p>© COPYRIGHT 2017 GENERAL ELECTRIC COMPANY (USA). ALL RIGHTS RESERVED. THE INFORMATION HEREIN IS PROPRIETARY AND TECHNICALLY EXCLUSIVE CONTENT THAT IS SOLELY OWNED BY GENERAL ELECTRIC COMPANY AND/OR ITS AFFILIATES. THIS IS BEING PROVIDED WITH THE EXPLICIT EXPECTATION OF RESTRICTED AND PRIVILEGED USE ALL PERSONS, OR LEGAL ENTITIES RECEIVING THIS INFORMATION SHALL BE DEEMED BY THE ACT OF ITS RECEIPT TO HAVE CONTRACTUALLY AGREED TO MAKE NO DUPLICATIONS, REPRODUCTIONS OF ANY NATURE BY ANY MEANS, MODIFICATIONS, DISCLOSURES, OR USE ANY PORTION OF THIS MATERIAL, EXCEPT AS IS EXPRESSLY AUTHORIZED IN WRITING BY GENERAL ELECTRIC COMPANY AND/OR ITS LEGITIMATE AFFILIATES.</p>				F	UPDATED COPYRIGHT	MR	02/16/17	EN	<p>THIRD ANGLE PROJECTION</p> <p>UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES DO NOT SCALE DRAWING</p> <p>TOLERANCES DECIMALS FRACTIONAL ANGULAR .XX ± .03 ± 1/8" ± 1"</p> <p>TEXT ASSY.</p> <p>LM6000®</p>
	E	NO CHANGES THIS SHEET	MR	12/14/16	EN					
	D	NO CHANGES THIS SHEET	MR	11/04/16	EN					
	C	UPDATED WITH AUXILIARY SKID ENCLOSED	MR	08/18/16	EN					
	B	UPDATED COPYRIGHT	SK	05/17/16	ZJ					
	A	ORIGINAL ISSUE	SK	10/28/15	ZJ					
	REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN				

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN
F	UPDATED COPYRIGHT		MR	02/16/17	EN
E	NO CHANGES THIS SHEET		MR	12/14/16	EN
D	NO CHANGES THIS SHEET		MR	11/04/16	EN
C	UPDATED WITH AUXILIARY SKID ENCLOSED		MR	08/18/16	EN
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ
A	ORIGINAL ISSUE		SK	10/28/15	ZJ

GE P&W DISTRIBUTED POWER

TITLE GENERAL ARRANGEMENT MAIN UNIT - RH

TWG NO. 7262875-504200


REV. F

SCALE 1/4" = 1'-0"

SHEET 13 OF 17

REVISIONS





LEFT SIDE ELEVATION  
PARTIALLY SHOWN FOR CLARITY, SEE NOTE 7

AREA CLASSIFICATION

ADDL INFO  
GE CLASS II (INTERNAL)

RESERVED

© COPYRIGHT 2017  
GENERAL ELECTRIC COMPANY (USA).  
ALL RIGHTS RESERVED. THE  
INFORMATION HEREIN IS PROPRIETARY  
AND TECHNICALLY EXCLUSIVE CONTENT  
THAT IS SOLELY OWNED BY GENERAL  
ELECTRIC COMPANY AND/OR ITS  
AFFILIATES. THIS IS BEING PROVIDED  
WITH THE EXPLICIT EXPECTATION OF  
RESTRICTED AND PRIVILEGED USE. ALL  
PERSONS, OR LEGAL ENTITIES RECEIVING  
THIS INFORMATION SHALL BE DEEMED  
BY THE ACT OF ITS RECEIPT TO HAVE  
CONTRACTUALLY AGREED TO MAKE NO  
DUPLICATIONS, REPRODUCTIONS OF ANY  
NATURE BY ANY MEANS, MODIFICATIONS,  
DISCLOSURES, OR USE ANY PORTION OF  
THIS MATERIAL, EXCEPT AS IS  
EXPRESSLY AUTHORIZED IN WRITING BY  
GENERAL ELECTRIC COMPANY AND/OR  
ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN	UNIT TYPE
F	UPDATED COPYRIGHT		MR	02/16/17	EN	
E	NO CHANGES THIS SHEET		MR	12/14/16	EN	
D	NO CHANGES THIS SHEET		MR	11/04/16	EN	
C	RENUMBERED THIS SHEET		MR	08/18/16	EN	
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ	
A	ORIGINAL ISSUE		SK	10/28/15	ZJ	

THIRD ANGLE PROJECTION

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES  
DO NOT SCALE DRAWING

TOLERANCES  
DECIMALS FRACTIONAL ANGULAR  
.XX ± .03 ± 1/8" ± 1"  
.XXX ± .010

TEXT ASSY.

LM6000®

GE P&W DISTRIBUTED POWER


TITLE  
GENERAL ARRANGEMENT  
MAIN UNIT - RH

TWG NO.  
7262875-504200

REV.  
F

SCALE 1/4" = 1'-0"

SHEET 14 OF 17



"0" DATUM - ALL TAIL DIMENSIONS ARE TAKEN FROM GENERATOR END AND BOTTOM OF SKID

"0" DATUM ALL ELEVATION DIMENSIONS ARE TAKEN FROM BOTTOM OF SKID

MINERAL LUBE OIL SKID RIGHT SIDE ELEVATION

AREA CLASSIFICATION

RESERVED

© COPYRIGHT 2017 GENERAL ELECTRIC COMPANY (USA). ALL RIGHTS RESERVED. THE INFORMATION HEREIN IS PROPRIETARY AND TECHNICALLY EXCLUSIVE CONTENT THAT IS SOLELY OWNED BY GENERAL ELECTRIC COMPANY AND/OR ITS AFFILIATES. THIS IS BEING PROVIDED WITH THE EXPLICIT EXPECTATION OF RESTRICTED AND PRIVILEGED USE. ALL PERSONS, OR LEGAL ENTITIES RECEIVING THIS INFORMATION SHALL BE DEEMED BY THE ACT OF ITS RECEIPT TO HAVE CONTRACTUALLY AGREED TO MAKE NO DUPLICATIONS, REPRODUCTIONS OF ANY NATURE BY ANY MEANS, MODIFICATIONS, DISCLOSURES, OR USE ANY PORTION OF THIS MATERIAL, EXCEPT AS IS EXPRESSLY AUTHORIZED IN WRITING BY GENERAL ELECTRIC COMPANY AND/OR ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN
F	UPDATED COPYRIGHT		MR	02/16/17	EN
E	NO CHANGES THIS SHEET		MR	12/14/16	EN
D	NO CHANGES THIS SHEET		MR	11/04/16	EN
C	UPDATED VIEW OF AUXILIARY SKID AND MLO SKID		MR	08/18/16	EN
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ
A	ORIGINAL ISSUE		SK	10/28/15	ZJ

THIRD ANGLE PROJECTION

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES DO NOT SCALE DRAWING

TOLERANCES DECIMALS FRACTIONAL ANGULAR .XX ± .03 ± 1/8" ± 1"

TEXT ASSY.

LM6000®

ADDL INFO GE CLASS II (INTERNAL)

GE P&W DISTRIBUTED POWER


TITLE GENERAL ARRANGEMENT MAIN UNIT - RH

TWG NO. 7262875-504200

REV. F

SCALE 1/4" = 1'-0"

SHEET 15 OF 17



**GENERATOR END VIEW**  
SOME SKIDS & INTERCONNECT PLATFORM NOT SHOWN FOR CLARITY

**EXHAUST END VIEW**  
SOME SKIDS NOT SHOWN FOR CLARITY

**MAIN UNIT 50Hz**

RESERVED

© COPYRIGHT 2017  
GENERAL ELECTRIC COMPANY (USA).  
ALL RIGHTS RESERVED. THE  
INFORMATION HEREIN IS PROPRIETARY  
AND TECHNICALLY EXCLUSIVE CONTENT  
THAT IS SOLELY OWNED BY GENERAL  
ELECTRIC COMPANY AND/OR ITS  
AFFILIATES. THIS INFORMATION IS BEING PROVIDED  
WITH THE EXPLICIT EXPECTATION OF  
RESTRICTED AND PRIVILEGED USE. ALL  
PERSONS, OR LEGAL ENTITIES RECEIVING  
THIS INFORMATION SHALL BE DEEMED  
BY THE ACT OF ITS RECEIPT TO HAVE  
CONTRACTUALLY AGREED TO MAKE NO  
DUPLICATIONS, REPRODUCTIONS OF ANY  
NATURE BY ANY MEANS, MODIFICATIONS,  
DISCLOSURES, OR USE ANY PORTION OF  
THIS MATERIAL, EXCEPT AS IS  
EXPRESSLY AUTHORIZED IN WRITING BY  
GENERAL ELECTRIC COMPANY AND/OR  
ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN	UNIT TYPE
F	UPDATED COPYRIGHT		MR	02/16/17	EN	
E	NO CHANGES THIS SHEET		MR	12/14/16	EN	
D	NO CHANGES THIS SHEET		MR	11/04/16	EN	
C	UPDATED MLO WITH FIN FAN COOLER		MR	08/18/16	EN	
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ	
A	ORIGINAL ISSUE		SK	10/28/15	ZJ	

THIRD ANGLE PROJECTION

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES  
DO NOT SCALE DRAWING

TOLERANCES  
DECIMALS FRACTIONAL ANGULAR  
.XX ± .03 ± 1/8" ± 1°  
.XXX ± .010

TEXT ASSY.

LM6000®

ADDL INFO  
GE CLASS II (INTERNAL)

**GE P&W DISTRIBUTED POWER**

TITLE  
**GENERAL ARRANGEMENT  
MAIN UNIT - RH**

TWG NO.  
7262875-504200

REV.  
F

SCALE 1/4" = 1'-0"

SHEET 16 OF 17

8

7

6

5

4

3

2

1

D

D

C


C

B

B


A

A




GAS FUEL FILTER SKID  
REFERENCE ONLY

R3'-3 3/8"  
[R1000]  
(TYP)




GAS CHROMATOGRAPH SYSTEM  
REFERENCE ONLY

R1'-8 7/8"  
[R530]  
(TYP)



GAS FUEL FILTER SKID  
REFERENCE ONLY

R3'-3 3/8"  
[R1000]  
(TYP)



GAS CHROMATOGRAPH SYSTEM  
REFERENCE ONLY

R1'-8 7/8"  
[R530]  
(TYP)

GAS FUEL FILTER SKID  
50 Hz

GAS CHROMATOGRAPH  
50 Hz

RESERVED

© COPYRIGHT 2017  
GENERAL ELECTRIC COMPANY (USA).  
ALL RIGHTS RESERVED. THE  
INFORMATION HEREIN IS PROPRIETARY  
AND TECHNICALLY EXCLUSIVE CONTENT  
THAT IS SOLELY OWNED BY GENERAL  
ELECTRIC COMPANY AND/OR ITS  
AFFILIATES. THIS IS BEING PROVIDED  
WITH THE EXPLICIT EXPECTATION OF  
RESTRICTED AND PRIVILEGED USE. ALL  
PERSONS, OR LEGAL ENTITIES RECEIVING  
THIS INFORMATION SHALL BE DEEMED  
BY THE ACT OF ITS RECEIPT TO HAVE  
CONTRACTUALLY AGREED TO MAKE NO  
DUPLICATIONS, REPRODUCTIONS OF ANY  
NATURE BY ANY MEANS, MODIFICATIONS,  
DISCLOSURES, OR USE ANY PORTION OF  
THIS MATERIAL, EXCEPT AS IS  
EXPRESSLY AUTHORIZED IN WRITING BY  
GENERAL ELECTRIC COMPANY AND/OR  
ITS LEGITIMATE AFFILIATES.

REV	DESCRIPTION	ECO	DRAWN	DATE	DESIGN
F	UPDATED COPYRIGHT		MR	02/16/17	EN
E	NO CHANGES THIS SHEET		MR	12/14/16	EN
D	NO CHANGES THIS SHEET		MR	11/04/16	EN
C	UPDATED WITH GAS CHROMATOGRAPH & GAS FILTER		MR	08/18/16	EN
B	UPDATED COPYRIGHT		SK	05/17/16	ZJ
A	ORIGINAL ISSUE		SK	10/28/15	ZJ

THIRD ANGLE  
PROJECTION

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES  
DO NOT SCALE DRAWING

TOLERANCES

DECIMALS	FRACTIONAL	ANGULAR
.XX ± .03	± 1/8"	± 1°
.XXX ± .010		

NEXT ASSY:

UNIT TYPE: LM6000®

ADDL INFO: GE CLASS II (INTERNAL)

**GE P&W DISTRIBUTED POWER**

TITLE: GENERAL ARRANGEMENT  
MAIN UNIT - RH

DWG NO.: 7262875-504200

REV: F

SCALE: 1/4" = 1'-0"

SHEET 17 OF 17

8

7

6

5

4

3

2

1

**PERFORMANCE CENTRAL REPORT**

Version 12.10 Built: 2017-07-17 22:35 UTC

Performance By: Not Found Date: 20/07/2017  
 Project: Not Found Time: 00:48:28

**Estimated Engine Performance NOT FOR GUARANTEE: USE FOR STUDY ONLY**

Engine:	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	LM6000	
Model:	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	PF-SPRINT-25	
Options:	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Generator	BDAX 7-290ER	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290	BDAX 7-290ERJT
Frequency,Hz	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50
Voltage,kV	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11
PF	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8
<b>Case</b>	<b>100</b>	<b>101</b>	<b>102</b>	<b>103</b>	<b>104</b>	<b>105</b>	<b>106</b>	<b>107</b>	<b>108</b>	<b>109</b>	<b>110</b>	<b>111</b>	<b>112</b>	<b>113</b>	<b>114</b>	<b>115</b>	<b>116</b>	<b>117</b>	<b>118</b>		
<b>Ambient Conditions</b>																					
Dry Bulb Temp., °C	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15
Wet Bulb Temp., °C	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82
Relative Humidity, %	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60
Elevation a.s.l., m	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Barometric Press., kPa	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325
<b>Pressure Losses</b>																					
Inlet Press. Loss, mmH2O	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6
Exh. Press. Loss, mmH2O	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4
Volume Loss, mmH2O	112.73	110.88	109.53	107.08	102.33	91.53	86.01	76.62	70.8	71.56	71.98	72.02	72.08	72.11	72.15	72.2	72.22	72.22	72.1	72.13	
<b>GTG Load, %</b>	<b>100</b>	<b>95</b>	<b>90</b>	<b>85</b>	<b>80</b>	<b>75</b>	<b>70</b>	<b>65</b>	<b>60</b>	<b>55</b>	<b>50</b>	<b>45</b>	<b>40</b>	<b>35</b>	<b>30</b>	<b>25</b>	<b>20</b>	<b>15</b>	<b>10</b>		
<b>Gen. Output, Gross, kW</b>	<b>47733</b>	<b>45346</b>	<b>42960</b>	<b>40573</b>	<b>38186</b>	<b>35800</b>	<b>33413</b>	<b>31026</b>	<b>28640</b>	<b>26253</b>	<b>23866</b>	<b>21480</b>	<b>19093</b>	<b>16706</b>	<b>14320</b>	<b>11933</b>	<b>9547</b>	<b>7160</b>	<b>4773</b>		
<b>HR, kJ(kWh)</b>	<b>8738</b>	<b>8791</b>	<b>8943</b>	<b>9157</b>	<b>9346</b>	<b>9249</b>	<b>9431</b>	<b>9616</b>	<b>9871</b>	<b>10249</b>	<b>10757</b>	<b>11509</b>	<b>12425</b>	<b>13427</b>	<b>14437</b>	<b>15922</b>	<b>18069</b>	<b>20641</b>	<b>28262</b>		
Comp. Inlet Temp., °C	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15
<b>Fuel Flow</b>																					
Fuel Number	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577	801-577
Fuel Name	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur	Fuel with sulfur
Fuel LHV, kJ/kg	44173	44173	44173	44173	44173	44173	44173	44173	44173	44173	44173	44173	44173	44173	44173	44173	44173	44173	44173	44173	44173
Heat Input, MW	115.9	110.7	106.7	103.2	99.1	92	87.5	82.9	78.5	74.7	71.3	68.7	65.9	62.3	57.4	52.8	47.9	41.1	37.5		
Fuel Flow, kg/h	9441.7	9024.5	8697.4	8410.4	8079.4	7496.1	7133.8	6753.9	6400.1	6091.4	5812.2	5596.6	5370.3	5078.3	4680.2	4301.2	3905	3345.7	3053.9		
Vol. Fuel Flow, Nm3/hr	1124.7	1071.9	1033.0	998.7	959.6	893.7	847.4	802.2	760.2	723.5	690.3	664.6	6378.8	6031.9	5559.1	5109	4638.3	3973.9	3627.4		
Fuel Temp., °C	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27
<b>NOx Control</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>	<b>DLE</b>
<b>Sprint Location</b>	<b>LPC</b>	<b>LPC</b>	<b>LPC</b>	<b>LPC</b>	<b>LPC</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>	<b>OFF</b>
Sprint Water Flow, kg/h	4220.7	4220.7	4220.7	4220.7	4220.7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Sprint Water Temp., °C	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6
<b>Exhaust Parameters</b>																					
Exhaust Temp., °C	457.07	443.54	436.7	442.66	449.38	452.05	463.26	473.01	482.07	490.59	495.76	490.74	494.24	495.33	486.55	482.6	475.22	445.6	448.25		
<b>Exhaust Flow, kg/s</b>	<b>132.3</b>	<b>131.1</b>	<b>129.9</b>	<b>125.2</b>	<b>119.4</b>	<b>116.8</b>	<b>108.8</b>	<b>101.9</b>	<b>95.8</b>	<b>90.7</b>	<b>87.4</b>	<b>88.2</b>	<b>86.7</b>	<b>84</b>	<b>80.5</b>	<b>76.3</b>	<b>72.3</b>	<b>67.2</b>	<b>63.9</b>		
Energy (Ref OR), kW	103154	100080	98128	95457	91960	89451	84768	80503	76719	73524	71362	71389	70500	68358	64617	60897	56984	50697	48322		
Energy (Ref TZ), kW	63593	60913	58861	57311	55590	54108	51856	49700	47753	46104	44502	43028	41753	40017	37573	35361	32901	29224	27266		
<b>Exhaust stack exit temperature estimate</b>	<b>395</b>	<b>381.47</b>	<b>374.63</b>	<b>380.59</b>	<b>387.31</b>	<b>389.98</b>	<b>401.19</b>	<b>410.94</b>	<b>420</b>	<b>428.52</b>	<b>433.69</b>	<b>428.67</b>	<b>432.17</b>	<b>433.26</b>	<b>424.48</b>	<b>420.53</b>	<b>413.15</b>	<b>383.53</b>	<b>386.18</b>		
<b>Emissions (ESTIMATED, NOT FOR GUARANTEE)</b>																					
NOx, Ref % O2, mg/Nm3	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2	51.2
CO, Ref % O2, mg/Nm3	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2
<b>Aero Energy Fuel Number</b> 801-577																					
Fuel Bound N, %Mass	0																				
Sulfur Content, %Mass	0.1																				
Hydrogen, %	0																				
Methane, %	84.5																				
Ethane, %	5.58																				
Ethylene, %	0																				
Propane, %	2.05																				
Propylene, %	0																				
Butane, %	0.78																				
Butylene, %	0																				
Butadiene, %	0																				
Pentane, %	0.18																				
Cyclopentane, %	0																				
Hexane, %	0.17																				
Heptane, %	0																				
Carbon Monoxide, %	0																				
Carbon Dioxide, %	0.67																				
Nitrogen, %	5.93																				

**PERFORMANCE CENTRAL REPORT**

Version 1.2.10 Built: 2017-07-17 22:35 UTC

Performance By: Not Found  
 Project: Not Found  
 Date: 20/07/2017  
 Time: 00:56:09

**Estimated Engine Performance NOT FOR GUARANTEE: USE FOR STUDY ONLY**

Engine Model:	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF	LM6000 PF
Options:	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Generator Frequency, Hz	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50
Voltage, kV	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11
PF	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8
<b>Case</b>	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118			
<b>Ambient Conditions</b>																						
Dry Bulb Temp., °C	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15
Wet Bulb Temp., °C	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82	10.82
Relative Humidity, %	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60
Elevation a.s.l., m	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Barometric Press., kPa	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325	101.325
<b>Pressure Losses</b>																						
Inlet Press. Loss, mmH2O	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6	101.6
Exh. Press. Loss, mmH2O	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4	152.4
Volume Loss, mmH2O	99.62	95.2	89.97	86.18	81.34	73.34	70.87	71.65	72.21	72.37	72.35	72.4	72.37	72.41	72.44	72.47	72.36	72.35	71.99			
<b>GTG Load, %</b>	100	95	90	85	80	75	70	65	60	55	50	45	40	35	30	25	20	15	10			
<b>Gen. Output, Gross, kW</b>	40726	38689	36653	34617	32581	30544	28508	26472	24435	22399	20363	18327	16290	14254	12218	10181	8145	6109	4073			
<b>HR, kJ/(kW*h)</b>	8904	8999	9132	9299	9483	9656	9913	10244	10625	11220	11997	12904	13678	14263	15825	17522	19192	23947	30587			
<b>Comp. Inlet Temp., °C</b>	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15

Fuel Flow	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2
Fuel Number	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2
Fuel Name	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2	Diesel #2
Fuel LHV, kJ/kg	42798	42798	42798	42798	42798	42798	42798	42798	42798	42798	42798	42798	42798	42798	42798	42798	42798	42798	42798	42798	42798	42798
Heat Input, MW	100.7	96.7	93	89.4	85.8	81.9	78.5	75.3	72.1	69.8	67.9	65.7	63.9	62.5	61.9	61.9	62.5	63.9	65.7	67.9	70.8	74.6
Fuel Flow, kg/h	8472.7	8135	7820.7	7521.3	7219.1	6891	6603	6366.1	6066.3	5871.9	5707.8	5525.7	5206.2	4750.3	4517.6	4168.4	3652.5	3418.1	2910.6			
Vol. Fuel Flow, Nm3/hr	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Fuel Temp., °C	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16

Nox Control	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE	DLE
<b>Exhaust Parameters</b>																						
Exhaust Temp., °C	461.07	456.86	456.44	455.71	466.12	475.42	484.05	492.38	501.48	502.08	498.86	507.52	501.53	486.52	490.56	484.57	457.13	460.83	468.06			
<b>Exhaust Flow, kg/s</b>	123.1	120.3	117	114	107.6	101.6	96.5	92	87.5	86.9	87.9	85.9	83.5	79.2	76.8	73.3	68.9	65.3	55.6			
Energy (Ref OR), kW	94636	91877	89238	86854	83238	79665	76642	73921	71210	70776	71249	70435	67855	62965	61436	58112	52466	50873	42944			
Energy (Ref T2), kW	58593	56663	55012	52984	51116	49344	47838	46472	45108	43886	42899	41935	40900	37348	35977	33879	30604	29074	26470			
<b>Stack exit exhaust temp</b>	399	394.79	394.37	393.64	404.05	413.35	421.98	430.31	439.41	440.01	436.79	445.45	439.46	424.45	428.49	422.5	395.06	398.76	405.99			

Emissions (ESTIMATED, NOT FOR GUARANTEE)	174.3	174.2	174.2	174.2	174.2	174.2	174.2	174.3	174.3	174.3	174.3	174.3	174.3	174.3	174.3	174.2	174.2	174.2	174.1			
NOx, Ref % O2, mg/Nm3	174.3	174.2	174.2	174.2	174.2	174.2	174.2	174.3	174.3	174.3	174.3	174.3	174.3	174.3	174.3	174.2	174.2	174.2	174.1			
CO, Ref % O2, mg/Nm3	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.2	31.1			

Exhaust Parameters	1.121	1.119	1.119	1.119	1.122	1.125	1.128	1.13	1.133	1.136	1.14	1.143	1.141	1.135	1.137	1.134	1.122	1.125	1.117			
Sp. Heat, kJ/(kg*°K)	1.121	1.119	1.119	1.119	1.122	1.125	1.128	1.13	1.133	1.136	1.14	1.143	1.141	1.135	1.137	1.134	1.122	1.125	1.117			
Exh Mol Wtght, kg/kmol	28.889	28.888	28.888	28.888	28.889	28.889	28.889	28.89	28.89	28.89	28.891	28.892	28.891	28.889	28.889	28.888	28.888	28.884	28.881			
Exh. Flow, ACFM	536219.4	520968.6	506132	492757.3	471619	450876	43328.6	417547.1	401822	399536	402612.1	397725.6	383482	356718.6	348042.7	329581.9	298671.6	289626.2	244284.1			
Exh. Flow, SCFM	213960.1	209072.1	203234.7	198062.7	186896.2	176456.7	167656.3	159792.8	151968.9	150988	152784.9	149255.2	145023.8	137566.8	133511.9	127430	119817.2	115602.9	96553.4			

Generator Information	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8
Gen. Capacity, kW	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8	50812.8
LPC Inlet Flow Wet, kg/s	122.168	119.425	116.103	113.626	110.395	104.827	103.041	103.606	104.014	104.126	104.115	104.147	104.127	104.157	104.178	104.197	104.124	104.112	103.856			
LPC Inlet Flow Dry, kg/s	121.39	118.665	115.364	112.902	109.692	104.159	102.385	102.946	103.351	103.463	103.452	103.484	103.464	103.493	103.515	103.533	103.461	103.449	103.195			

Generator	BDAX 7-290EF																					
Coolant	Air																					
Run Control Level 1	Shaft Horse P% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load	% Load
Target Power	100	95	90	85	80	75	70	65	60	55	50	45	40	35	30	25	20	15	10			
Target Part Load, %	100	95	90	85	80	75	70	65	60	55	50	45	40	35	30	25	20	15	10			
GTG Load, %	100	95	90	85	80	75	70	65	60	55	50	45	40	35	30	25	20	15	10			
<b>Gen. Output, Gross, kW</b>	40726	38689	36653	34617	32581	30544	28508	26472	24435	22399	20363	18327	162									

## APPENDIX G

### Practitioner Capability Statement

As presented in Appendix 1 of Environment Protection Authority (2016) Ambient Air Quality Assessment, the following Capability Statement is respectfully offered.

**Table G-1 Practitioner capability statement**

Section	Requirements	Reeves Plains Power Station Project
Cover page	Project title	Reeves Plains Power Station Project
	Proponent details	Arcadis Australia Pacific Pty Ltd., on behalf of Alinta Energy (Reeves Plains) Pty Ltd
	Location of the premises	Reeves Plains, South Australia
Primary consulting organisation	Name of the practitioner/s	Gary Graham, Director, Northstar Air Quality Martin Doyle, Director, Northstar Air Quality Marie-Laure Nguyen, AQ Engineer, Northstar Air Quality
	Company name	Northstar Air Quality Pty Ltd
	ACN	609 741 728
	Responsible person	Gary Graham
	Qualifications of relevant staff	Gary Graham, BSc(hons), MSc Martin Doyle, BSc(hons), PhD Marie-Laure Nguyen, M.Physics
	Experience and practitioner affiliation	Gary Graham, 24 years, CSci, CEnv, CAQP (CASANZ) Martin Doyle, 18 years, AAirQual (CASANZ)
	Accreditation (NATA or equivalent)	Marie-Laure Nguyen, 11 years
	Is the accreditation specific to methods	Not applicable
Subcontractors	(a) Monitoring practitioners	None required or used
	(b) Analytical laboratories	None required or used
	(c) Modelling practitioners	Northstar Air Quality Pty Ltd (details as stated above)
Methods used	List of monitoring or analytical method(s) being used for which practitioners have accreditation, or dispersion models for which the practitioners have demonstrated experience	No monitoring or analytical methods were required. The assessment uses the TAPM and AERMOD dispersion models

To further assist with demonstrating that appropriate methods and practices have been adopted, the following key requirements have been addressed:

**Table G-2 Air quality impact assessment requirements**

Reference	Requirement	Response
Section 1.3 Reports and submissions	The EPA has a continuing commitment to assess submissions as soon as possible, so this document sets out how best to present information in a Project. This includes methods, protocols, comparisons against relevant criteria, quality processes that should be used and the range of supporting information needed for reports. It is important that reports are based on these principles and signed off by qualified and experienced senior practitioners.	Reference should be made to the practitioner capability statement
Section 2 Risk-based air quality assessment	To demonstrate that no adverse effects will occur at ground level due to emissions from a proposed or existing facility, owners/operators or proponents of facilities should initially use appropriate conservative models to predict the maximum ground level concentrations (GLCs) of pollutants.	The methodology used for modelling is presented in <b>Section 4.2</b> . The modelling contains a high degree of conservatism, as outlined in <b>Section 4.2</b> and discussed throughout the AQIA.
	Owners/operators or proponents are required to demonstrate that these maximum concentrations are less than the GLCs of pollutants specified in Schedule 2 or odour criteria in Schedule 3 of the Air EPP at sensitive receptor(s). The GLCs are levels of specific pollutants or odours, below which environmental risk can be considered to be acceptable.	Reference should be made to <b>Section 6.2</b> which demonstrates that the predicted concentrations are below the GLCs specified in the Air EPP.
	GLCs adopted under the Air EPP may be based on public health or amenity or may relate to other environmental values, where applicable.	The pollutants assessed during construction and operation are discussed in <b>Section 2.3</b> . The criteria adopted are presented in <b>Section 1.3</b>
	It is expected that existing ambient background concentrations of pollutants are also included into the assessment process, so that total concentrations of specific pollutants are less than their respective GLC. Where applicable, these background concentrations can be based on data from the nearest EPA monitoring station, modelled background levels, baseline monitoring performed for the project or advice from the EPA given on a case-by-case basis.	The assumptions used to assess the contribution of background air quality is discussed in <b>Section 3.3</b> . The results presented in <b>Section 6.2</b> account for the contribution of background air quality.
Section 3 Modelling	The first step in undertaking air quality modelling is to clearly define the objectives and expected outcomes. This can be done by addressing questions such as:	



Reference	Requirement	Response
	<ul style="list-style-type: none"> <li>• What is the reason for the air quality modelling?</li> </ul>	Reference should be made to <b>Section 1.2</b>
	<ul style="list-style-type: none"> <li>• What questions need to be answered by modelling work?</li> </ul>	Reference should be made to <b>Section 1.2</b>
	<ul style="list-style-type: none"> <li>• What pollutants or environmental indicators need to be modelled in order to provide the information required?</li> </ul>	Reference should be made to <b>Section 2.3</b>
	<ul style="list-style-type: none"> <li>• What data and information are already available and how can these help?</li> </ul>	Reference should be made to <b>Section 4.2</b>
	<ul style="list-style-type: none"> <li>• What considerations need to be made about background concentrations of pollutants?</li> </ul>	Reference should be made to <b>Section 3.3</b>
	<ul style="list-style-type: none"> <li>• What type of pollutant source/s need to be modelled?</li> </ul>	Reference should be made to <b>Section 4.2</b>
	<ul style="list-style-type: none"> <li>• What are the geographical features near the pollutant source/s?</li> </ul>	Reference should be made to <b>Section 3.1</b>
	<ul style="list-style-type: none"> <li>• How is the modelled data best utilised and reported to describe the issues under investigation?</li> </ul>	Reference should be made to <b>Section 6.2, and Section 7</b>